

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Michael Zouak
Airtek Environmental Corporation
39 West 38th Street, 12th Floor
New York, NY 10018

Received: 05/09/07 5:05:00 PM
ATC Group #: 24951
Analysis Date: 05/10/07

Fax: (212) 768-0759 Phone: (212) 768-0516

Project: Fiterman Hall, Project# 06-0200
30 West Broadway, New York, NY

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5μ-5	>5μ		(S/mm ²)	(S/cc)	
01 24951-1	1940.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
02 24951-2	1940.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
03 24951-3	1940.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
04 24951-4	1940.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	

MARK PEYSAKHOV

Analyzed by:

MILENA BONEZZI

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Confidentiality Notice:

The document(s) contained herein are confidential and privileged information, intended for the exclusive use of the individual or entity named above.

Liability Notice:

ATC Associates Inc. and its personnel shall not be liable for any misinformation provided to us by the client regarding these samples. This report relates only to samples submitted and analyzed.

Unless otherwise indicated, no blank corrections were performed.

The condition of all samples was acceptable upon receipt.

Unless otherwise indicated all QC results were in control.

The laboratory certifies that the test results meet all requirements of NELAC.

Supplement to test report batch # _____, Amendments: _____, Amendment Dates:

Attn: Mr. Michael Zouak
Airtek Environmental Corporation
39 West 38th Sreet, 12th Floor
New York, NY 10018

Received: 05/09/07 5:05:00 PM
ATC Group #: 24951
Analysis Date: 05/10/07

Fax: (212) 768-0759 Phone: (212) 768-0516

Project: Fiterman Hall, Project# 06-0200
30 West Broadway, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	>5µ		(S/mm ²)	(S/cc)	
05 24951-5	1940.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
06 24951-6	1940.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
07 24951-7	1880.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	

MARK PEYSAKHOV

Analyzed by:



MILENA BONEZZI

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Confidentiality Notice:

The document(s) contained herein are confidential and privileged information, intended for the exclusive use of the individual or entity named above.

Liability Notice:

ATC Associates Inc. and its personnel shall not be liable for any misinformation provided to us by the client regarding these samples. This report relates only to samples submitted and analyzed.

Unless otherwise indicated, no blank corrections were performed.

The condition of all samples was acceptable upon receipt.

Unless otherwise indicated all QC results were in control.

The laboratory certifies that the test results meet all requirements of NELAC.

Supplement to test report batch # _____, Amendments: ____, Amendment Dates:

#24951

PROJECT INFORMATION (fill out ALL information)

CLIENT: DASNY		PROJECT NAME: Fireman Hall		SAMPLING START DATE: 05-09-07	
CLIENT ADDRESS: One Penn Plaza, New York, NY		PROJECT ADDRESS: 30 West Broadway, New York, NY		PROJECT #: 07-0050	
Turnaround Time: 24 HRS	Method: TEM/ AHRA	Laboratory: ATC	PROJECT PHASE: Asbestos Project Monitoring	Comments: Please email results to: cchen@airtekeny.com, benllewis@airtekeny.com, and emackenzie@airtekeny.com	
SAMPLING TECHNICIAN: <i>Dillon Sue</i>		LOT #: 1415			
ROTOMETER #: 3/05A		PROJECT MANAGER: Erin Mackenzie			

Sample #	Sample Media	Sample Location	Total Minutes			Flow Rate (L/min)				Contaminant	Conc.		
			Start	Stop	Total	Leak? Y/N	Start	Leak? Y/N	Final			Leak? Y/N	Avg
FH-01	MCE-25	In the Personal Area	0710	0515	485	04	N	04	N	04	1940	Asbestos	
FH-02	MCE-25	Outside the Personal Area	0711	0516	485	04	N	04	N	04	1940	Asbestos	
FH-03	MCE-25	Inside the waste room	0712	0517	485	04	N	04	N	04	1940	Asbestos	
FH-04	MCE-25	Outside the waste room	0713	0518	485	04	N	04	N	04	1940	Asbestos	
FH-05	MCE-25	Next to Miced trap Exhaust	0714	0519	485	04	N	04	N	04	1940	Asbestos	
FH-06	MCE-25	Next to the Fence	0715	0520	485	04	N	04	N	04	1940	Asbestos	
FH-07	MCE-25	Next to freight elevator entrance	0720	0510	470	04	N	04	N	04	1880	Asbestos	
FH-08	MCE-25	Field Blank										Asbestos	
FH-09	MCE-25	Field Blank										Asbestos	
FH-	MCE-25											Asbestos	

LAB INFORMATION

CHAIN OF CUSTODY		LAB INFORMATION	
Relinquished By (Print/Sign) <i>Dillon Sue</i>	Received By (Print/Sign) <i>R. Kogan</i>	Analyzed By (Print/Sign) <i>[Signature]</i>	Date/Time 05/09/07 17:05
Date/Time 05/09/07	Date/Time 05/09/07	Date/Time 05/09/07	Date/Time 05/09/07