

Submittal Summary - Scaffold Phase Week 15 (08/06/07 to 08/12/07)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Work Shift/Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	Asbestos PCME Concentration (f/cm ³)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											0.0009				
EPA Site Specific Trigger Levels											N/A				
EMSL	FH-080607-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/6/2007	1/Scaffold	2.880	030726579-0001	8/6/2007	8/7/2007	PCME	ASBESTOS	NA	8/7/2007	NA	NA	See Note 1
EMSL	FH-080607-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/6/2007	1/Scaffold	2.880	030726579-0002	8/6/2007	8/7/2007	PCME	ASBESTOS	NA	8/7/2007	NA	NA	See Note 1
EMSL	FH-080607-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/6/2007	1/Scaffold	2.880	030726579-0003	8/6/2007	8/7/2007	PCME	ASBESTOS	NA	8/7/2007	NA	NA	See Note 1
EMSL	FH-080607-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/6/2007	1/Scaffold	2.880	030726579-0004	8/6/2007	8/7/2007	PCME	ASBESTOS	NA	8/7/2007	NA	NA	See Note 1
EMSL	FH-080607-05	#5 - 5TH FL SETBACK ROOF N. SIDE	8/6/2007	1/Scaffold	2.880	030726579-0005	8/6/2007	8/7/2007	PCME	ASBESTOS	NA	8/7/2007	NA	NA	See Note 1
EMSL	FH-080607-06	#6 - 5TH FL SETBACK ROOF SW SIDE	8/6/2007	1/Scaffold	2.880	030726579-0006	8/6/2007	8/7/2007	PCME	ASBESTOS	NA	8/7/2007	NA	NA	See Note 1
EMSL	FH-080707-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/7/2007	1/Scaffold	2.880	030726716-0001	8/7/2007	8/7/2007	PCME	ASBESTOS	<0.00086	8/8/2007	No	No	
EMSL	FH-080707-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/7/2007	1/Scaffold	2.880	030726716-0002	8/7/2007	8/7/2007	PCME	ASBESTOS	<0.00086	8/8/2007	No	No	
EMSL	FH-080707-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/7/2007	1/Scaffold	2.880	030726716-0003	8/7/2007	8/7/2007	PCME	ASBESTOS	<0.00086	8/8/2007	No	No	
EMSL	FH-080707-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/7/2007	1/Scaffold	2.880	030726716-0004	8/7/2007	8/7/2007	PCME	ASBESTOS	<0.00086	8/8/2007	No	No	
EMSL	FH-080707-05	#5 - 5TH FL SETBACK ROOF N. SIDE	8/7/2007	1/Scaffold	2.880	030726716-0005	8/7/2007	8/7/2007	PCME	ASBESTOS	<0.00086	8/8/2007	No	No	
EMSL	FH-080707-06	#6 - 5TH FL SETBACK ROOF SW SIDE	8/7/2007	1/Scaffold	2.880	030726716-0006	8/7/2007	8/7/2007	PCME	ASBESTOS	<0.00086	8/8/2007	No	No	
EMSL	FH-080707-65	DUPLICATE (STATION #1)	8/7/2007	1/Scaffold	2.880	030726716-0007	8/7/2007	8/7/2007	PCME	ASBESTOS	<0.00086	8/8/2007	No	No	
EMSL	FH-080807-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/8/2007	1/Scaffold	2.880	030726854-0001	8/8/2007	8/9/2007	PCME	ASBESTOS	<0.00086	8/9/2007	No	No	
EMSL	FH-080807-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/8/2007	1/Scaffold	2.880	030726854-0002	8/8/2007	8/9/2007	PCME	ASBESTOS	<0.00086	8/9/2007	No	No	
EMSL	FH-080807-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/8/2007	1/Scaffold	2.880	030726854-0003	8/8/2007	8/9/2007	PCME	ASBESTOS	<0.00086	8/9/2007	No	No	
EMSL	FH-080807-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/8/2007	1/Scaffold	2.880	030726854-0004	8/8/2007	8/9/2007	PCME	ASBESTOS	<0.00086	8/9/2007	No	No	
EMSL	FH-080807-05	#5 - 5TH FL SETBACK ROOF N. SIDE	8/8/2007	1/Scaffold	2.880	030726854-0005	8/8/2007	8/9/2007	PCME	ASBESTOS	<0.00086	8/9/2007	No	No	
EMSL	FH-080807-06	#6 - 5TH FL SETBACK ROOF SW SIDE	8/8/2007	1/Scaffold	2.880	030726854-0006	8/8/2007	8/9/2007	PCME	ASBESTOS	<0.00086	8/9/2007	No	No	
EMSL	FH-080907-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/9/2007	1/Scaffold	2.880	030727067-0001	8/9/2007	8/10/2007	PCME	ASBESTOS	<0.00086	8/10/2007	No	No	
EMSL	FH-080907-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/9/2007	1/Scaffold	2.880	030727067-0002	8/9/2007	8/10/2007	PCME	ASBESTOS	<0.00086	8/10/2007	No	No	
EMSL	FH-080907-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/9/2007	1/Scaffold	2.880	030727067-0003	8/9/2007	8/10/2007	PCME	ASBESTOS	<0.00086	8/10/2007	No	No	
EMSL	FH-080907-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/9/2007	1/Scaffold	2.880	030727067-0004	8/9/2007	8/10/2007	PCME	ASBESTOS	<0.00086	8/10/2007	No	No	
EMSL	FH-080907-05	#5 - 5TH FL SETBACK ROOF N. SIDE	8/9/2007	1/Scaffold	2.880	030727067-0005	8/9/2007	8/10/2007	PCME	ASBESTOS	<0.00086	8/10/2007	No	No	
EMSL	FH-080907-06	#6 - 5TH FL SETBACK ROOF SW SIDE	8/9/2007	1/Scaffold	2.880	030727067-0006	8/9/2007	8/10/2007	PCME	ASBESTOS	<0.00086	8/10/2007	No	No	
EMSL	FH-081007-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/10/2007	1/Scaffold	2.880	030727190-0001	8/10/2007	8/11/2007	PCME	ASBESTOS	<0.00086	8/13/2007	No	No	
EMSL	FH-081007-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/10/2007	1/Scaffold	2.880	030727190-0002	8/10/2007	8/11/2007	PCME	ASBESTOS	<0.00086	8/13/2007	No	No	
EMSL	FH-081007-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/10/2007	1/Scaffold	2.880	030727190-0003	8/10/2007	8/11/2007	PCME	ASBESTOS	<0.00086	8/13/2007	No	No	
EMSL	FH-081007-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/10/2007	1/Scaffold	2.880	030727190-0004	8/10/2007	8/11/2007	PCME	ASBESTOS	<0.00086	8/13/2007	No	No	
EMSL	FH-081007-05	#5 - 5TH FL SETBACK ROOF N. SIDE	8/10/2007	1/Scaffold	2.880	030727190-0005	8/10/2007	8/11/2007	PCME	ASBESTOS	<0.00086	8/13/2007	No	No	
EMSL	FH-081007-06	#6 - 5TH FL SETBACK ROOF SW SIDE	8/10/2007	1/Scaffold	2.880	030727190-0006	8/10/2007	8/11/2007	PCME	ASBESTOS	<0.00086	8/13/2007	No	No	
EMSL	FH-081107-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/11/2007	1/Scaffold	2.880	030727418-0001	8/13/2007	8/14/2007	PCME	ASBESTOS	<0.00086	8/15/2007	No	No	
EMSL	FH-081107-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/11/2007	1/Scaffold	2.880	030727418-0002	8/13/2007	8/14/2007	PCME	ASBESTOS	<0.00086	8/15/2007	No	No	
EMSL	FH-081107-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/11/2007	1/Scaffold	2.880	030727418-0003	8/13/2007	8/15/2007	PCME	ASBESTOS	<0.00086	8/15/2007	No	No	
EMSL	FH-081107-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/11/2007	1/Scaffold	2.880	030727418-0004	8/13/2007	8/14/2007	PCME	ASBESTOS	<0.00086	8/15/2007	No	No	
EMSL	FH-081107-05	#5 - 5TH FL SETBACK ROOF N. SIDE	8/11/2007	1/Scaffold	2.880	030727418-0005	8/13/2007	8/14/2007	PCME	ASBESTOS	<0.00086	8/15/2007	No	No	
EMSL	FH-081107-06	#6 - 5TH FL SETBACK ROOF SW SIDE	8/11/2007	1/Scaffold	2.880	030727418-0006	8/13/2007	8/14/2007	PCME	ASBESTOS	<0.00086	8/15/2007	No	No	
EMSL	FH-081207-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/12/2007	1/Scaffold	2.880	030727416-0001	8/13/2007	8/14/2007	PCME	ASBESTOS	<0.00086	8/15/2007	No	No	
EMSL	FH-081207-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/12/2007	1/Scaffold	2.880	030727416-0002	8/13/2007	8/14/2007	PCME	ASBESTOS	<0.00086	8/15/2007	No	No	
EMSL	FH-081207-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/12/2007	1/Scaffold	2.880	030727416-0003	8/13/2007	8/14/2007	PCME	ASBESTOS	<0.00086	8/15/2007	No	No	
EMSL	FH-081207-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/12/2007	1/Scaffold	2.880	030727416-0004	8/13/2007	8/14/2007	PCME	ASBESTOS	<0.00086	8/15/2007	No	No	
EMSL	FH-081207-05	#5 - 5TH FL SETBACK ROOF N. SIDE	8/12/2007	1/Scaffold	2.880	030727416-0005	8/13/2007	8/14/2007	PCME	ASBESTOS	<0.00086	8/15/2007	No	No	
EMSL	FH-081207-06	#6 - 5TH FL SETBACK ROOF SW SIDE	8/12/2007	1/Scaffold	2.880	030727416-0006	8/13/2007	8/15/2007	PCME	ASBESTOS	<0.00086	8/15/2007	No	No	

Note 1: Samples were overloaded with particulates and were analyzed with Modified VDI-Rechtlinien (VDI-3492) Method. No asbestos was detected.

Submittal Summary - Scaffold Phase Week 15 (08/06/07 to 08/12/07)

Lab Name	Airetek Field Sample No.	Sample Location	Collection Start Date	Work Shift/Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	Asbestos AHERA Concentration (S/mm ³)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											N/A				
EPA Site Specific Trigger Levels											70				
EMSL	FH-080607-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/6/2007	1/Scaffold	2.880	030726579-0001	8/6/2007	8/7/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	NA	8/7/2007	NA	NA	See Note 1
EMSL	FH-080607-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/6/2007	1/Scaffold	2.880	030726579-0002	8/6/2007	8/7/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	NA	8/7/2007	NA	NA	See Note 1
EMSL	FH-080607-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/6/2007	1/Scaffold	2.880	030726579-0003	8/6/2007	8/7/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	NA	8/7/2007	NA	NA	See Note 1
EMSL	FH-080607-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/6/2007	1/Scaffold	2.880	030726579-0004	8/6/2007	8/7/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	NA	8/7/2007	NA	NA	See Note 1
EMSL	FH-080607-05	#5 - 5TH FL SETBACK ROOF N. SIDE	8/6/2007	1/Scaffold	2.880	030726579-0005	8/6/2007	8/7/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	NA	8/7/2007	NA	NA	See Note 1
EMSL	FH-080607-06	#6 - 5TH FL SETBACK ROOF SW SIDE	8/6/2007	1/Scaffold	2.880	030726579-0006	8/6/2007	8/7/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	NA	8/7/2007	NA	NA	See Note 1
EMSL	FH-080707-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/7/2007	1/Scaffold	2.880	030726716-0001	8/7/2007	8/7/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/8/2007	No	No	
EMSL	FH-080707-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/7/2007	1/Scaffold	2.880	030726716-0002	8/7/2007	8/7/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/8/2007	No	No	
EMSL	FH-080707-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/7/2007	1/Scaffold	2.880	030726716-0003	8/7/2007	8/7/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/8/2007	No	No	
EMSL	FH-080707-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/7/2007	1/Scaffold	2.880	030726716-0004	8/7/2007	8/7/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/8/2007	No	No	
EMSL	FH-080707-05	#5 - 5TH FL SETBACK ROOF N. SIDE	8/7/2007	1/Scaffold	2.880	030726716-0005	8/7/2007	8/7/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/8/2007	No	No	
EMSL	FH-080707-06	#6 - 5TH FL SETBACK ROOF SW SIDE	8/7/2007	1/Scaffold	2.880	030726716-0006	8/7/2007	8/7/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/8/2007	No	No	
EMSL	FH-080707-65	DUPLICATE (STATION #1)	8/7/2007	1/Scaffold	2.880	030726716-0007	8/7/2007	8/7/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/8/2007	No	No	
EMSL	FH-080807-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/8/2007	1/Scaffold	2.880	030726854-0001	8/8/2007	8/9/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/9/2007	No	No	
EMSL	FH-080807-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/8/2007	1/Scaffold	2.880	030726854-0002	8/8/2007	8/9/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/9/2007	No	No	
EMSL	FH-080807-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/8/2007	1/Scaffold	2.880	030726854-0003	8/8/2007	8/9/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/9/2007	No	No	
EMSL	FH-080807-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/8/2007	1/Scaffold	2.880	030726854-0004	8/8/2007	8/9/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/9/2007	No	No	
EMSL	FH-080807-05	#5 - 5TH FL SETBACK ROOF N. SIDE	8/8/2007	1/Scaffold	2.880	030726854-0005	8/8/2007	8/9/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/9/2007	No	No	
EMSL	FH-080807-06	#6 - 5TH FL SETBACK ROOF SW SIDE	8/8/2007	1/Scaffold	2.880	030726854-0006	8/8/2007	8/9/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/9/2007	No	No	
EMSL	FH-080907-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/9/2007	1/Scaffold	2.880	030727067-0001	8/9/2007	8/10/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/10/2007	No	No	
EMSL	FH-080907-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/9/2007	1/Scaffold	2.880	030727067-0002	8/9/2007	8/10/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/10/2007	No	No	
EMSL	FH-080907-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/9/2007	1/Scaffold	2.880	030727067-0003	8/9/2007	8/10/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/10/2007	No	No	
EMSL	FH-080907-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/9/2007	1/Scaffold	2.880	030727067-0004	8/9/2007	8/10/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/10/2007	No	No	
EMSL	FH-080907-05	#5 - 5TH FL SETBACK ROOF N. SIDE	8/9/2007	1/Scaffold	2.880	030727067-0005	8/9/2007	8/10/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/10/2007	No	No	
EMSL	FH-080907-06	#6 - 5TH FL SETBACK ROOF SW SIDE	8/9/2007	1/Scaffold	2.880	030727067-0006	8/9/2007	8/10/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/10/2007	No	No	
EMSL	FH-081007-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/10/2007	1/Scaffold	2.880	030727190-0001	8/10/2007	8/11/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/11/2007	No	No	
EMSL	FH-081007-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/10/2007	1/Scaffold	2.880	030727190-0002	8/10/2007	8/11/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/11/2007	No	No	
EMSL	FH-081007-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/10/2007	1/Scaffold	2.880	030727190-0003	8/10/2007	8/11/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/11/2007	No	No	
EMSL	FH-081007-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/10/2007	1/Scaffold	2.880	030727190-0004	8/10/2007	8/11/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/11/2007	No	No	
EMSL	FH-081007-05	#5 - 5TH FL SETBACK ROOF N. SIDE	8/10/2007	1/Scaffold	2.880	030727190-0005	8/10/2007	8/11/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/11/2007	No	No	
EMSL	FH-081007-06	#6 - 5TH FL SETBACK ROOF SW SIDE	8/10/2007	1/Scaffold	2.880	030727190-0006	8/10/2007	8/11/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/11/2007	No	No	
EMSL	FH-081107-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/11/2007	1/Scaffold	2.880	030727418-0001	8/13/2007	8/14/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/15/2007	No	No	
EMSL	FH-081107-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/11/2007	1/Scaffold	2.880	030727418-0002	8/13/2007	8/14/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/15/2007	No	No	
EMSL	FH-081107-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/11/2007	1/Scaffold	2.880	030727418-0003	8/13/2007	8/15/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/15/2007	No	No	
EMSL	FH-081107-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/11/2007	1/Scaffold	2.880	030727418-0004	8/13/2007	8/14/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/15/2007	No	No	
EMSL	FH-081107-05	#5 - 5TH FL SETBACK ROOF N. SIDE	8/11/2007	1/Scaffold	2.880	030727418-0005	8/13/2007	8/14/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/15/2007	No	No	
EMSL	FH-081107-06	#6 - 5TH FL SETBACK ROOF SW SIDE	8/11/2007	1/Scaffold	2.880	030727418-0006	8/13/2007	8/14/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/15/2007	No	No	
EMSL	FH-081207-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/12/2007	1/Scaffold	2.880	030727416-0001	8/13/2007	8/14/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/15/2007	No	No	
EMSL	FH-081207-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/12/2007	1/Scaffold	2.880	030727416-0002	8/13/2007	8/14/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/15/2007	No	No	
EMSL	FH-081207-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/12/2007	1/Scaffold	2.880	030727416-0003	8/13/2007	8/14/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/15/2007	No	No	
EMSL	FH-081207-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/12/2007	1/Scaffold	2.880	030727416-0004	8/13/2007	8/14/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/15/2007	No	No	
EMSL	FH-081207-05	#5 - 5TH FL SETBACK ROOF N. SIDE	8/12/2007	1/Scaffold	2.880	030727416-0005	8/13/2007	8/14/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/15/2007	No	No	
EMSL	FH-081207-06	#6 - 5TH FL SETBACK ROOF SW SIDE	8/12/2007	1/Scaffold	2.880	030727416-0006	8/13/2007	8/15/2007	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	8/15/2007	No	No	

Note 1: Samples were overloaded with particulates and were analyzed with Modified VDI-Rechtlinien (VDI-3492) Method. No asbestos was detected.

Submittal Summary - Scaffold Phase Week 15 (08/06/07 to 08/12/07)

Airtek Field Sample No.	Sampling Location	Real-time Readings Date	Collection time (minutes)	Analyte	Analytical Method	Instrument	Particulate PM 2.5 (ug/m ³)	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels							40			
EPA Site Specific Trigger Levels							65			
FH-080607-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/6/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	25.96	No	No	
FH-080607-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/6/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	33.88	No	No	
FH-080607-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/6/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	38.87	No	No	
FH-080607-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/6/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	35.66	No	No	
FH-080607-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	8/6/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	30.81	No	No	
FH-080607-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	8/6/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	27.17	No	No	
FH-080607-TEOM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/6/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	23.15	No	No	
FH-080707-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/7/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	38.17	No	No	
FH-080707-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/7/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	38.77	No	No	
FH-080707-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/7/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	39.24	No	No	
FH-080707-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/7/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	33.88	No	No	
FH-080707-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	8/7/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	32.06	No	No	
FH-080707-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	8/7/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	38.13	No	No	
FH-080707-TEOM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/7/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	32.53	No	No	
FH-080807-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/8/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	31.42	No	No	
FH-080807-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/8/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	31.79	No	No	
FH-080807-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/8/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	29.40	No	No	
FH-080807-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/8/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	24.88	No	No	
FH-080807-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	8/8/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	20.38	No	No	
FH-080807-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	8/8/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	31.74	No	No	
FH-080807-TEOM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/8/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	23.86	No	No	
FH-080907-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/9/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	9.39	No	No	
FH-080907-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/9/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	11.90	No	No	
FH-080907-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/9/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	32.72	No	No	
FH-080907-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/9/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	25.72	No	No	
FH-080907-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	8/9/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	21.92	No	No	
FH-080907-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	8/9/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	11.20	No	No	
FH-080907-TEOM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/9/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	7.58	No	No	
FH-081007-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/10/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	11.38	No	No	
FH-081007-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/10/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	15.74	No	No	
FH-081007-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/10/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	13.97	No	No	
FH-081007-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/10/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	19.92	No	No	
FH-081007-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	8/10/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	16.36	No	No	
FH-081007-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	8/10/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	12.27	No	No	
FH-081007-TEOM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/10/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	3.70	No	No	
FH-081107-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/11/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	5.53	No	No	
FH-081107-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/11/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	9.13	No	No	
FH-081107-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/11/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	21.24	No	No	
FH-081107-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/11/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	19.56	No	No	
FH-081107-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	8/11/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	21.94	No	No	
FH-081107-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	8/11/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	6.17	No	No	
FH-081107-TEOM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/11/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	6.92	No	No	
FH-081207-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/12/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	10.84	No	No	
FH-081207-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/12/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	13.49	No	No	
FH-081207-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/12/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	29.44	No	No	
FH-081207-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/12/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	23.60	No	No	
FH-081207-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	8/12/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	22.97	No	No	
FH-081207-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	8/12/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	12.03	No	No	
FH-081207-TEOM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/12/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	10.61	No	No	

Submittal Summary - Scaffold Phase Week 15 (08/06/07 to 08/12/07)

Airtek Field Sample No.	Sampling Location	Real-time Readings Date	Collection time (minutes)	Analyte	Analytical Method	Instrument	Particulate PM 10 (ug/m ³)	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
							150			
Target Air Quality Levels										
EPA Site Specific Trigger Levels							150			
FH-080607-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/6/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	55.10	No	No	
FH-080607-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/6/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	37.10	No	No	
FH-080607-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/6/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	38.89	No	No	
FH-080607-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/6/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	38.07	No	No	
FH-080607-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	8/6/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	32.78	No	No	
FH-080607-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	8/6/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	36.56	No	No	
FH-080607-TEOM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/6/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	46.82	No	No	
FH-080707-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/7/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	56.12	No	No	
FH-080707-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/7/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	64.49	No	No	
FH-080707-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/7/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	63.25	No	No	
FH-080707-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/7/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	63.50	No	No	
FH-080707-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	8/7/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	56.96	No	No	
FH-080707-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	8/7/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	51.86	No	No	
FH-080707-TEOM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/7/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	71.94	No	No	
FH-080807-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/8/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	61.06	No	No	
FH-080807-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/8/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	56.76	No	No	
FH-080807-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/8/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	68.41	No	No	
FH-080807-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/8/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	58.35	No	No	
FH-080807-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	8/8/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	66.63	No	No	
FH-080807-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	8/8/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	70.83	No	No	
FH-080807-TEOM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/8/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	56.62	No	No	
FH-080907-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/9/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	38.72	No	No	
FH-080907-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/9/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	18.29	No	No	
FH-080907-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/9/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	28.83	No	No	
FH-080907-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/9/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	20.02	No	No	
FH-080907-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	8/9/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	20.77	No	No	
FH-080907-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	8/9/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	18.87	No	No	
FH-080907-TEOM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/9/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	27.65	No	No	
FH-081007-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/10/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	33.94	No	No	
FH-081007-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/10/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	23.06	No	No	
FH-081007-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/10/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	29.51	No	No	
FH-081007-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/10/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	24.31	No	No	
FH-081007-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	8/10/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	22.10	No	No	
FH-081007-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	8/10/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	32.03	No	No	
FH-081007-TEOM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/10/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	12.58	No	No	
FH-081107-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/11/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	31.18	No	No	
FH-081107-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/11/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	10.81	No	No	
FH-081107-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/11/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	14.65	No	No	
FH-081107-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/11/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	10.20	No	No	
FH-081107-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	8/11/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	9.66	No	No	
FH-081107-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	8/11/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	11.28	No	No	
FH-081107-TEOM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/11/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	16.47	No	No	
FH-081207-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/12/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	25.73	No	No	
FH-081207-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	8/12/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	17.97	No	No	
FH-081207-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/12/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	28.99	No	No	
FH-081207-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	8/12/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	17.62	No	No	
FH-081207-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	8/12/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	15.99	No	No	
FH-081207-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	8/12/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	18.03	No	No	
FH-081207-TEOM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	8/12/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	26.54	No	No	

Submittal Summary - Scaffold Phase Week 15 (08/06/07 to 08/12/07)

Lab Name	Airetek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	Mercury-Total Concentration (ng/m3)	Unit	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
											300					
											3,000					
EPA Site Specific Trigger Levels																
BRL	FH-080607-11	#1 - Sidewalk bridge level NW corner	08/06/2007	Scaffold	0.576	07BR1149-01	08/08/2007	08/09/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/13/2007	No	No	
BRL	FH-080607-12	#2 - Sidewalk bridge level SW corner	08/06/2007	Scaffold	0.576	07BR1149-02	08/08/2007	08/09/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/13/2007	No	No	
BRL	FH-080607-13	#3 - Sidewalk bridge level SE corner	08/06/2007	Scaffold	0.576	07BR1149-03	08/08/2007	08/09/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/13/2007	No	No	
BRL	FH-080607-14	#4 - Sidewalk bridge level NE corner	08/06/2007	Scaffold	0.576	07BR1149-04	08/08/2007	08/09/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/13/2007	No	No	
BRL	FH-080607-15	#5 - 5th floor setback roof N side	08/06/2007	Scaffold	0.576	07BR1149-05	08/08/2007	08/09/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/13/2007	No	No	
BRL	FH-080607-16	#6 - 5th floor setback roof SW side	08/06/2007	Scaffold	0.576	07BR1149-06	08/08/2007	08/09/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/13/2007	No	No	
BRL	FH-080707-11	#1 - Sidewalk bridge level NW corner	08/07/2007	Scaffold	0.5760	07BR1157-01	08/09/2007	08/10/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/14/2007	No	No	
BRL	FH-080707-12	#2 - Sidewalk bridge level SW corner	08/07/2007	Scaffold	0.5760	07BR1157-02	08/09/2007	08/10/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/14/2007	No	No	
BRL	FH-080707-13	#3 - Sidewalk bridge level SE corner	08/07/2007	Scaffold	0.5760	07BR1157-03	08/09/2007	08/10/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/14/2007	No	No	
BRL	FH-080707-14	#4 - Sidewalk bridge level NE corner	08/07/2007	Scaffold	0.5760	07BR1157-04	08/09/2007	08/10/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/14/2007	No	No	
BRL	FH-080707-15	#5 - 5th floor setback roof N side	08/07/2007	Scaffold	0.5760	07BR1157-05	08/09/2007	08/10/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/14/2007	No	No	
BRL	FH-080707-16	#6 - 5th floor setback roof SW side	08/07/2007	Scaffold	0.5760	07BR1157-06	08/09/2007	08/10/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/14/2007	No	No	
BRL	FH-080707-66	Duplicate (Station #1)	08/07/2007	Scaffold	0.5760	07BR1157-08	08/09/2007	08/10/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/14/2007	No	No	
BRL	FH-080807-11	#1 - Sidewalk bridge level NW corner	08/08/2007	Scaffold	0.5760	07BR1166-01	08/10/2007	08/13/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/15/2007	No	No	
BRL	FH-080807-12	#2 - Sidewalk bridge level SW corner	08/08/2007	Scaffold	0.5760	07BR1166-02	08/10/2007	08/13/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/15/2007	No	No	
BRL	FH-080807-13	#3 - Sidewalk bridge level SE corner	08/08/2007	Scaffold	0.5760	07BR1166-03	08/10/2007	08/13/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/15/2007	No	No	
BRL	FH-080807-14	#4 - Sidewalk bridge level NE corner	08/08/2007	Scaffold	0.5760	07BR1166-04	08/10/2007	08/13/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/15/2007	No	No	
BRL	FH-080807-15	#5 - 5th floor setback roof N side	08/08/2007	Scaffold	0.5760	07BR1166-05	08/10/2007	08/13/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/15/2007	No	No	
BRL	FH-080807-16	#6 - 5th floor setback roof SW side	08/08/2007	Scaffold	0.5760	07BR1166-06	08/10/2007	08/13/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/15/2007	No	No	
BRL	FH-080907-11	#1 - Sidewalk bridge level NW corner	08/09/2007	Scaffold	0.5760	0733001-01	08/11/2007	08/14/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/16/2007	No	No	
BRL	FH-080907-12	#2 - Sidewalk bridge level SW corner	08/09/2007	Scaffold	0.5760	0733001-02	08/11/2007	08/14/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/16/2007	No	No	
BRL	FH-080907-13	#3 - Sidewalk bridge level SE corner	08/09/2007	Scaffold	0.5760	0733001-03	08/11/2007	08/14/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/16/2007	No	No	
BRL	FH-080907-14	#4 - Sidewalk bridge level NE corner	08/09/2007	Scaffold	0.5760	0733001-04	08/11/2007	08/14/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/16/2007	No	No	
BRL	FH-080907-15	#5 - 5th floor setback roof N side	08/09/2007	Scaffold	0.5760	0733001-05	08/11/2007	08/14/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/16/2007	No	No	
BRL	FH-080907-16	#6 - 5th floor setback roof SW side	08/09/2007	Scaffold	0.5760	0733001-06	08/11/2007	08/14/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/16/2007	No	No	
BRL	FH-081007-11	#1 - Sidewalk bridge level NW corner	08/10/2007	Scaffold	0.5760	0733006-01	08/14/2007	08/16/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/17/2007	No	No	
BRL	FH-081007-12	#2 - Sidewalk bridge level SW corner	08/10/2007	Scaffold	0.5760	0733006-02	08/14/2007	08/16/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/17/2007	No	No	
BRL	FH-081007-13	#3 - Sidewalk bridge level SE corner	08/10/2007	Scaffold	0.5760	0733006-03	08/14/2007	08/16/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/17/2007	No	No	
BRL	FH-081007-14	#4 - Sidewalk bridge level NE corner	08/10/2007	Scaffold	0.5760	0733006-04	08/14/2007	08/16/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/17/2007	No	No	
BRL	FH-081007-15	#5 - 5th floor setback roof N side	08/10/2007	Scaffold	0.5760	0733006-05	08/14/2007	08/16/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/17/2007	No	No	
BRL	FH-081007-16	#6 - 5th floor setback roof SW side	08/10/2007	Scaffold	0.5760	0733006-06	08/14/2007	08/16/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/17/2007	No	No	
BRL	FH-081107-11	#1 - Sidewalk bridge level NW corner	08/11/2007	Scaffold	0.5760	0733007-01	08/14/2007	08/16/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/17/2007	No	No	
BRL	FH-081107-12	#2 - Sidewalk bridge level SW corner	08/11/2007	Scaffold	0.5760	0733007-02	08/14/2007	08/16/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/17/2007	No	No	
BRL	FH-081107-13	#3 - Sidewalk bridge level SE corner	08/11/2007	Scaffold	0.5760	0733007-03	08/14/2007	08/16/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/17/2007	No	No	
BRL	FH-081107-14	#4 - Sidewalk bridge level NE corner	08/11/2007	Scaffold	0.5760	0733007-04	08/14/2007	08/16/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/17/2007	No	No	
BRL	FH-081107-15	#5 - 5th floor setback roof N side	08/11/2007	Scaffold	0.5760	0733007-05	08/14/2007	08/16/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/17/2007	No	No	
BRL	FH-081107-16	#6 - 5th floor setback roof SW side	08/11/2007	Scaffold	0.5760	0733007-06	08/14/2007	08/16/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/17/2007	No	No	
BRL	FH-081207-11	#1 - Sidewalk bridge level NW corner	08/12/2007	Scaffold	0.5760	0733008-01	08/14/2007	08/16/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/17/2007	No	No	
BRL	FH-081207-12	#2 - Sidewalk bridge level SW corner	08/12/2007	Scaffold	0.5760	0733008-02	08/14/2007	08/16/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/17/2007	No	No	
BRL	FH-081207-13	#3 - Sidewalk bridge level SE corner	08/12/2007	Scaffold	0.5760	0733008-03	08/14/2007	08/16/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/17/2007	No	No	
BRL	FH-081207-14	#4 - Sidewalk bridge level NE corner	08/12/2007	Scaffold	0.5760	0733008-04	08/14/2007	08/17/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/17/2007	No	No	
BRL	FH-081207-15	#5 - 5th floor setback roof N side	08/12/2007	Scaffold	0.5760	0733008-05	08/14/2007	08/17/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/17/2007	No	No	
BRL	FH-081207-16	#6 - 5th floor setback roof SW side	08/12/2007	Scaffold	0.5760	0733008-06	08/14/2007	08/17/2007	EPA 324/1631	Hg	<26.0	ng/m ³	08/17/2007	No	No	

Submittal Summary - Scaffold Phase Week 15 (08/06/07 to 08/12/07)

Ohio Lumex Daily Mercury Readings

all readings are in ng/m³

Target air quality level: 300 ng/m³

USEPA site specific mercury trigger level: 3000 ng/m³

Exceedances: None

Exceedances: None

3 Site Tours Conducted per Work Shift

DATE: 08/06/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:												
PERIMETER OF BUILDING	0900-0905 1200-1205 1500-1505	Tour 1	19	20	20	21	21	24	21	21	22	21	21	21	21.00
		Tour 2	21	21	21	20	20	19	21	21	21	21	21	20	20.58
		Tour 3	20	20	20	19	21	21	22	22	19	19	19	20	20.17
5th FLOOR SETBACK ROOF PERIMETER	0910-0915 1210-1215 1510-1515	Tour 1	24	25	25	26	26	25	25	24	23	25	24	23	24.58
		Tour 2	25	25	26	27	25	25	25	24	25	26	26	27	25.50
		Tour 3	26	26	27	26	25	25	24	24	23	24	26	25	25.08
ROOF PERIMETER	0925-0930 1225-1230 1525-1530	Tour 1	27	29	29	31	31	31	30	30	31	32	33	33	30.58
		Tour 2	31	31	31	30	29	28	30	30	30	31	31	33	30.42
		Tour 3	32	33	33	34	33	31	31	31	32	30	31	31	31.83

DATE: 08/07/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:												
PERIMETER OF BUILDING	0900-0905 1200-1205 1500-1505	Tour 1	19	19	20	21	19	20	20	21	21	20	20	20	20.00
		Tour 2	20	21	20	21	20	21	22	21	22	22	23	22	21.25
		Tour 3	20	20	20	20	21	21	22	22	23	22	21	21	21.08
5th FLOOR SETBACK ROOF PERIMETER	0910-0915 1210-1215 1510-1515	Tour 1	24	24	25	25	26	26	25	25	24	24	25	25	24.83
		Tour 2	25	26	26	27	27	26	25	25	24	25	24	24	25.33
		Tour 3	25	25	25	26	26	25	25	27	27	26	25	25	25.58
ROOF PERIMETER	0925-0930 1225-1230 1525-1530	Tour 1	29	29	30	30	31	31	34	32	34	31	30	31	31.00
		Tour 2	30	31	31	31	32	32	29	33	31	31	31	31	31.08
		Tour 3	30	30	30	31	30	29	30	32	32	32	34	32	30.92

DATE: 08/08/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:												
PERIMETER OF BUILDING	0900-0905 1200-1205 1500-1505	Tour 1	20	21	21	21	21	22	22	21	21	19	21	21	20.92
		Tour 2	20	20	19	21	21	20	21	21	21	22	21	21	20.67
		Tour 3	20	20	20	20	19	21	20	20	21	21	21	21	20.33
5th FLOOR SETBACK ROOF PERIMETER	0910-0915 1210-1215 1510-1515	Tour 1	25	26	26	26	25	26	26	27	27	28	29	27	26.50
		Tour 2	25	25	25	24	25	24	25	26	26	27	26	27	25.42
		Tour 3	28	27	27	26	27	28	28	27	28	27	26	26	27.08
ROOF PERIMETER	0925-0930 1225-1230 1525-1530	Tour 1	31	31	31	32	33	29	30	29	31	31	31	31	30.83
		Tour 2	31	32	32	33	31	33	31	30	30	30	29	30	31.00
		Tour 3	31	31	31	33	33	32	31	31	31	30	31	30	31.25

DATE: 08/09/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:												
PERIMETER OF BUILDING	0900-0905 1200-1205 1500-1505	Tour 1	22	22	24	23	22	22	21	21	20	22	21	20	21.67
		Tour 2	21	21	20	20	21	21	22	21	20	19	19	20	20.42
		Tour 3	21	20	20	20	20	21	21	23	22	21	20	20	20.75
5th FLOOR SETBACK ROOF PERIMETER	0910-0915 1210-1215 1510-1515	Tour 1	25	25	24	25	26	26	25	25	24	24	25	25	24.92
		Tour 2	25	26	26	25	26	27	27	26	25	25	25	25	25.67
		Tour 3	24	24	24	26	26	26	25	25	27	26	24	23	25.00
ROOF PERIMETER	0925-0930 1225-1230 1525-1530	Tour 1	31	30	31	31	30	30	31	31	30	33	34	33	31.25
		Tour 2	30	29	30	30	30	32	32	32	31	32	31	31	30.83
		Tour 3	32	30	30	31	29	31	32	34	33	32	32	32	31.50

DATE: 08/10/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:												
PERIMETER OF BUILDING	0900-0905 1200-1205 1500-1505	Tour 1	19	19	20	20	19	21	20	20	21	21	22	22	20.33
		Tour 2	20	21	21	21	20	21	22	22	22	22	21	21	21.17
		Tour 3	20	20	20	20	19	19	21	21	21	20	20	21	20.25
5th FLOOR SETBACK ROOF PERIMETER	0910-0915 1210-1215 1510-1515	Tour 1	24	24	24	25	23	23	24	25	26	26	26	26	24.58
		Tour 2	26	25	25	26	23	24	25	26	27	27	26	25	25.42
		Tour 3	25	25	26	26	27	26	28	27	26	25	25	24	25.83
ROOF PERIMETER	0925-0930 1225-1230 1525-1530	Tour 1	29	30	29	31	30	31	32	32	32	31	32	31	30.83
		Tour 2	29	29	30	30	30	32	32	31	32	35	33	31	31.17
		Tour 3	31	32	33	31	31	32	31	33	31	32	31	32	31.67

DATE: 08/11/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:												
PERIMETER OF BUILDING	0900-0905 1200-1205 1500-1505	Tour 1	19	19	19	29	21	21	20	21	21	20	20	20	20.83
		Tour 2	20	20	21	21	21	22	21	20	20	21	19	19	20.42
		Tour 3	19	20	20	21	22	22	22	21	21	20	20	20	20.67
5th FLOOR SETBACK ROOF PERIMETER	0910-0915 1210-1215 1510-1515	Tour 1	24	25	25	24	24	25	23	23	24	24	24	25	24.17
		Tour 2	24	24	24	24	25	23	23	24	25	25	26	25	24.33
		Tour 3	25	24	25	25	24	23	24	25	26	25	25	25	24.67
ROOF PERIMETER	0925-0930 1225-1230 1525-1530	Tour 1	29	29	30	30	31	30	32	31	31	33	32	32	30.83
		Tour 2	30	29	29	30	30	32	32	34	33	32	31	31	31.08
		Tour 3	30	30	31	31	31	32	32	31	30	31	31	30	30.83

DATE: 08/12/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:												
PERIMETER OF BUILDING	0900-0905 1200-1205 1500-1505	Tour 1	20	20	21	21	21	19	19	19	20	20	19	19	19.83
		Tour 2	19	19	19	20	21	21	21	22	22	21	20	21	20.50
		Tour 3	20	21	20	20	19	19	22	21	22	22	21	21	20.67
5th FLOOR SETBACK ROOF PERIMETER	0910-0915 1210-1215 1510-1515	Tour 1	24	25	24	26	26	25	25	24	23	23	25	24	24.50
		Tour 2	25	25	25	27	27	26	25	26	25	24	25	25	25.42
		Tour 3	25	24	24	24	25	25	26	26	24	24	24	24	24.58
ROOF PERIMETER	0925-0930 1225-1230 1525-1530	Tour 1	31	31	30	31	31	33	33	33	32	31	31	31	31.50
		Tour 2	29	28	30	30	32	31	31	31	32	32	31	31	30.67
		Tour 3	30	30	30	31	30	30	31	32	32	32	32	32	31.00

Submittal Summary - Scaffold Phase Week 15 (08/06/07 to 08/12/07)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Work Shift/Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	Silica-Quartz Concentration (ug/m3)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											10				
EPA Site Specific Trigger Levels											10				
EMSL	FH-080607-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	08/06/2007	Scaffold	0.960	040718909-0001	08/07/2007	08/08/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/09/2007	No	No	
EMSL	FH-080607-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	08/06/2007	Scaffold	0.960	040718909-0002	08/07/2007	08/08/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/09/2007	No	No	
EMSL	FH-080607-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	08/06/2007	Scaffold	0.960	040718909-0003	08/07/2007	08/08/2007	NIOSH 7500 XRD	Silica-Quartz	10	08/09/2007	No	No	
EMSL	FH-080607-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	08/06/2007	Scaffold	0.960	040718909-0004	08/07/2007	08/08/2007	NIOSH 7500 XRD	Silica-Quartz	5	08/09/2007	No	No	
EMSL	FH-080607-33	#5 - 5TH FL SETBACK ROOF N. SIDE	08/06/2007	Scaffold	0.960	040718909-0005	08/07/2007	08/08/2007	NIOSH 7500 XRD	Silica-Quartz	6	08/09/2007	No	No	
EMSL	FH-080607-34	#6 - 5TH FL SETBACK ROOF SW SIDE	08/06/2007	Scaffold	0.960	040718909-0006	08/07/2007	08/08/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/09/2007	No	No	
EMSL	FH-080707-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	08/07/2007	Scaffold	0.960	040719045-0001	08/08/2007	08/09/2007	NIOSH 7500 XRD	Silica-Quartz	5	08/10/2007	No	No	
EMSL	FH-080707-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	08/07/2007	Scaffold	0.960	040719045-0002	08/08/2007	08/09/2007	NIOSH 7500 XRD	Silica-Quartz	5	08/10/2007	No	No	
EMSL	FH-080707-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	08/07/2007	Scaffold	0.960	040719045-0003	08/08/2007	08/09/2007	NIOSH 7500 XRD	Silica-Quartz	13	08/10/2007	Yes	Yes	See Note 1
EMSL	FH-080707-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	08/07/2007	Scaffold	0.960	040719045-0004	08/08/2007	08/09/2007	NIOSH 7500 XRD	Silica-Quartz	6	08/10/2007	No	No	
EMSL	FH-080707-33	#5 - 5TH FL SETBACK ROOF N. SIDE	08/07/2007	Scaffold	0.960	040719045-0005	08/08/2007	08/09/2007	NIOSH 7500 XRD	Silica-Quartz	6	08/10/2007	No	No	
EMSL	FH-080707-34	#6 - 5TH FL SETBACK ROOF SW SIDE	08/07/2007	Scaffold	0.960	040719045-0006	08/08/2007	08/09/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/10/2007	No	No	
EMSL	FH-080707-68	DUPLICATE (STATION #1)	08/07/2007	Scaffold	0.960	040719045-0008	08/08/2007	08/09/2007	NIOSH 7500 XRD	Silica-Quartz	9	08/10/2007	No	No	
EMSL	FH-080807-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	08/08/2007	Scaffold	0.960	040719201-0001	08/09/2007	08/09/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/10/2007	No	No	
EMSL	FH-080807-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	08/08/2007	Scaffold	0.960	040719201-0002	08/09/2007	08/09/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/10/2007	No	No	
EMSL	FH-080807-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	08/08/2007	Scaffold	0.960	040719201-0003	08/09/2007	08/09/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/10/2007	No	No	
EMSL	FH-080807-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	08/08/2007	Scaffold	0.960	040719201-0004	08/09/2007	08/09/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/10/2007	No	No	
EMSL	FH-080807-33	#5 - 5TH FL SETBACK ROOF N. SIDE	08/08/2007	Scaffold	0.960	040719201-0005	08/09/2007	08/09/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/10/2007	No	No	
EMSL	FH-080807-34	#6 - 5TH FL SETBACK ROOF SW SIDE	08/08/2007	Scaffold	0.960	040719201-0006	08/09/2007	08/09/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/10/2007	No	No	
EMSL	FH-080907-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	08/09/2007	Scaffold	0.960	040719329-0001	08/10/2007	08/10/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/11/2007	No	No	
EMSL	FH-080907-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	08/09/2007	Scaffold	0.960	040719329-0002	08/10/2007	08/10/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/11/2007	No	No	
EMSL	FH-080907-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	08/09/2007	Scaffold	0.960	040719329-0003	08/10/2007	08/10/2007	NIOSH 7500 XRD	Silica-Quartz	5	08/11/2007	No	No	
EMSL	FH-080907-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	08/09/2007	Scaffold	0.960	040719329-0004	08/10/2007	08/10/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/11/2007	No	No	
EMSL	FH-080907-33	#5 - 5TH FL SETBACK ROOF N. SIDE	08/09/2007	Scaffold	0.960	040719329-0005	08/10/2007	08/10/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/11/2007	No	No	
EMSL	FH-080907-34	#6 - 5TH FL SETBACK ROOF SW SIDE	08/09/2007	Scaffold	0.960	040719329-0006	08/10/2007	08/10/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/11/2007	No	No	
EMSL	FH-081007-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	08/10/2007	Scaffold	0.960	040719442-0001	08/11/2007	08/13/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/14/2007	No	No	
EMSL	FH-081007-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	08/10/2007	Scaffold	0.960	040719442-0002	08/11/2007	08/13/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/14/2007	No	No	
EMSL	FH-081007-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	08/10/2007	Scaffold	0.960	040719442-0003	08/11/2007	08/13/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/14/2007	No	No	
EMSL	FH-081007-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	08/10/2007	Scaffold	0.960	040719442-0004	08/11/2007	08/13/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/14/2007	No	No	
EMSL	FH-081007-33	#5 - 5TH FL SETBACK ROOF N. SIDE	08/10/2007	Scaffold	0.960	040719442-0005	08/11/2007	08/13/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/14/2007	No	No	
EMSL	FH-081007-34	#6 - 5TH FL SETBACK ROOF SW SIDE	08/10/2007	Scaffold	0.960	040719442-0006	08/11/2007	08/13/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/14/2007	No	No	
EMSL	FH-081107-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	08/11/2007	Scaffold	0.960	040719630-0001	08/14/2007	05/15/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/16/2007	No	No	
EMSL	FH-081107-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	08/11/2007	Scaffold	0.960	040719630-0002	08/14/2007	05/15/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/16/2007	No	No	
EMSL	FH-081107-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	08/11/2007	Scaffold	0.960	040719630-0003	08/14/2007	05/15/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/16/2007	No	No	
EMSL	FH-081107-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	08/11/2007	Scaffold	0.960	040719630-0004	08/14/2007	05/15/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/16/2007	No	No	
EMSL	FH-081107-33	#5 - 5TH FL SETBACK ROOF N. SIDE	08/11/2007	Scaffold	0.960	040719630-0005	08/14/2007	05/15/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/16/2007	No	No	
EMSL	FH-081107-34	#6 - 5TH FL SETBACK ROOF SW SIDE	08/11/2007	Scaffold	0.960	040719630-0006	08/14/2007	05/15/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/16/2007	No	No	
EMSL	FH-081207-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	08/12/2007	Scaffold	0.960	040719629-0001	08/14/2007	08/15/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/16/2007	No	No	
EMSL	FH-081207-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	08/12/2007	Scaffold	0.960	040719629-0002	08/14/2007	08/15/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/16/2007	No	No	
EMSL	FH-081207-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	08/12/2007	Scaffold	0.960	040719629-0003	08/14/2007	08/15/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/16/2007	No	No	
EMSL	FH-081207-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	08/12/2007	Scaffold	0.960	040719629-0004	08/14/2007	08/15/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/16/2007	No	No	
EMSL	FH-081207-33	#5 - 5TH FL SETBACK ROOF N. SIDE	08/12/2007	Scaffold	0.960	040719629-0005	08/14/2007	08/15/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/16/2007	No	No	
EMSL	FH-081207-34	#6 - 5TH FL SETBACK ROOF SW SIDE	08/12/2007	Scaffold	0.960	040719629-0006	08/14/2007	08/15/2007	NIOSH 7500 XRD	Silica-Quartz	<5	08/16/2007	No	No	

Note 1: Exceedances reported to USEPA

Submittal Summary - Scaffold Phase Week 15 (08/06/07 to 08/12/07)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	Dioxin/Furans Concentration (ng/m ³)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											0.00025				
EPA Site Specific Trigger Levels											0.025				
STL-SAC	FH-081207-40	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/12/2007	Scaffold	360	G7H140330003	08/14/2007	08/19/2007	TO-9	Toxicity Equivalent Quotient (TEQ)	0.00020	08/28/2007	No	No	

Submittal Summary - Scaffold Phase Week 15 (08/06/07 to 08/12/07)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	PAHs Concentration (ug/m3)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											0.034				
EPA Site Specific Trigger Levels											3.4				
STL-SAC	FH-081207-49	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/12/2007	Scaffold	360	G7H140329003	08/14/2007	08/20/2007	8270C SIM	BAP-equivalent	<0.007	08/27/2007	No	No	

Submittal Summary - Scaffold Phase Week 15 (08/06/07 to 08/12/07)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	PCBs Concentration (ug/m3)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											0.12				
EPA Site Specific Trigger Levels											12				
STL-SAC	FH-081207-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/12/2007	Scaffold	360	G7H140328003	08/14/2007	08/24/2007	TO-4	Aroclor 1016	<0.0021	08/28/2007	No	No	
STL-SAC	FH-081207-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/12/2007	Scaffold	360	G7H140328003	08/14/2007	08/24/2007	TO-4	Aroclor 1221	<0.0021	08/28/2007	No	No	
STL-SAC	FH-081207-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/12/2007	Scaffold	360	G7H140328003	08/14/2007	08/24/2007	TO-4	Aroclor 1232	<0.0021	08/28/2007	No	No	
STL-SAC	FH-081207-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/12/2007	Scaffold	360	G7H140328003	08/14/2007	08/24/2007	TO-4	Aroclor 1242	0.0049	08/28/2007	No	No	
STL-SAC	FH-081207-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/12/2007	Scaffold	360	G7H140328003	08/14/2007	08/24/2007	TO-4	Aroclor 1248	<0.0021	08/28/2007	No	No	
STL-SAC	FH-081207-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/12/2007	Scaffold	360	G7H140328003	08/14/2007	08/24/2007	TO-4	Aroclor 1254	<0.0021	08/28/2007	No	No	
STL-SAC	FH-081207-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	8/12/2007	Scaffold	360	G7H140328003	08/14/2007	08/24/2007	TO-4	Aroclor 1260	<0.0021	08/28/2007	No	No	