

Submittal Summary - Scaffold Phase Week 23 (10/01/07 to 10/07/07)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Work Shift/Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	Asbestos PCME Concentration (f/cm ³)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels															
EPA Site Specific Trigger Levels															
											0.0009				
											N/A				
EMSL	FH-100107-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	10/1/2007	1/Scaffold	2.880	030732620-0001	10/1/2007	10/2/2007	PCME	ASBESTOS	<0.00086	10/2/2007	No	No	
EMSL	FH-100107-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	10/1/2007	1/Scaffold	2.880	030732620-0002	10/1/2007	10/2/2007	PCME	ASBESTOS	<0.00086	10/2/2007	No	No	
EMSL	FH-100107-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	10/1/2007	1/Scaffold	2.880	030732620-0003	10/1/2007	10/2/2007	PCME	ASBESTOS	<0.00086	10/2/2007	No	No	
EMSL	FH-100107-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	10/1/2007	1/Scaffold	2.880	030732620-0004	10/1/2007	10/2/2007	PCME	ASBESTOS	<0.00086	10/2/2007	No	No	
EMSL	FH-100107-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	10/1/2007	1/Scaffold	2.880	030732620-0005	10/1/2007	10/2/2007	PCME	ASBESTOS	<0.00086	10/2/2007	No	No	
EMSL	FH-100107-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	10/1/2007	1/Scaffold	2.880	030732620-0006	10/1/2007	10/2/2007	PCME	ASBESTOS	<0.00086	10/2/2007	No	No	
EMSL	FH-100107-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	10/1/2007	1/Scaffold	2.880	030732620-0007	10/1/2007	10/2/2007	PCME	ASBESTOS	<0.00086	10/2/2007	No	No	
EMSL	FH-100107-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	10/1/2007	1/Scaffold	2.880	030732620-0008	10/1/2007	10/2/2007	PCME	ASBESTOS	<0.00086	10/2/2007	No	No	
EMSL	FH-100207-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	10/2/2007	1/Scaffold	2.880	030732738-0001	10/2/2007	10/3/2007	PCME	ASBESTOS	<0.00086	10/3/2007	No	No	
EMSL	FH-100207-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	10/2/2007	1/Scaffold	2.880	030732738-0002	10/2/2007	10/3/2007	PCME	ASBESTOS	<0.00086	10/3/2007	No	No	
EMSL	FH-100207-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	10/2/2007	1/Scaffold	2.880	030732738-0003	10/2/2007	10/3/2007	PCME	ASBESTOS	<0.00086	10/3/2007	No	No	
EMSL	FH-100207-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	10/2/2007	1/Scaffold	2.880	030732738-0004	10/2/2007	10/3/2007	PCME	ASBESTOS	<0.00086	10/3/2007	No	No	
EMSL	FH-100207-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	10/2/2007	1/Scaffold	2.880	030732738-0005	10/2/2007	10/3/2007	PCME	ASBESTOS	<0.00086	10/3/2007	No	No	
EMSL	FH-100207-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	10/2/2007	1/Scaffold	2.880	030732738-0006	10/2/2007	10/3/2007	PCME	ASBESTOS	<0.00086	10/3/2007	No	No	
EMSL	FH-100207-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	10/2/2007	1/Scaffold	2.880	030732738-0007	10/2/2007	10/3/2007	PCME	ASBESTOS	<0.00086	10/3/2007	No	No	
EMSL	FH-100207-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	10/2/2007	1/Scaffold	2.880	030732738-0008	10/2/2007	10/3/2007	PCME	ASBESTOS	<0.00086	10/3/2007	No	No	
EMSL	FH-100207-65	DUPLICATE (STATION #1)	10/2/2007	1/Scaffold	2.880	030732738-0009	10/2/2007	10/3/2007	PCME	ASBESTOS	<0.00086	10/3/2007	No	No	
EMSL	FH-100307-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	10/3/2007	1/Scaffold	2.880	030732865-0001	10/3/2007	10/4/2007	PCME	ASBESTOS	<0.00086	10/4/2007	No	No	
EMSL	FH-100307-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	10/3/2007	1/Scaffold	2.880	030732865-0002	10/3/2007	10/4/2007	PCME	ASBESTOS	<0.00086	10/4/2007	No	No	
EMSL	FH-100307-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	10/3/2007	1/Scaffold	2.880	030732865-0003	10/3/2007	10/4/2007	PCME	ASBESTOS	<0.00086	10/4/2007	No	No	
EMSL	FH-100307-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	10/3/2007	1/Scaffold	2.880	030732865-0004	10/3/2007	10/4/2007	PCME	ASBESTOS	<0.00086	10/4/2007	No	No	
EMSL	FH-100307-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	10/3/2007	1/Scaffold	2.880	030732865-0005	10/3/2007	10/4/2007	PCME	ASBESTOS	<0.00086	10/4/2007	No	No	
EMSL	FH-100307-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	10/3/2007	1/Scaffold	2.880	030732865-0006	10/3/2007	10/4/2007	PCME	ASBESTOS	<0.00086	10/4/2007	No	No	
EMSL	FH-100307-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	10/3/2007	1/Scaffold	2.880	030732865-0007	10/3/2007	10/4/2007	PCME	ASBESTOS	<0.00086	10/4/2007	No	No	
EMSL	FH-100307-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	10/3/2007	1/Scaffold	2.880	030732865-0008	10/3/2007	10/4/2007	PCME	ASBESTOS	<0.00086	10/4/2007	No	No	
EMSL	FH-100407-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	10/4/2007	1/Scaffold	2.880	030732945-0001	10/4/2007	10/5/2007	PCME	ASBESTOS	<0.00086	10/5/2007	No	No	
EMSL	FH-100407-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	10/4/2007	1/Scaffold	2.880	030732945-0002	10/4/2007	10/5/2007	PCME	ASBESTOS	<0.00086	10/5/2007	No	No	
EMSL	FH-100407-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	10/4/2007	1/Scaffold	2.880	030732945-0003	10/4/2007	10/5/2007	PCME	ASBESTOS	<0.00086	10/5/2007	No	No	
EMSL	FH-100407-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	10/4/2007	1/Scaffold	2.880	030732945-0004	10/4/2007	10/5/2007	PCME	ASBESTOS	<0.00086	10/5/2007	No	No	
EMSL	FH-100407-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	10/4/2007	1/Scaffold	2.880	030732945-0005	10/4/2007	10/5/2007	PCME	ASBESTOS	<0.00086	10/5/2007	No	No	
EMSL	FH-100407-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	10/4/2007	1/Scaffold	2.880	030732945-0006	10/4/2007	10/5/2007	PCME	ASBESTOS	<0.00086	10/5/2007	No	No	
EMSL	FH-100407-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	10/4/2007	1/Scaffold	2.880	030732945-0007	10/4/2007	10/5/2007	PCME	ASBESTOS	<0.00086	10/5/2007	No	No	
EMSL	FH-100407-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	10/4/2007	1/Scaffold	2.880	030732945-0008	10/4/2007	10/5/2007	PCME	ASBESTOS	<0.00086	10/5/2007	No	No	
EMSL	FH-100507-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	10/5/2007	1/Scaffold	2.880	030733084-0001	10/5/2007	10/6/2007	PCME	ASBESTOS	NA	10/6/2007	N/A	N/A	See Note 1
EMSL	FH-100507-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	10/5/2007	1/Scaffold	2.880	030733084-0002	10/5/2007	10/6/2007	PCME	ASBESTOS	NA	10/6/2007	N/A	N/A	See Note 1
EMSL	FH-100507-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	10/5/2007	1/Scaffold	2.880	030733084-0003	10/5/2007	10/6/2007	PCME	ASBESTOS	NA	10/6/2007	N/A	N/A	See Note 1
EMSL	FH-100507-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	10/5/2007	1/Scaffold	2.880	030733084-0004	10/5/2007	10/6/2007	PCME	ASBESTOS	NA	10/6/2007	N/A	N/A	See Note 1
EMSL	FH-100507-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	10/5/2007	1/Scaffold	2.880	030733084-0005	10/5/2007	10/6/2007	PCME	ASBESTOS	NA	10/6/2007	N/A	N/A	See Note 1
EMSL	FH-100507-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	10/5/2007	1/Scaffold	2.880	030733084-0006	10/5/2007	10/6/2007	PCME	ASBESTOS	<0.00086	10/6/2007	No	No	
EMSL	FH-100507-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	10/5/2007	1/Scaffold	2.880	030733084-0007	10/5/2007	10/6/2007	PCME	ASBESTOS	<0.00086	10/6/2007	No	No	
EMSL	FH-100507-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	10/5/2007	1/Scaffold	2.880	030733084-0008	10/5/2007	10/6/2007	PCME	ASBESTOS	NA	10/6/2007	N/A	N/A	See Note 1
EMSL	FH-100607-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	10/6/2007	1/Scaffold	2.880	030733233-0001	10/8/2007	10/9/2007	PCME	ASBESTOS	<0.00086	10/9/2007	No	No	
EMSL	FH-100607-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	10/6/2007	1/Scaffold	2.880	030733233-0002	10/8/2007	10/9/2007	PCME	ASBESTOS	<0.00086	10/9/2007	No	No	
EMSL	FH-100607-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	10/6/2007	1/Scaffold	2.880	030733233-0003	10/8/2007	10/9/2007	PCME	ASBESTOS	<0.00086	10/9/2007	No	No	
EMSL	FH-100607-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	10/6/2007	1/Scaffold	2.880	030733233-0004	10/8/2007	10/9/2007	PCME	ASBESTOS	<0.00086	10/9/2007	No	No	
EMSL	FH-100607-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	10/6/2007	1/Scaffold	2.880	030733233-0005	10/8/2007	10/9/2007	PCME	ASBESTOS	<0.00086	10/9/2007	No	No	
EMSL	FH-100607-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	10/6/2007	1/Scaffold	2.880	030733233-0006	10/8/2007	10/9/2007	PCME	ASBESTOS	<0.00086	10/9/2007	No	No	
EMSL	FH-100607-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	10/6/2007	1/Scaffold	2.880	030733233-0007	10/8/2007	10/9/2007	PCME	ASBESTOS	<0.00086	10/9/2007	No	No	
EMSL	FH-100607-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	10/6/2007	1/Scaffold	2.880	030733233-0008	10/8/2007	10/9/2007	PCME	ASBESTOS	<0.00086	10/9/2007	No	No	
EMSL	FH-100707-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	10/7/2007	1/Scaffold	2.880	030733236-0001	10/8/2007	10/9/2007	PCME	ASBESTOS	NA	10/9/2007	N/A	N/A	See Note 1
EMSL	FH-100707-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	10/7/2007	1/Scaffold	2.880	030733236-0002	10/8/2007	10/9/2007	PCME	ASBESTOS	NA	10/9/2007	N/A	N/A	See Note 1
EMSL	FH-100707-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	10/7/2007	1/Scaffold	2.880	030733236-0003	10/8/2007	10/9/2007	PCME	ASBESTOS	NA	10/9/2007	N/A	N/A	See Note 1
EMSL	FH-100707-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	10/7/2007	1/Scaffold	2.880	030733236-0004	10/8/2007	10/9/2007	PCME	ASBESTOS	NA	10/9/2007	N/A	N/A	See Note 1
EMSL	FH-100707-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	10/7/2007	1/Scaffold	2.880	030733236-0005	10/8/2007	10/9/2007	PCME	ASBESTOS	NA	10/9/2007	N/A	N/A	See Note 1
EMSL	FH-100707-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	10/7/2007	1/Scaffold	2.880	030733236-0006	10/8/2007	10/9/2007	PCME	ASBESTOS	NA	10/9/2007	N/A	N/A	See Note 1
EMSL	FH-100707-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	10/7/2007	1/Scaffold	2.880	030733236-0007	10/8/2007	10/9/2007	PCME	ASBESTOS	NA	10/9/2007	N/A	N/A	See Note 1
EMSL	FH-100707-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	10/7/2007	1/Scaffold	2.880	030733236-0008	10/8/2007	10/9/2007	PCME	ASBESTOS	NA	10/9/2007	N/A	N/A	See Note 1

Note 1: Sample was overloaded with particulates and was analyzed with Modified VDI-Rechtlinien (VDI-3492) Method. No asbestos was detected.

Submission Summary - Scaffold Phase Week 23 (10/01/07 to 10/07/07)

Ohio Lumex Daily Mercury Readings

all readings are in ng/m³

Target air quality level: 300 ng/m³

USEPA site specific mercury trigger level: 3000 ng/m³

Exceedances: None
Exceedances: None

3 Site Tours Conducted per Work Shift

DATE: 10/1/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	21	21	20	21	21	20	19	19	21	21	21	20	20.42	
	1200-1205	Tour 2	21	21	20	21	21	20	20	19	20	19	19	20		20.08
	1500-1505	Tour 3	25	26	20	21	21	21	22	23	23	23	21	21		22.25
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	25	25	26	26	27	26	25	26	25	27	27	28	26.08	
	1210-1215	Tour 2	26	26	27	26	28	28	29	26	27	27	27	26		26.92
	1510-1515	Tour 3	26	26	27	28	25	25	26	27	26	28	26	26		26.33
ROOF PERIMETER	0925-0930	Tour 1	31	31	30	31	32	31	32	33	33	31	31	31	31.42	
	1225-1230	Tour 2	29	29	28	29	31	31	31	30	31	32	31	31		30.25
	1525-1530	Tour 3	30	30	31	31	33	32	31	32	33	31	31	31		31.33

DATE: 10/2/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	21	21	20	21	22	23	23	22	21	21	20	19	21.17	
	1200-1205	Tour 2	20	20	20	19	19	20	21	21	23	23	23	21		20.83
	1500-1505	Tour 3	20	21	21	21	20	21	20	19	19	19	21	21		20.25
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	25	25	24	25	26	26	26	25	26	26	27	28	25.75	
	1210-1215	Tour 2	27	27	26	26	27	26	23	21	21	22	26	29		25.08
	1510-1515	Tour 3	27	26	26	25	26	27	26	26	27	26	27	28		26.42
ROOF PERIMETER	0925-0930	Tour 1	31	31	29	28	31	31	31	31	31	32	31	31	30.67	
	1225-1230	Tour 2	31	31	32	30	30	19	18	21	21	21	32	31		26.42
	1525-1530	Tour 3	32	31	31	31	31	31	29	28	28	27	29	31		29.92

DATE: 10/3/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	20	21	21	21	21	20	19	19	21	21	21	20	20.42	
	1200-1205	Tour 2	19	18	18	19	21	21	21	20	19	19	21	21		19.75
	1500-1505	Tour 3	20	19	19	21	21	20	20	20	19	21	21	21		20.17
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	25	26	27	27	26	26	25	24	24	24	23	26	25.25	
	1210-1215	Tour 2	26	26	26	26	27	27	25	26	26	26	23	24		25.67
	1510-1515	Tour 3	27	27	27	26	26	27	25	25	26	27	23	23		25.75
ROOF PERIMETER	0925-0930	Tour 1	29	30	29	29	30	31	31	32	33	29	28	29	30.00	
	1225-1230	Tour 2	29	29	30	30	31	30	30	29	31	28	27	28		29.33
	1525-1530	Tour 3	30	30	31	31	32	33	31	29	28	28	27	28		29.83

DATE: 10/4/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	22	21	21	21	20	21	22	23	20	19	19	21	20.83	
	1200-1205	Tour 2	21	22	21	22	23	23	24	23	20	19	19	19		21.33
	1500-1505	Tour 3	24	23	23	22	21	21	21	21	20	19	21	21		21.42
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	24	25	25	25	26	25	25	26	27	26	27	24	25.42	
	1210-1215	Tour 2	24	23	24	25	25	26	27	27	28	27	26	25		25.58
	1510-1515	Tour 3	24	23	22	22	22	21	22	23	24	24	25	26		23.17
ROOF PERIMETER	0925-0930	Tour 1	31	31	30	31	31	31	30	29	28	31	34	33	30.83	
	1225-1230	Tour 2	31	31	29	31	31	31	29	30	31	31	31	31		30.58
	1525-1530	Tour 3	34	35	31	31	31	32	31	31	32	32	31	31		31.83

DATE: 10/5/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	21	21	20	20	19	20	21	21	22	23	21	20	20.75	
	1200-1205	Tour 2	21	21	21	22	21	20	20	20	21	21	20	19		20.58
	1500-1505	Tour 3	21	19	19	18	19	21	21	21	20	19	19	18		19.58
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	26	25	25	26	27	26	26	25	26	27	27	26	26.00	
	1210-1215	Tour 2	28	26	26	26	27	26	26	23	26	26	26	25		25.92
	1510-1515	Tour 3	28	28	27	26	26	26	23	26	26	25	25	24		25.83
ROOF PERIMETER	0925-0930	Tour 1	31	31	30	31	30	31	31	29	28	29	31	31	30.25	
	1225-1230	Tour 2	31	32	32	31	31	30	29	30	28	28	29	31		30.17
	1525-1530	Tour 3	32	31	31	31	23	28	28	31	31	28	28	31		29.42

DATE: 10/6/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	19	19	29	21	21	21	20	23	23	22	22	22	21.83	
	1200-1205	Tour 2	20	20	21	21	20	19	19	21	21	21	22	22		20.58
	1500-1505	Tour 3	20	19	19	21	21	20	20	20	21	19	19	21		20.00
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	24	25	26	25	24	25	28	25	25	25	24	25	25.08	
	1210-1215	Tour 2	25	25	25	26	24	24	26	26	25	25	24	25.00		
	1510-1515	Tour 3	24	24	25	25	23	25	24	25	25	26	25	25		24.67
ROOF PERIMETER	0925-0930	Tour 1	29	31	31	29	30	30	29	33	33	32	31	31	30.75	
	1225-1230	Tour 2	30	30	30	29	30	31	34	32	32	31	32	31		31.00
	1525-1530	Tour 3	31	30	30	31	31	33	33	29	31	30	32	32		31.08

DATE: 10/7/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	21	20	20	19	20	21	21	20	23	21	20	21	20.58	
	1200-1205	Tour 2	20	20	19	19	21	21	20	22	22	21	21	20		20.50
	1500-1505	Tour 3	19	19	20	19	21	21	20	23	21	21	22	21		20.58
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	24	24	26	26	24	25	25	26	27	24	25	27	25.25	
	1210-1215	Tour 2	25	24	24	25	25	26	26	24	24	25	25	25		24.83
	1510-1515	Tour 3	24	25	26	26	25	26	25	24	25	25	26	25		25.17
ROOF PERIMETER	0925-0930	Tour 1	29	30	31	30	30	30	31	29	29	33	32	31	30.42	
	1225-1230	Tour 2	31	31	33	33	30	30	31	30	30	29	31	32		30.92
	1525-1530	Tour 3	36	32	32	31	30	30	30	29	29	33	33	31		31.33

Submittal Summary - Scaffold Phase Week 23 (10/01/07 to 10/07/07)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	Dioxin/Furans Concentration (ng/m ³)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											0.00025				
EPA Site Specific Trigger Levels											0.025				
STL-SAC	FH-100607-41	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	10/6/2007	Scaffold	360	G7J090333004	10/09/2007	10/17/2007	TO-9	Toxicity Equivalent Quotient (TEQ)	0.00011	10/23/2007	No	No	

Submittal Summary - Scaffold Phase Week 23 (10/01/07 to 10/07/07)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	PAHs Concentration (ug/m3)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											0.034				
EPA Site Specific Trigger Levels											3.4				
STL-SAC	FH-100607-50	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	10/6/2007	Scaffold	360	G7J090334004	10/09/2007	10/15/2007	8270C SIM	BAP-equivalent	<0.007	10/23/2007	No	No	

Submittal Summary - Scaffold Phase Week 23 (10/01/07 to 10/07/07)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	PCBs Concentration (ug/m3)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											0.12				
EPA Site Specific Trigger Levels											12				
STL-SAC	FH-100607-59	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	10/6/2007	Scaffold	360	G7J090335004	10/09/2007	10/22/2007	TO-4	Aroclor 1016	<0.0021	10/23/2007	No	No	
STL-SAC	FH-100607-59	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	10/6/2007	Scaffold	360	G7J090335004	10/09/2007	10/22/2007	TO-4	Aroclor 1221	<0.0021	10/23/2007	No	No	
STL-SAC	FH-100607-59	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	10/6/2007	Scaffold	360	G7J090335004	10/09/2007	10/22/2007	TO-4	Aroclor 1232	<0.0021	10/23/2007	No	No	
STL-SAC	FH-100607-59	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	10/6/2007	Scaffold	360	G7J090335004	10/09/2007	10/22/2007	TO-4	Aroclor 1242	0.0050	10/23/2007	No	No	
STL-SAC	FH-100607-59	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	10/6/2007	Scaffold	360	G7J090335004	10/09/2007	10/22/2007	TO-4	Aroclor 1248	<0.0021	10/23/2007	No	No	
STL-SAC	FH-100607-59	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	10/6/2007	Scaffold	360	G7J090335004	10/09/2007	10/22/2007	TO-4	Aroclor 1254	<0.0021	10/23/2007	No	No	
STL-SAC	FH-100607-59	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	10/6/2007	Scaffold	360	G7J090335004	10/09/2007	10/22/2007	TO-4	Aroclor 1260	<0.0021	10/23/2007	No	No	