





**Submittal Summary - Scaffold Phase Week 27 (10/29/07 to 11/04/07)**

Airetek Field Sample No.	Sampling Location	Real-time Readings Date	Collection time (minutes)	Analyte	Analytical Method	Instrument	Particulate PM 2.5 (ug/m <sup>3</sup> )	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
							40			
							65			
<b>EPA Site Specific Trigger Levels</b>										
FH-102907-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	10/29/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	4.94	No	No	
FH-102907-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	10/29/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	7.83	No	No	
FH-102907-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	10/29/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	21.03	No	No	
FH-102907-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	10/29/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	28.58	No	No	
FH-102907-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	10/29/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	16.47	No	No	
FH-102907-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	10/29/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	6.00	No	No	
FH-102907-EBAM2.5-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	10/29/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	26.68	No	No	
FH-102907-EBAM2.5-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	10/29/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	8.31	No	No	
FH-102907-TEOM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	10/29/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	8.17	No	No	
FH-103007-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	10/30/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	15.10	No	No	
FH-103007-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	10/30/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	17.92	No	No	
FH-103007-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	10/30/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	27.80	No	No	
FH-103007-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	10/30/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	17.48	No	No	
FH-103007-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	10/30/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	32.50	No	No	
FH-103007-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	10/30/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	16.42	No	No	
FH-103007-EBAM2.5-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	10/30/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	35.98	No	No	
FH-103007-EBAM2.5-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	10/30/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	21.48	No	No	
FH-103007-TEOM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	10/30/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	19.15	No	No	
FH-103107-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	10/31/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	23.35	No	No	
FH-103107-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	10/31/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	23.58	No	No	
FH-103107-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	10/31/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	34.63	No	No	
FH-103107-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	10/31/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	23.85	No	No	
FH-103107-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	10/31/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	22.61	No	No	
FH-103107-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	10/31/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	23.82	No	No	
FH-103107-EBAM2.5-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	10/31/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	27.53	No	No	
FH-103107-EBAM2.5-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	10/31/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	25.74	No	No	
FH-103107-TEOM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	10/31/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	23.70	No	No	
FH-110107-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/1/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	10.58	No	No	
FH-110107-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/1/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	12.34	No	No	
FH-110107-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/1/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	25.59	No	No	
FH-110107-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/1/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	13.06	No	No	
FH-110107-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/1/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	13.26	No	No	
FH-110107-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	11/1/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	10.26	No	No	
FH-110107-EBAM2.5-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	11/1/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	19.06	No	No	
FH-110107-EBAM2.5-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	11/1/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	15.76	No	No	
FH-110107-TEOM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/1/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	13.98	No	No	
FH-110207-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/2/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	5.69	No	No	
FH-110207-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/2/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	7.50	No	No	
FH-110207-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/2/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	21.56	No	No	
FH-110207-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/2/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	12.95	No	No	
FH-110207-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/2/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	26.69	No	No	
FH-110207-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	11/2/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	6.17	No	No	
FH-110207-EBAM2.5-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	11/2/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	24.32	No	No	
FH-110207-EBAM2.5-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	11/2/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	7.35	No	No	
FH-110207-TEOM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/2/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	8.48	No	No	
FH-110307-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/3/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	3.49	No	No	
FH-110307-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/3/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	6.13	No	No	
FH-110307-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/3/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	16.67	No	No	
FH-110307-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/3/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	7.80	No	No	
FH-110307-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/3/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	4.49	No	No	
FH-110307-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	11/3/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	4.49	No	No	
FH-110307-EBAM2.5-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	11/3/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	25.46	No	No	
FH-110307-EBAM2.5-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	11/3/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	7.21	No	No	
FH-110307-TEOM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/3/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	5.06	No	No	
FH-110407-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/4/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	10.11	No	No	
FH-110407-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/4/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	11.07	No	No	
FH-110407-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/4/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	24.03	No	No	
FH-110407-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/4/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	14.38	No	No	
FH-110407-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/4/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	22.81	No	No	
FH-110407-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	11/4/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	10.33	No	No	
FH-110407-EBAM2.5-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	11/4/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	29.86	No	No	
FH-110407-EBAM2.5-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	11/4/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	10.28	No	No	
FH-110407-TEOM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/4/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	14.40	No	No	

**Submittal Summary - Scaffold Phase Week 27 (10/29/07 to 11/04/07)**

Airtek Field Sample No.	Sampling Location	Real-time Readings Date	Collection time (minutes)	Analyte	Analytical Method	Instrument	Particulate PM 10 (ug/m <sup>3</sup> )	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
							150			
							150			
<b>Target Air Quality Levels</b>										
<b>EPA Site Specific Trigger Levels</b>										
FH-102907-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	10/29/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	16.09	No	No	
FH-102907-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	10/29/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	10.38	No	No	
FH-102907-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	10/29/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	18.31	No	No	
FH-102907-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	10/29/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	9.16	No	No	
FH-102907-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	10/29/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	8.65	No	No	
FH-102907-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	10/29/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	11.30	No	No	
FH-102907-EBAM10-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	10/29/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	22.60	No	No	
FH-102907-EBAM10-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	10/29/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	12.90	No	No	
FH-102907-TEOM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	10/29/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	12.94	No	No	
FH-103007-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	10/30/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	28.29	No	No	
FH-103007-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	10/30/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	24.81	No	No	
FH-103007-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	10/30/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	26.52	No	No	
FH-103007-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	10/30/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	21.14	No	No	
FH-103007-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	10/30/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	20.98	No	No	
FH-103007-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	10/30/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	24.17	No	No	
FH-103007-EBAM10-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	10/30/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	28.63	No	No	
FH-103007-EBAM10-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	10/30/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	20.94	No	No	
FH-103007-TEOM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	10/30/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	26.99	No	No	
FH-103107-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	10/31/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	29.94	No	No	
FH-103107-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	10/31/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	35.49	No	No	
FH-103107-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	10/31/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	43.49	No	No	
FH-103107-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	10/31/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	35.06	No	No	
FH-103107-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	10/31/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	33.63	No	No	
FH-103107-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	10/31/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	33.35	No	No	
FH-103107-EBAM10-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	10/31/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	34.38	No	No	
FH-103107-EBAM10-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	10/31/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	28.08	No	No	
FH-103107-TEOM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	10/31/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	24.71	No	No	
FH-110107-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/1/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	11.04	No	No	
FH-110107-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/1/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	13.47	No	No	
FH-110107-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/1/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	22.23	No	No	
FH-110107-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/1/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	19.24	No	No	
FH-110107-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/1/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	19.69	No	No	
FH-110107-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	11/1/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	29.51	No	No	
FH-110107-EBAM10-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	11/1/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	19.96	No	No	
FH-110107-EBAM10-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	11/1/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	16.76	No	No	
FH-110107-TEOM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/1/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	16.83	No	No	
FH-110207-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/2/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	9.74	No	No	
FH-110207-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/2/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	10.50	No	No	
FH-110207-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/2/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	14.85	No	No	
FH-110207-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/2/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	15.17	No	No	
FH-110207-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/2/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	11.50	No	No	
FH-110207-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	11/2/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	26.65	No	No	
FH-110207-EBAM10-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	11/2/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	16.00	No	No	
FH-110207-EBAM10-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	11/2/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	10.86	No	No	
FH-110207-TEOM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/2/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	14.72	No	No	
FH-110307-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/3/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	23.01	No	No	
FH-110307-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/3/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	7.99	No	No	
FH-110307-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/3/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	10.82	No	No	
FH-110307-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/3/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	11.31	No	No	
FH-110307-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/3/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	9.01	No	No	
FH-110307-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	11/3/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	9.26	No	No	
FH-110307-EBAM10-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	11/3/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	12.07	No	No	
FH-110307-EBAM10-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	11/3/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	8.17	No	No	
FH-110307-TEOM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/3/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	10.65	No	No	
FH-110407-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/4/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	17.14	No	No	
FH-110407-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/4/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	12.94	No	No	
FH-110407-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/4/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	18.52	No	No	
FH-110407-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/4/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	17.38	No	No	
FH-110407-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/4/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	14.13	No	No	
FH-110407-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	11/4/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	13.99	No	No	
FH-110407-EBAM10-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	11/4/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	18.15	No	No	
FH-110407-EBAM10-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	11/4/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	15.59	No	No	
FH-110407-TEOM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/4/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	14.86	No	No	



**Submittal Summary - Scaffold Phase Week 27 (10/29/07 to 11/04/07)**

Ohio Lumex Daily Mercury Readings

all readings are in ng/m<sup>3</sup>

Target air quality level: 300 ng/m<sup>3</sup>

USEPA site specific mercury trigger level: 3000 ng/m<sup>3</sup>

Exceedances: None  
Exceedances: None

3 Site Tours Conducted per Work Shift

**DATE: 10/29/2007**

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	19	19	19	20	19	21	19	20	20	20	21	19	19.67	
	1200-1205	Tour 2	20	20	19	20	20	19	21	19	20	21	20	20		19.92
	1500-1505	Tour 3	19	21	20	21	20	19	19	20	20	19	21	21		20.00
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	24	24	24	25	24	24	25	23	25	25	24	24	24.25	
	1210-1215	Tour 2	25	25	25	26	24	25	24	24	26	26	25	25		25.00
	1510-1515	Tour 3	23	23	26	27	25	25	24	25	23	23	24	24		24.33
ROOF PERIMETER	0925-0930	Tour 1	29	31	30	30	29	29	29	31	30	31	29	29	29.75	
	1225-1230	Tour 2	30	30	35	35	32	30	31	31	31	32	31	31		31.58
	1525-1530	Tour 3	33	33	31	32	30	31	31	30	31	31	30	32		31.25

**DATE: 10/30/2007**

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	19	19	19	21	21	22	23	21	20	19	20	21	20.42	
	1200-1205	Tour 2	20	21	20	19	19	20	20	21	22	22	21	21		20.50
	1500-1505	Tour 3	19	20	19	20	20	20	19	19	21	21	22	22		20.17
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	24	24	25	25	24	26	26	25	25	24	25	25	24.83	
	1210-1215	Tour 2	24	25	25	24	26	26	25	25	25	26	25	24		25.00
	1510-1515	Tour 3	25	25	27	27	24	23	26	26	27	25	25	25		25.42
ROOF PERIMETER	0925-0930	Tour 1	29	29	31	31	30	32	31	32	31	29	29	29	30.25	
	1225-1230	Tour 2	30	30	30	29	30	29	29	29	30	31	31	31		29.92
	1525-1530	Tour 3	32	32	32	31	31	32	30	30	29	31	31	31		31.00

**DATE: 10/31/2007**

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	20	20	19	19	21	22	21	20	20	21	21	22	20.50	
	1200-1205	Tour 2	20	21	21	21	20	20	19	19	19	18	19	20		19.75
	1500-1505	Tour 3	19	19	18	19	20	20	21	21	21	22	23	21		20.33
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	25	23	23	23	21	21	22	24	25	26	26	26	23.75	
	1210-1215	Tour 2	26	26	27	26	22	22	21	21	22	23	24	23		23.58
	1510-1515	Tour 3	25	25	26	26	27	28	27	26	24	24	25	26		25.75
ROOF PERIMETER	0925-0930	Tour 1	31	31	30	30	31	32	31	31	31	32	31	31	31.00	
	1225-1230	Tour 2	30	30	29	28	29	29	30	31	31	33	31	31		30.17
	1525-1530	Tour 3	30	30	30	29	30	30	31	32	33	31	31	31		30.67

**DATE: 11/1/2007**

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	21	20	20	20	21	22	23	21	19	19	18	19	20.25	
	1200-1205	Tour 2	20	20	19	19	18	19	20	20	21	21	21	20		19.83
	1500-1505	Tour 3	21	21	21	20	20	20	19	19	19	18	21	20		19.92
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	26	25	26	26	27	26	27	27	28	29	28	27	26.83	
	1210-1215	Tour 2	25	25	26	23	23	22	23	21	22	21	26	23		23.33
	1510-1515	Tour 3	25	26	26	27	26	25	25	26	26	27	26	25		25.83
ROOF PERIMETER	0925-0930	Tour 1	31	31	30	30	30	29	30	31	31	31	30	29	30.25	
	1225-1230	Tour 2	29	29	30	30	31	30	30	29	28	28	29	30		29.42
	1525-1530	Tour 3	30	30	31	31	31	32	31	31	31	31	30	29		30.58

**DATE: 11/2/2007**

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	19	19	19	20	20	19	21	21	20	19	20	20	19.75	
	1200-1205	Tour 2	20	21	19	19	20	21	20	20	21	19	20	20		20.00
	1500-1505	Tour 3	20	19	20	20	19	19	21	22	22	20	19	21		20.17
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	25	25	23	26	25	24	23	23	24	25	25	25	24.42	
	1210-1215	Tour 2	27	27	26	26	24	24	25	25	23	23	25	24		24.92
	1510-1515	Tour 3	24	25	24	24	25	25	25	27	26	25	24	24		24.83
ROOF PERIMETER	0925-0930	Tour 1	30	31	30	29	32	32	31	29	29	30	32	32	30.58	
	1225-1230	Tour 2	29	28	30	30	32	30	31	30	30	32	32	31		30.42
	1525-1530	Tour 3	31	31	30	32	31	29	30	29	29	31	30	30		30.25

**DATE: 11/3/2007**

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	19	19	19	20	20	19	19	22	22	21	20	19	19.92	
	1200-1205	Tour 2	19	20	20	21	19	21	21	21	20	19	19	20		20.00
	1500-1505	Tour 3	20	20	17	19	19	20	20	20	21	20	19	19		19.50
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	24	24	26	24	24	24	23	23	24	24	25	24	24.08	
	1210-1215	Tour 2	25	24	25	24	25	24	24	25	25	26	25	24.75		
	1510-1515	Tour 3	24	24	26	26	25	25	25	24	24	25	23	24		24.58
ROOF PERIMETER	0925-0930	Tour 1	31	30	30	29	30	31	33	32	32	30	31	31	30.83	
	1225-1230	Tour 2	29	29	29	31	31	30	31	29	29	29	30	30		29.75
	1525-1530	Tour 3	30	31	30	31	32	31	31	31	29	29	30	31		30.50

**DATE: 11/4/2007**

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	21	21	21	21	20	19	18	19	20	20	20	21	20.08	
	1200-1205	Tour 2	19	19	18	20	20	19	19	19	21	21	20	20		19.58
	1500-1505	Tour 3	20	20	20	21	21	20	21	21	21	20	20	19		20.33
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	26	26	26	26	25	25	26	26	26	28	26	26	26.00	
	1210-1215	Tour 2	23	23	24	24	25	21	21	21	21	20	21	21		22.08
	1510-1515	Tour 3	24	24	23	23	23	21	21	21	21	20	21	21		21.92
ROOF PERIMETER	0925-0930	Tour 1	31	31	30	30	30	31	31	31	30	30	31	29	30.42	
	1225-1230	Tour 2	28	28	29	28	28	29	29	29	28	28	29	29		28.50
	1525-1530	Tour 3	30	30	29	29	28	27	30	31	31	31	30	28		29.50

Submittal Summary - Scaffold Phase Week 27 (10/29/07 to 11/04/07)

Lab Name	Field Sample ID	Sample Location	Date Collected	Project Phase	Sample Volume (m3)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Antimony Concentration (ug/m <sup>3</sup> )	Barium Concentration (ug/m <sup>3</sup> )	Beryllium Concentration (ug/m <sup>3</sup> )	Cadmium Concentration (ug/m <sup>3</sup> )	Chromium (Total) Concentration (ug/m <sup>3</sup> )	Copper Concentration (ug/m <sup>3</sup> )	Lead Concentration (ug/m <sup>3</sup> )	Manganese Concentration (ug/m <sup>3</sup> )	Nickel Concentration (ug/m <sup>3</sup> )	Zinc Concentration (ug/m <sup>3</sup> )	Unit	Flag	Qualifier	Date Reported	Exceeds Target Air Quality Level?	Exceeds EPA Site Specific Trigger Level?	Comments						
Target Air Quality Levels										5,000	5,000	20	2,000	500	10,000	1,500	500	10,000	16,000													
EPA Site Specific Trigger Levels										10,000	10,000	200	2,000	10	100,000	3,000	100	100,000	160,000													
STL-SAC	PH-10290-20	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	10/29/2007	Scaffold	5.768	GTJ310184001	10/31/2007	11/2/2007	6020	-34.7	-1730	-173	-173	-173	-173	-173	-173	-173	-173	-173	ng/m <sup>3</sup>			11/5/2007	No	No						
STL-SAC	PH-10290-21	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	10/29/2007	Scaffold	5.768	GTJ310184002	10/31/2007	11/2/2007	6020	-34.7	-1730	-173	-173	-173	-173	-173	-173	-173	-173	-173	ng/m <sup>3</sup>			11/5/2007	No	No						
STL-SAC	PH-10290-22	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	10/29/2007	Scaffold	5.768	GTJ310184003	10/31/2007	11/2/2007	6020	-34.7	-1730	-173	-173	-173	-173	-173	-173	-173	-173	-173	ng/m <sup>3</sup>			11/5/2007	No	No						
STL-SAC	PH-10290-23	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	10/29/2007	Scaffold	5.768	GTJ310184004	10/31/2007	11/2/2007	6020	-34.7	-1730	-173	-173	-173	-173	-173	-173	-173	-173	-173	ng/m <sup>3</sup>			11/5/2007	No	No						
STL-SAC	PH-10290-24	#5 - 5TH FLOOR SETBACK ROOF N SIDE	10/29/2007	Scaffold	5.768	GTJ310184005	10/31/2007	11/2/2007	6020	-34.7	-1730	-173	-173	-173	-173	-173	-173	-173	-173	-173	ng/m <sup>3</sup>			11/5/2007	No	No						
STL-SAC	PH-10290-25	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	10/29/2007	Scaffold	5.768	GTJ310184006	10/31/2007	11/2/2007	6020	-34.7	-1730	-173	-173	-173	-173	-173	-173	-173	-173	-173	ng/m <sup>3</sup>			11/5/2007	No	No						
STL-SAC	PH-10290-26	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	10/29/2007	Scaffold	5.768	GTJ310184007	10/31/2007	11/2/2007	6020	-34.7	-1730	-173	-173	-173	-173	-173	-173	-173	-173	-173	ng/m <sup>3</sup>			11/5/2007	No	No						
STL-SAC	PH-10290-27	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	10/29/2007	Scaffold	5.768	GTJ310184008	10/31/2007	11/2/2007	6020	-34.7	-1730	-173	-173	-173	-173	-173	-173	-173	-173	-173	ng/m <sup>3</sup>			11/5/2007	No	No						
STL-SAC	PH-10300-20	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	10/30/2007	Scaffold	5.756	GTW010206001	11/1/2007	11/2/2007	6020	-34.7	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/6/2007	No	No						
STL-SAC	PH-10300-21	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	10/30/2007	Scaffold	5.756	GTW010206002	11/1/2007	11/2/2007	6020	-34.7	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/6/2007	No	No						
STL-SAC	PH-10300-22	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	10/30/2007	Scaffold	5.756	GTW010206003	11/1/2007	11/2/2007	6020	-34.7	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/6/2007	No	No						
STL-SAC	PH-10300-23	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	10/30/2007	Scaffold	5.756	GTW010206004	11/1/2007	11/2/2007	6020	-34.7	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/6/2007	No	No						
STL-SAC	PH-10300-24	#5 - 5TH FLOOR SETBACK ROOF N SIDE	10/30/2007	Scaffold	5.756	GTW010206005	11/1/2007	11/2/2007	6020	-34.7	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/6/2007	No	No						
STL-SAC	PH-10300-25	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	10/30/2007	Scaffold	5.756	GTW010206006	11/1/2007	11/2/2007	6020	-34.7	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/6/2007	No	No						
STL-SAC	PH-10300-26	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	10/30/2007	Scaffold	5.756	GTW010206007	11/1/2007	11/2/2007	6020	-34.7	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/6/2007	No	No						
STL-SAC	PH-10300-27	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	10/30/2007	Scaffold	5.756	GTW010206008	11/1/2007	11/2/2007	6020	-34.7	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/6/2007	No	No						
STL-SAC	PH-10300-67	DUPLICATE (STATION #1)	10/30/2007	Scaffold	5.756	GTW010206010	11/1/2007	11/2/2007	6020	-34.7	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/6/2007	No	No						
STL-SAC	PH-10310-20	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	10/31/2007	Scaffold	5.744	GTW020167001	11/2/2007	11/2/2007	6020	-34.8	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/7/2007	No	No						
STL-SAC	PH-10310-21	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	10/31/2007	Scaffold	5.744	GTW020167002	11/2/2007	11/2/2007	6020	-34.8	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/7/2007	No	No						
STL-SAC	PH-10310-22	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	10/31/2007	Scaffold	5.744	GTW020167003	11/2/2007	11/2/2007	6020	-34.8	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/7/2007	No	No						
STL-SAC	PH-10310-23	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	10/31/2007	Scaffold	5.744	GTW020167004	11/2/2007	11/2/2007	6020	-34.8	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/7/2007	No	No						
STL-SAC	PH-10310-24	#5 - 5TH FLOOR SETBACK ROOF N SIDE	10/31/2007	Scaffold	5.744	GTW020167005	11/2/2007	11/2/2007	6020	-34.8	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/7/2007	No	No						
STL-SAC	PH-10310-25	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	10/31/2007	Scaffold	5.744	GTW020167006	11/2/2007	11/2/2007	6020	-34.8	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/7/2007	No	No						
STL-SAC	PH-10310-26	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	10/31/2007	Scaffold	5.744	GTW020167007	11/2/2007	11/2/2007	6020	-34.8	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/7/2007	No	No						
STL-SAC	PH-10310-27	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	10/31/2007	Scaffold	5.744	GTW020167008	11/2/2007	11/2/2007	6020	-34.8	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/7/2007	No	No						
STL-SAC	PH-11010-20	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/1/2007	Scaffold	5.763	GTW030208001	11/2/2007	11/7/2007	6020	-34.7	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/8/2007	No	No						
STL-SAC	PH-11010-21	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/1/2007	Scaffold	5.763	GTW030208002	11/2/2007	11/7/2007	6020	-34.7	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/8/2007	No	No						
STL-SAC	PH-11010-22	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/1/2007	Scaffold	5.763	GTW030208003	11/2/2007	11/7/2007	6020	-34.7	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/8/2007	No	No						
STL-SAC	PH-11010-23	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/1/2007	Scaffold	5.748	GTW030208004	11/2/2007	11/7/2007	6020	-34.8	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/8/2007	No	No						
STL-SAC	PH-11010-24	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/1/2007	Scaffold	5.76	GTW030208005	11/2/2007	11/7/2007	6020	-34.7	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/8/2007	No	No						
STL-SAC	PH-11010-25	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	11/1/2007	Scaffold	5.756	GTW030208006	11/2/2007	11/7/2007	6020	-34.7	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/8/2007	No	No						
STL-SAC	PH-11010-26	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	11/1/2007	Scaffold	5.763	GTW030208007	11/2/2007	11/7/2007	6020	-34.7	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/8/2007	No	No						
STL-SAC	PH-11010-27	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	11/1/2007	Scaffold	5.772	GTW030208008	11/2/2007	11/7/2007	6020	-34.6	-1730	-17.3	-17.3	-17.3	-17.3	-17.3	-17.3	-17.3	-17.3	-17.3	ng/m <sup>3</sup>			11/8/2007	No	No						
STL-SAC	PH-11020-20	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/2/2007	Scaffold	5.752	GTW060155001	11/6/2007	11/7/2007	6020	-34.8	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/9/2007	No	No						
STL-SAC	PH-11020-21	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/2/2007	Scaffold	5.748	GTW060155002	11/6/2007	11/7/2007	6020	-34.8	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/9/2007	No	No						
STL-SAC	PH-11020-22	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/2/2007	Scaffold	5.756	GTW060155003	11/6/2007	11/7/2007	6020	-34.7	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/9/2007	No	No						
STL-SAC	PH-11020-23	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/2/2007	Scaffold	5.752	GTW060155004	11/6/2007	11/7/2007	6020	-34.7	-1740	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	-17.4	ng/m <sup>3</sup>			11/9/2007	No	No						
STL-SAC	PH-11020-24	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/2/2007	Scaffold	5.752	GTW060155005	11/6/2007	11/7/2007	6020	-34.8	-1740	-17.4	-17.4	-17.4	-17.4																	



**Submittal Summary - Scaffold Phase Week 27 (10/29/07 to 11/04/07)**

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m <sup>3</sup> )	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	Dioxin/Furans Concentration (ng/m <sup>3</sup> )	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
<b>Target Air Quality Levels</b>											0.00025				
<b>EPA Site Specific Trigger Levels</b>											0.025				
STL-SAC	FH-103007-44	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	10/30/2007	Scaffold	360	G7K010374007	11/01/2007	11/09/2007	TO-9	Toxicity Equivalent Quotient (TEQ)	0.000088	11/15/2007	No	No	

**Submittal Summary - Scaffold Phase Week 27 (10/29/07 to 11/04/07)**

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m <sup>3</sup> )	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	PAHs Concentration (ug/m3)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											0.034				
EPA Site Specific Trigger Levels											3.4				
STL-SAC	FH-103007-53	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	10/30/2007	Scaffold	360	G7K010388007	11/01/2007	11/11/2007	8270C SIM	BAP-equivalent	<0.007	11/15/2007	No	No	

**Submittal Summary - Scaffold Phase Week 27 (10/29/07 to 11/04/07)**

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m <sup>3</sup> )	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	PCBs Concentration (ug/m3)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
<b>Target Air Quality Levels</b>											<b>0.12</b>				
<b>EPA Site Specific Trigger Levels</b>											<b>12</b>				
STL-SAC	FH-103007-62	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	10/30/2007	Scaffold	360	G7K010389007	11/01/2007	11/08/2007	TO-4	Aroclor 1016	<0.0021	11/15/2007	No	No	
STL-SAC	FH-103007-62	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	10/30/2007	Scaffold	360	G7K010389007	11/01/2007	11/08/2007	TO-4	Aroclor 1221	<0.0021	11/15/2007	No	No	
STL-SAC	FH-103007-62	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	10/30/2007	Scaffold	360	G7K010389007	11/01/2007	11/08/2007	TO-4	Aroclor 1232	<0.0021	11/15/2007	No	No	
STL-SAC	FH-103007-62	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	10/30/2007	Scaffold	360	G7K010389007	11/01/2007	11/08/2007	TO-4	Aroclor 1242	<0.0021	11/15/2007	No	No	
STL-SAC	FH-103007-62	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	10/30/2007	Scaffold	360	G7K010389007	11/01/2007	11/08/2007	TO-4	Aroclor 1248	<0.0021	11/15/2007	No	No	
STL-SAC	FH-103007-62	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	10/30/2007	Scaffold	360	G7K010389007	11/01/2007	11/08/2007	TO-4	Aroclor 1254	<0.0021	11/15/2007	No	No	
STL-SAC	FH-103007-62	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	10/30/2007	Scaffold	360	G7K010389007	11/01/2007	11/08/2007	TO-4	Aroclor 1260	<0.0021	11/15/2007	No	No	