







**Submittal Summary - Scaffold Phase Week 30 (11/19/07 to 11/25/07)**

Airtek Field Sample No.	Sampling Location	Real-time Readings Date	Collection time (minutes)	Analyte	Analytical Method	Instrument	Particulate PM 10 (ug/m <sup>3</sup> )	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
							150			
							150			
<b>EPA Site Specific Trigger Levels</b>										
FH-111907-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/19/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	20.56	No	No	
FH-111907-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/19/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	18.40	No	No	
FH-111907-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/19/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	36.51	No	No	
FH-111907-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/19/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	28.01	No	No	
FH-111907-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/19/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	35.04	No	No	
FH-111907-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	11/19/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	27.70	No	No	
FH-111907-EBAM10-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	11/19/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	21.08	No	No	
FH-111907-EBAM10-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	11/19/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	13.82	No	No	
FH-111907-TEOM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/19/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	11.37	No	No	
FH-112007-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/20/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	10.69	No	No	
FH-112007-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/20/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	33.37	No	No	
FH-112007-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/20/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	47.39	No	No	
FH-112007-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/20/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	25.56	No	No	
FH-112007-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/20/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	33.19	No	No	
FH-112007-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	11/20/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	36.78	No	No	
FH-112007-EBAM10-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	11/20/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	16.66	No	No	
FH-112007-EBAM10-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	11/20/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	13.89	No	No	
FH-112007-TEOM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/20/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	14.81	No	No	
FH-112107-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/21/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	23.13	No	No	
FH-112107-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/21/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	46.49	No	No	
FH-112107-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/21/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	46.21	No	No	
FH-112107-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/21/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	50.14	No	No	
FH-112107-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/21/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	51.78	No	No	
FH-112107-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	11/21/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	54.42	No	No	
FH-112107-EBAM10-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	11/21/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	48.63	No	No	
FH-112107-EBAM10-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	11/21/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	39.03	No	No	
FH-112107-TEOM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/21/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	45.41	No	No	
FH-112207-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/22/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	30.91	No	No	
FH-112207-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/22/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	55.05	No	No	
FH-112207-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/22/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	44.78	No	No	
FH-112207-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/22/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	66.47	No	No	
FH-112207-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/22/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	69.97	No	No	
FH-112207-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	11/22/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	74.73	No	No	
FH-112207-EBAM10-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	11/22/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	38.93	No	No	
FH-112207-EBAM10-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	11/22/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	26.86	No	No	
FH-112207-TEOM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/22/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	18.87	No	No	
FH-112307-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/23/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	31.44	No	No	
FH-112307-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/23/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	7.95	No	No	
FH-112307-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/23/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	10.38	No	No	
FH-112307-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/23/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	6.81	No	No	
FH-112307-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/23/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	5.94	No	No	
FH-112307-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	11/23/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	8.96	No	No	
FH-112307-EBAM10-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	11/23/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	9.74	No	No	
FH-112307-EBAM10-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	11/23/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	6.19	No	No	
FH-112307-TEOM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/23/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	7.79	No	No	
FH-112407-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/24/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	18.26	No	No	
FH-112407-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/24/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	9.72	No	No	
FH-112407-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/24/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	12.67	No	No	
FH-112407-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/24/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	10.69	No	No	
FH-112407-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/24/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	8.99	No	No	
FH-112407-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	11/24/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	11.78	No	No	
FH-112407-EBAM10-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	11/24/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	13.01	No	No	
FH-112407-EBAM10-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	11/24/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	9.17	No	No	
FH-112407-TEOM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/24/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	8.24	No	No	
FH-112507-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/25/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	9.22	No	No	
FH-112507-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/25/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	17.02	No	No	
FH-112507-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/25/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	19.55	No	No	
FH-112507-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/25/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	18.81	No	No	
FH-112507-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/25/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	17.76	No	No	
FH-112507-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	11/25/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	18.81	No	No	
FH-112507-EBAM10-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	11/25/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	22.21	No	No	
FH-112507-EBAM10-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	11/25/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	17.54	No	No	
FH-112507-TEOM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/25/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	13.95	No	No	



**Submittal Summary - Scaffold Phase Week 30 (11/19/07 to 11/25/07)**

Ohio Lumex Daily Mercury Readings

all readings are in ng/m<sup>3</sup>

Target air quality level: 300 ng/m<sup>3</sup>

USEPA site specific mercury trigger level: 3000 ng/m<sup>3</sup>

Exceedances: None  
Exceedances: None

3 Site Tours Conducted per Work Shift

**DATE: 11/19/2007**

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	18	18	19	18	18	17	18	18	19	18	17	16	17.83	
	1200-1205	Tour 2	18	17	17	16	17	17	17	18	19	18	17	17		17.33
	1500-1505	Tour 3	19	19	18	18	18	17	18	18	19	18	17	18		18.08
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	18	18	19	19	17	18	19	19	20	19	17	17	18.33	
	1210-1215	Tour 2	18	19	19	19	18	18	17	17	18	20	19	18		18.33
	1510-1515	Tour 3	18	18	17	17	16	17	18	17	18	18	18	19		17.58
ROOF PERIMETER	0925-0930	Tour 1	18	16	16	17	16	16	17	17	18	16	16	16	16.58	
	1225-1230	Tour 2	16	16	18	17	17	16	16	16	18	16	17	17		16.67
	1525-1530	Tour 3	16	16	16	17	16	17	16	16	18	16	16	18		16.67

**DATE: 11/20/2007**

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	18	18	18	19	18	19	18	17	17	17	18	19	19	18.17
	1200-1205	Tour 2	19	19	18	18	19	17	17	17	17	16	17	18	17.67	
	1500-1505	Tour 3	20	19	19	18	19	20	20	21	24	20	20	18	19.83	
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	17	17	16	18	18	18	19	18	18	18	19	18	17.83	
	1210-1215	Tour 2	17	17	17	16	17	18	18	18	17	18	18	18		17.42
	1510-1515	Tour 3	16	16	17	17	16	17	16	16	19	19	18	18		17.08
ROOF PERIMETER	0925-0930	Tour 1	18	17	17	17	18	16	16	17	16	17	18	19	17.17	
	1225-1230	Tour 2	19	18	19	19	18	19	19	18	18	18	18	18		18.42
	1525-1530	Tour 3	18	17	17	17	18	19	19	18	18	17	16	17		17.75

**DATE: 11/21/2007**

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	18	17	17	16	17	16	16	16	17	16	17	18	16.75	
	1200-1205	Tour 2	18	17	17	17	16	17	17	17	16	17	17	17		16.92
	1500-1505	Tour 3	18	18	17	16	16	16	15	16	17	16	16	17		16.50
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	18	17	17	16	16	18	18	17	16	16	16	16	16.75	
	1210-1215	Tour 2	16	16	17	17	16	17	16	15	15	16	16	16		16.08
	1510-1515	Tour 3	16	16	15	16	17	16	17	16	16	17	16	17		16.25
ROOF PERIMETER	0925-0930	Tour 1	15	15	14	15	16	16	17	15	15	16	17	15	15.50	
	1225-1230	Tour 2	15	15	15	16	17	16	16	16	15	16	16	16		15.75
	1525-1530	Tour 3	15	16	16	15	17	16	16	16	16	16	17	16		16.00

**DATE: 11/22/2007**

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	18	17	17	16	16	16	17	16	16	17	16	17	16.58	
	1200-1205	Tour 2	16	16	17	16	16	15	16	16	16	16	16	16		16.00
	1500-1505	Tour 3	16	16	15	16	17	16	16	16	16	16	17	16		16.08
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	17	16	16	15	15	15	16	15	16	16	17	16	15.83	
	1210-1215	Tour 2	16	16	17	16	16	16	16	15	16	16	16	16		16.00
	1510-1515	Tour 3	17	16	16	17	16	15	15	14	16	16	17	16		15.92
ROOF PERIMETER	0925-0930	Tour 1	15	15	13	15	16	16	17	16	13	13	13	16	14.83	
	1225-1230	Tour 2	15	13	15	15	13	13	15	16	16	16	13	14		14.50
	1525-1530	Tour 3	13	13	15	15	16	16	17	16	16	15	16	16		15.33

**DATE: 11/23/2007**

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	17	18	18	18	19	18	18	18	17	18	18	19	18.00	
	1200-1205	Tour 2	18	18	18	19	18	17	17	17	16	18	18	18		17.67
	1500-1505	Tour 3	18	17	17	18	18	19	18	17	17	18	18	18		17.75
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	20	18	18	18	18	17	17	19	18	18	18	18	18.08	
	1210-1215	Tour 2	17	18	18	18	17	18	17	17	18	18	18	19		17.75
	1510-1515	Tour 3	17	17	17	16	17	18	18	18	17	18	17	17		17.25
ROOF PERIMETER	0925-0930	Tour 1	18	17	17	17	16	17	16	16	16	17	16	17	16.67	
	1225-1230	Tour 2	17	17	16	17	16	17	16	16	16	16	16	15		16.25
	1525-1530	Tour 3	16	17	17	16	16	17	17	17	17	16	16	17		16.58

**DATE: 11/24/2007**

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	18	17	17	16	17	16	16	17	16	17	16	16	16.58	
	1200-1205	Tour 2	16	16	16	17	16	16	16	17	16	15	16	17		16.17
	1500-1505	Tour 3	16	16	17	16	16	16	16	15	16	16	15	16		15.92
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	17	17	17	16	17	17	16	16	17	16	17	17	16.67	
	1210-1215	Tour 2	17	17	16	16	16	17	16	16	16	17	16	15		16.25
	1510-1515	Tour 3	15	16	16	16	15	16	17	18	18	17	16	16		16.33
ROOF PERIMETER	0925-0930	Tour 1	16	16	17	16	13	13	13	14	13	15	15	16	14.75	
	1225-1230	Tour 2	16	17	17	13	13	15	15	16	16	17	16	17		15.67
	1525-1530	Tour 3	17	17	17	16	16	17	16	15	15	16	16	16		16.17

**DATE: 11/25/2007**

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	18	17	17	17	16	17	17	16	15	16	17	18	16.75	
	1200-1205	Tour 2	18	18	19	18	18	17	18	17	17	17	16	17		17.50
	1500-1505	Tour 3	18	18	17	17	17	18	17	16	17	17	17	16		17.08
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	17	16	16	16	17	16	16	15	16	15	16	16	16.00	
	1210-1215	Tour 2	16	16	16	17	16	17	16	17	17	17	16	15		16.33
	1510-1515	Tour 3	16	16	17	17	17	16	17	17	16	15	15	16		16.25
ROOF PERIMETER	0925-0930	Tour 1	15	15	16	15	16	16	17	16	16	17	16	17	16.00	
	1225-1230	Tour 2	15	16	16	18	18	19	17	16	17	17	17	17		16.92
	1525-1530	Tour 3	17	17	16	17	17	16	17	16	17	17	16	17		16.67





**Submittal Summary - Scaffold Phase Week 30 (11/19/07 to 11/25/07)**

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m <sup>3</sup> )	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	Dioxin/Furans Concentration (ng/m <sup>3</sup> )	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
<b>Target Air Quality Levels</b>											0.00025				
<b>EPA Site Specific Trigger Levels</b>											0.025				
STL-SAC	FH-112407-40	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/24/2007	Scaffold	360	G7K270203003	11/27/2007	12/11/2007	TO-9	Toxicity Equivalent Quotient (TEQ)	0.00011	12/12/2007	No	No	

**Submittal Summary - Scaffold Phase Week 30 (11/19/07 to 11/25/07)**

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m <sup>3</sup> )	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	PAHs Concentration (ug/m3)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
<b>Target Air Quality Levels</b>											0.034				
<b>EPA Site Specific Trigger Levels</b>											3.4				
STL-SAC	FH-112407-49	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/24/2007	Scaffold	360	G7K270211002	11/27/2007	12/05/2007	8270C SIM	BAP-equivalent	<0.007	12/11/2007	No	No	

**Submittal Summary - Scaffold Phase Week 30 (11/19/07 to 11/25/07)**

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m <sup>3</sup> )	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	PCBs Concentration (ug/m3)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											0.12				
EPA Site Specific Trigger Levels											12				
STL-SAC	FH-112407-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/24/2007	Scaffold	360	G7K270208003	11/27/2007	12/05/2007	TO-4	Aroclor 1016	<0.0021	12/11/2007	No	No	
STL-SAC	FH-112407-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/24/2007	Scaffold	360	G7K270208003	11/27/2007	12/05/2007	TO-4	Aroclor 1221	<0.0021	12/11/2007	No	No	
STL-SAC	FH-112407-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/24/2007	Scaffold	360	G7K270208003	11/27/2007	12/05/2007	TO-4	Aroclor 1232	<0.0021	12/11/2007	No	No	
STL-SAC	FH-112407-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/24/2007	Scaffold	360	G7K270208003	11/27/2007	12/05/2007	TO-4	Aroclor 1242	<0.0021	12/11/2007	No	No	
STL-SAC	FH-112407-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/24/2007	Scaffold	360	G7K270208003	11/27/2007	12/05/2007	TO-4	Aroclor 1248	<0.0021	12/11/2007	No	No	
STL-SAC	FH-112407-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/24/2007	Scaffold	360	G7K270208003	11/27/2007	12/05/2007	TO-4	Aroclor 1254	<0.0021	12/11/2007	No	No	
STL-SAC	FH-112407-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/24/2007	Scaffold	360	G7K270208003	11/27/2007	12/05/2007	TO-4	Aroclor 1260	<0.0021	12/11/2007	No	No	