

Submittal Summary - Scaffold Phase Week 31 (11/26/07 to 12/02/07)

Airetek Field Sample No.	Sampling Location	Real-time Readings Date	Collection time (minutes)	Analyte	Analytical Method	Instrument	Particulate PM 2.5 (ug/m ³)	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
							40			
							65			
EPA Site Specific Trigger Levels										
FH-112607-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/26/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	25.16	No	No	
FH-112607-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/26/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	30.96	No	No	
FH-112607-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/26/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	39.47	No	No	
FH-112607-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/26/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	31.94	No	No	
FH-112607-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/26/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	39.49	No	No	
FH-112607-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	11/26/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	34.43	No	No	
FH-112607-EBAM2.5-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	11/26/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	24.38	No	No	
FH-112607-EBAM2.5-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	11/26/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	38.80	No	No	
FH-112607-TEOM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/26/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	14.48	No	No	
FH-112707-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/27/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	8.35	No	No	
FH-112707-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/27/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	9.63	No	No	
FH-112707-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/27/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	19.06	No	No	
FH-112707-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/27/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	28.82	No	No	
FH-112707-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/27/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	21.49	No	No	
FH-112707-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	11/27/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	8.90	No	No	
FH-112707-EBAM2.5-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	11/27/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	22.94	No	No	
FH-112707-EBAM2.5-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	11/27/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	8.71	No	No	
FH-112707-TEOM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/27/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	13.57	No	No	
FH-112807-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/28/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	7.11	No	No	
FH-112807-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/28/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	6.93	No	No	
FH-112807-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/28/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	15.34	No	No	
FH-112807-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/28/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	7.03	No	No	
FH-112807-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/28/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	5.88	No	No	
FH-112807-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	11/28/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	8.26	No	No	
FH-112807-EBAM2.5-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	11/28/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	14.94	No	No	
FH-112807-EBAM2.5-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	11/28/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	9.39	No	No	
FH-112807-TEOM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/28/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	9.86	No	No	
FH-112907-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/29/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	9.93	No	No	
FH-112907-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/29/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	10.83	No	No	
FH-112907-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/29/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	17.43	No	No	
FH-112907-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/29/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	10.57	No	No	
FH-112907-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/29/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	31.70	No	No	
FH-112907-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	11/29/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	10.64	No	No	
FH-112907-EBAM2.5-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	11/29/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	24.10	No	No	
FH-112907-EBAM2.5-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	11/29/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	13.13	No	No	
FH-112907-TEOM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/29/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	12.12	No	No	
FH-113007-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/30/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	11.47	No	No	
FH-113007-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/30/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	13.03	No	No	
FH-113007-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/30/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	14.84	No	No	
FH-113007-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/30/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	11.09	No	No	
FH-113007-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/30/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	9.79	No	No	
FH-113007-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	11/30/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	12.51	No	No	
FH-113007-EBAM2.5-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	11/30/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	30.99	No	No	
FH-113007-EBAM2.5-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	11/30/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	14.95	No	No	
FH-113007-TEOM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/30/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	13.93	No	No	
FH-120107-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	12/1/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	5.66	No	No	
FH-120107-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	12/1/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	9.03	No	No	
FH-120107-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	12/1/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	15.56	No	No	
FH-120107-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	12/1/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	5.83	No	No	
FH-120107-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	12/1/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	6.81	No	No	
FH-120107-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	12/1/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	7.17	No	No	
FH-120107-EBAM2.5-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	12/1/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	31.25	No	No	
FH-120107-EBAM2.5-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	12/1/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	9.40	No	No	
FH-120107-TEOM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	12/1/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	7.49	No	No	
FH-120207-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	12/2/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	20.26	No	No	
FH-120207-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	12/2/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	23.35	No	No	
FH-120207-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	12/2/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	31.04	No	No	
FH-120207-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	12/2/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	23.71	No	No	
FH-120207-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	12/2/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	28.51	No	No	
FH-120207-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	12/2/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	21.46	No	No	
FH-120207-EBAM2.5-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	12/2/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	31.73	No	No	
FH-120207-EBAM2.5-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	12/2/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	26.25	No	No	
FH-120207-TEOM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	12/2/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	19.13	No	No	

Submittal Summary - Scaffold Phase Week 31 (11/26/07 to 12/02/07)

Ohio Lumex Daily Mercury Readings

all readings are in ng/m³

Target air quality level: 300 ng/m³

USEPA site specific mercury trigger level: 3000 ng/m³

Exceedances: None
Exceedances: None

3 Site Tours Conducted per Work Shift

DATE: 11/26/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	18	18	19	19	18	18	17	17	16	17	18	19	17.83	
	1200-1205	Tour 2	17	17	16	17	18	18	17	18	18	19	18	18		17.58
	1500-1505	Tour 3	18	17	17	17	16	17	19	19	18	19	18	19		17.83
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	18	17	17	16	17	16	16	17	16	17	17	16	16.67	
	1210-1215	Tour 2	17	17	16	17	16	16	15	15	16	17	18	18		16.50
	1510-1515	Tour 3	18	19	19	21	21	21	20	19	18	18	19	21		19.50
ROOF PERIMETER	0925-0930	Tour 1	17	17	16	16	15	16	17	16	15	15	15	16	15.92	
	1225-1230	Tour 2	16	16	18	16	16	16	17	17	16	17	17	16		16.50
	1525-1530	Tour 3	18	18	19	18	18	19	19	19	20	18	16	17		18.42

DATE: 11/27/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	18	17	16	17	17	18	17	16	17	17	17	17	16.92	
	1200-1205	Tour 2	16	16	16	17	16	16	17	17	17	16	16	17		16.42
	1500-1505	Tour 3	17	18	17	17	16	16	19	16	17	17	16	16		16.83
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	17	17	16	18	18	17	17	16	16	17	18	18	17.08	
	1210-1215	Tour 2	18	18	16	17	17	18	18	18	17	16	18	18		17.42
	1510-1515	Tour 3	18	16	15	15	16	17	17	18	15	16	17	19		16.58
ROOF PERIMETER	0925-0930	Tour 1	16	16	16	16	19	19	18	17	17	18	19	20	17.58	
	1225-1230	Tour 2	17	17	18	18	17	17	18	18	19	19	18	16		17.67
	1525-1530	Tour 3	17	19	18	19	17	17	18	18	19	18	19	18		18.08

DATE: 11/28/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	15	15	15	17	17	16	16	17	17	16	17	17	16.25	
	1200-1205	Tour 2	16	16	15	16	16	15	17	17	17	17	17	16		16.25
	1500-1505	Tour 3	16	16	15	15	15	15	15	17	18	17	17	17		16.08
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	17	17	17	17	17	17	18	18	18	18	17	17	17.33	
	1210-1215	Tour 2	17	16	16	17	16	17	17	15	15	18	18	18		16.67
	1510-1515	Tour 3	18	18	17	17	17	18	16	15	16	16	15	15		16.50
ROOF PERIMETER	0925-0930	Tour 1	18	19	19	18	18	17	17	17	16	16	18	16	17.42	
	1225-1230	Tour 2	17	17	18	19	19	19	18	17	17	16	16	16		17.42
	1525-1530	Tour 3	16	16	18	17	17	19	19	19	19	17	17	18		17.87

DATE: 11/29/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	15	16	16	15	15	17	17	17	16	17	15	15	15.92	
	1200-1205	Tour 2	16	16	16	17	17	15	15	16	16	16	17	17		16.17
	1500-1505	Tour 3	17	17	17	17	16	16	16	17	17	17	15	17		16.58
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	17	17	17	16	17	18	18	18	16	16	16	16	16.83	
	1210-1215	Tour 2	18	18	17	17	16	16	16	17	17	17	17	17		16.92
	1510-1515	Tour 3	15	16	16	16	18	17	18	17	18	16	16	16		16.58
ROOF PERIMETER	0925-0930	Tour 1	18	18	18	18	18	17	17	17	16	18	19	18	17.67	
	1225-1230	Tour 2	17	18	18	18	17	16	16	16	18	17	17	17		17.08
	1525-1530	Tour 3	19	19	17	17	17	18	16	16	17	17	17	16		17.17

DATE: 11/30/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	18	19	19	18	17	17	16	17	18	19	18	18	17.83	
	1200-1205	Tour 2	18	17	17	17	16	17	16	17	18	17	18	18		17.17
	1500-1505	Tour 3	18	18	18	19	19	21	20	19	19	18	18	18		18.75
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	16	17	16	16	18	17	17	17	16	17	18	19	17.00	
	1210-1215	Tour 2	16	17	17	17	18	16	16	17	16	17	17	17		16.75
	1510-1515	Tour 3	18	18	17	17	16	17	17	16	18	18	18	18		17.33
ROOF PERIMETER	0925-0930	Tour 1	18	19	18	18	17	16	16	16	15	16	15	16	16.67	
	1225-1230	Tour 2	16	16	15	16	17	17	17	16	17	17	16	16		16.33
	1525-1530	Tour 3	15	16	16	15	16	16	16	15	15	14	15	16		15.42

DATE: 12/1/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	18	17	16	16	16	15	16	17	16	16	16	16	16.25	
	1200-1205	Tour 2	16	16	17	16	17	17	16	15	15	16	15	16		16.00
	1500-1505	Tour 3	16	16	18	17	17	16	18	17	17	16	17	17		16.83
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	16	16	16	17	17	18	17	17	16	17	17	16	16.67	
	1210-1215	Tour 2	16	16	17	16	15	15	15	15	14	15	16	15		15.42
	1510-1515	Tour 3	15	15	16	17	16	16	16	15	16	16	16	16		15.83
ROOF PERIMETER	0925-0930	Tour 1	16	16	17	16	16	15	15	16	15	16	15	16	15.75	
	1225-1230	Tour 2	15	15	16	15	16	15	15	15	14	14	15	14		14.92
	1525-1530	Tour 3	15	15	16	17	16	16	15	13	13	14	13	14		14.75

DATE: 12/2/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	10	10	9	8	8	7	8	9	10	10	10	10	9.08	
	1200-1205	Tour 2	10	11	10	11	9	9	8	9	10	10	9	10		9.67
	1500-1505	Tour 3	9	9	8	7	7	9	8	7	9	9	10	10		8.50
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	10	10	10	11	10	10	9	9	10	9	10	10	9.83	
	1210-1215	Tour 2	10	11	10	9	8	8	8	7	8	8	7	10		8.67
	1510-1515	Tour 3	10	9	9	8	8	7	8	7	9	10	10	9		8.67
ROOF PERIMETER	0925-0930	Tour 1	8	8	6	8	9	9	10	9	8	7	7	6	7.92	
	1225-1230	Tour 2	8	7	7	7	6	6	5	7	8	7	6	7		6.75
	1525-1530	Tour 3	8	8	8	9	10	9	10	10	10	8	8	8		8.75

Submittal Summary - Scaffold Phase Week 31 (11/26/07 to 12/02/07)

Lab Name	Field Sample ID	Sample Location	Date Collected	Project Phase	Sample Volume (m3)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Antimony Concentration (ug/m ³)	Barium Concentration (ug/m ³)	Beryllium Concentration (ug/m ³)	Cadmium Concentration (ug/m ³)	Chromium (Total) Concentration (ug/m ³)	Copper Concentration (ug/m ³)	Lead Concentration (ug/m ³)	Manganese Concentration (ug/m ³)	Nickel Concentration (ug/m ³)	Zinc Concentration (ug/m ³)	Unit	Flag	Qualifier	Date Reported	Exceeds Target Air Quality Level?	Exceeds EPA Site Specific Trigger Level?	Comments						
Target Air Quality Levels										5,000	5,000	20	50	2,000	500	10,000	1,000	500	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000		
EPA Site Specific Trigger Levels										14,000	14,000	200	100,000	200	10	100,000	10,000	5,000	100,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000
STL-SAC	PH-112607-20	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/26/2007	Scaffold	5.764	GWK280221001	11/26/2007	11/29/2007	6020	<-34.7	<-1730	<-173	<-86.7	<-173	<-173	<-173	<-86.7	<-173	<-86.7	<-347	ng/m ³			12/3/2007	No	No						
STL-SAC	PH-112607-21	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/26/2007	Scaffold	5.764	GWK280221002	11/26/2007	11/29/2007	6020	<-34.7	<-1730	<-173	<-86.7	<-173	<-173	<-173	<-86.7	<-173	<-86.7	<-347	ng/m ³			12/3/2007	No	No						
STL-SAC	PH-112607-22	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/26/2007	Scaffold	5.764	GWK280221003	11/26/2007	11/29/2007	6020	<-34.7	<-1730	<-173	<-86.7	<-173	<-173	<-173	<-86.7	<-173	<-86.7	<-347	ng/m ³			12/3/2007	No	No						
STL-SAC	PH-112607-23	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/26/2007	Scaffold	5.764	GWK280221004	11/26/2007	11/29/2007	6020	<-34.7	<-1730	<-173	<-86.7	<-173	<-173	<-173	<-86.7	<-173	<-86.7	<-347	ng/m ³			12/3/2007	No	No						
STL-SAC	PH-112607-24	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/26/2007	Scaffold	5.764	GWK280221005	11/26/2007	11/29/2007	6020	<-34.7	<-1730	<-173	<-86.7	<-173	<-173	<-173	<-86.7	<-173	<-86.7	<-347	ng/m ³			12/3/2007	No	No						
STL-SAC	PH-112607-25	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	11/26/2007	Scaffold	5.764	GWK280221006	11/26/2007	11/29/2007	6020	<-34.7	<-1730	<-173	<-86.7	<-173	<-173	<-173	<-86.7	<-173	<-86.7	<-347	ng/m ³			12/3/2007	No	No						
STL-SAC	PH-112607-26	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	11/26/2007	Scaffold	5.764	GWK280221007	11/26/2007	11/29/2007	6020	<-34.7	<-1730	<-173	<-86.7	<-173	<-173	<-173	<-86.7	<-173	<-86.7	<-347	ng/m ³			12/3/2007	No	No						
STL-SAC	PH-112607-27	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	11/26/2007	Scaffold	5.764	GWK280221008	11/26/2007	11/29/2007	6020	<-34.7	<-1730	<-173	<-86.7	<-173	<-173	<-173	<-86.7	<-173	<-86.7	<-347	ng/m ³			12/3/2007	No	No						
STL-SAC	PH-112707-20	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/27/2007	Scaffold	5.792	GWK290161001	11/29/2007	12/3/2007	6020	<-34.5	<-1730	<-173	<-86.3	<-173	<-173	<-173	<-86.3	<-173	<-86.3	<-345	ng/m ³			12/4/2007	No	No						
STL-SAC	PH-112707-21	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/27/2007	Scaffold	5.792	GWK290161002	11/29/2007	12/3/2007	6020	<-34.5	<-1730	<-173	<-86.3	<-173	<-173	<-173	<-86.3	<-173	<-86.3	<-345	ng/m ³			12/4/2007	No	No						
STL-SAC	PH-112707-22	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/27/2007	Scaffold	5.792	GWK290161003	11/29/2007	12/3/2007	6020	<-34.5	<-1730	<-173	<-86.3	<-173	<-173	<-173	<-86.3	<-173	<-86.3	<-345	ng/m ³			12/4/2007	No	No						
STL-SAC	PH-112707-23	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/27/2007	Scaffold	5.796	GWK290161004	11/29/2007	12/3/2007	6020	<-34.5	<-1730	<-172	<-86.3	<-172	<-172	<-172	<-86.3	<-172	<-86.3	<-345	ng/m ³			12/4/2007	No	No						
STL-SAC	PH-112707-24	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/27/2007	Scaffold	5.792	GWK290161005	11/29/2007	12/3/2007	6020	<-34.5	<-1730	<-173	<-86.3	<-173	<-173	<-173	<-86.3	<-173	<-86.3	<-345	ng/m ³			12/4/2007	No	No						
STL-SAC	PH-112707-25	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	11/27/2007	Scaffold	5.792	GWK290161006	11/29/2007	12/3/2007	6020	<-34.5	<-1730	<-173	<-86.3	<-173	<-173	<-173	<-86.3	<-173	<-86.3	<-345	ng/m ³			12/4/2007	No	No						
STL-SAC	PH-112707-26	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	11/27/2007	Scaffold	5.792	GWK290161007	11/29/2007	12/3/2007	6020	<-34.5	<-1730	<-173	<-86.3	<-173	<-173	<-173	<-86.3	<-173	<-86.3	<-345	ng/m ³			12/4/2007	No	No						
STL-SAC	PH-112707-27	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	11/27/2007	Scaffold	5.792	GWK290161008	11/29/2007	12/3/2007	6020	<-34.5	<-1730	<-173	<-86.3	<-173	<-173	<-173	<-86.3	<-173	<-86.3	<-345	ng/m ³			12/4/2007	No	No						
STL-SAC	PH-112707-6F	DUPLICATE (STATION 6F)	11/27/2007	Scaffold	5.792	GWK290161010	11/29/2007	12/3/2007	6020	<-34.5	<-1730	<-173	<-86.3	<-173	<-173	<-173	<-86.3	<-173	<-86.3	<-345	ng/m ³			12/4/2007	No	No						
STL-SAC	PH-112807-20	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/28/2007	Scaffold	5.756	GWK300207001	11/30/2007	12/3/2007	6020	<-34.7	<-1740	<-174	<-87.0	<-174	<-174	<-174	<-86.9	<-174	<-86.9	<-347	ng/m ³			12/5/2007	No	No						
STL-SAC	PH-112807-21	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/28/2007	Scaffold	5.748	GWK300207002	11/30/2007	12/3/2007	6020	<-34.8	<-1740	<-174	<-87.0	<-174	<-174	<-174	<-87.0	<-174	<-87.0	<-348	ng/m ³			12/5/2007	No	No						
STL-SAC	PH-112807-22	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/28/2007	Scaffold	5.748	GWK300207003	11/30/2007	12/3/2007	6020	<-34.8	<-1740	<-174	<-87.0	<-174	<-174	<-174	<-87.0	<-174	<-87.0	<-348	ng/m ³			12/5/2007	No	No						
STL-SAC	PH-112807-23	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/28/2007	Scaffold	5.744	GWK300207004	11/30/2007	12/3/2007	6020	<-34.8	<-1740	<-174	<-87.0	<-174	<-174	<-174	<-87.0	<-174	<-87.0	<-348	ng/m ³			12/5/2007	No	No						
STL-SAC	PH-112807-24	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/28/2007	Scaffold	5.748	GWK300207005	11/30/2007	12/3/2007	6020	<-34.8	<-1740	<-174	<-87.0	<-174	<-174	<-174	<-87.0	<-174	<-87.0	<-348	ng/m ³			12/5/2007	No	No						
STL-SAC	PH-112807-25	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	11/28/2007	Scaffold	5.748	GWK300207006	11/30/2007	12/3/2007	6020	<-34.8	<-1740	<-174	<-87.0	<-174	<-174	<-174	<-87.0	<-174	<-87.0	<-348	ng/m ³			12/5/2007	No	No						
STL-SAC	PH-112807-26	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	11/28/2007	Scaffold	5.744	GWK300207007	11/30/2007	12/3/2007	6020	<-34.8	<-1740	<-174	<-87.0	<-174	<-174	<-174	<-87.0	<-174	<-87.0	<-348	ng/m ³			12/5/2007	No	No						
STL-SAC	PH-112807-27	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	11/28/2007	Scaffold	5.752	GWK300207008	11/30/2007	12/3/2007	6020	<-34.8	<-1740	<-174	<-86.9	<-174	<-174	<-174	<-86.9	<-174	<-86.9	<-348	ng/m ³			12/5/2007	No	No						
STL-SAC	PH-112907-20	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/29/2007	Scaffold	5.78	GLT010225001	12/1/2007	12/3/2007	6020	<-34.6	<-1730	<-173	<-86.5	<-173	<-173	<-173	<-86.5	<-173	<-86.5	<-346	ng/m ³			12/6/2007	No	No						
STL-SAC	PH-112907-21	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/29/2007	Scaffold	5.788	GLT010225002	12/1/2007	12/4/2007	6020	<-34.6	<-1730	<-173	<-86.4	<-173	<-173	<-173	<-86.4	<-173	<-86.4	<-346	ng/m ³			12/6/2007	No	No						
STL-SAC	PH-112907-22	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/29/2007	Scaffold	5.79	GLT010225003	12/1/2007	12/4/2007	6020	<-34.6	<-1730	<-173	<-86.5	<-173	<-173	<-173	<-86.5	<-173	<-86.5	<-346	ng/m ³			12/6/2007	No	No						
STL-SAC	PH-112907-23	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/29/2007	Scaffold	5.784	GLT010225004	12/1/2007	12/4/2007	6020	<-34.6	<-1730	<-173	<-86.4	<-173	<-173	<-173	<-86.4	<-173	<-86.4	<-346	ng/m ³			12/6/2007	No	No						
STL-SAC	PH-112907-24	#5 - 5TH FLOOR SETBACK ROOF N SIDE	11/29/2007	Scaffold	5.768	GLT010225005	12/1/2007	12/4/2007	6020	<-34.6	<-1730	<-173	<-86.4	<-173	<-173	<-173	<-86.4	<-173	<-86.4	<-346	ng/m ³			12/6/2007	No	No						
STL-SAC	PH-112907-25	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	11/29/2007	Scaffold	5.788	GLT010225006	12/1/2007	12/4/2007	6020	<-34.6	<-1730	<-173	<-86.4	<-173	<-173	<-173	<-86.4	<-173	<-86.4	<-346	ng/m ³			12/6/2007	No	No						
STL-SAC	PH-112907-26	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	11/29/2007	Scaffold	5.788	GLT010225007	12/1/2007	12/4/2007	6020	<-34.6	<-1730	<-173	<-86.4	<-173	<-173	<-173	<-86.4	<-173	<-86.4	<-346	ng/m ³			12/6/2007	No	No						
STL-SAC	PH-112907-27	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	11/29/2007	Scaffold	5.788	GLT010225008	12/1/2007	12/4/2007	6020	<-34.6	<-1730	<-173	<-86.4	<-173	<-173	<-173	<-86.4	<-173	<-86.4	<-346	ng/m ³			12/6/2007	No	No						
STL-SAC	PH-113007-20	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/30/2007	Scaffold	5.752	GLT040243001	12/4/2007	12/6/2007	6020	<-34.8	<-1740	<-174	<-86.9	<-174	<-174	<-174	<-86.9	<-174	<-86.9	<-348	ng/m ³			12/7/2007	No	No						
STL-SAC	PH-113007-21	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/30/2007	Scaffold	5.752	GLT040243002	12/4/2007	12/6/2007	6020	<-34.8	<-1740	<-174	<-86.9	<-174	<-174	<-174	<-86.9	<-174	<-86.9	<-348	ng/m ³											

Submittal Summary - Scaffold Phase Week 31 (11/26/07 to 12/02/07)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Work Shift/Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	Silica-Quartz Concentration (ug/m3)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels												10			
EPA Site Specific Trigger Levels												10			
EMSL	FH-112607-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/26/2007	Scaffold	2.882	040729396-0001	11/28/2007	11/29/2007	NIOSH 7500 XRD	Silica-Quartz	<2	11/30/2007	No	No	
EMSL	FH-112607-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/26/2007	Scaffold	2.882	040729396-0002	11/28/2007	11/29/2007	NIOSH 7500 XRD	Silica-Quartz	<2	11/30/2007	No	No	
EMSL	FH-112607-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/26/2007	Scaffold	2.882	040729396-0003	11/28/2007	11/29/2007	NIOSH 7500 XRD	Silica-Quartz	<2	11/30/2007	No	No	
EMSL	FH-112607-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/26/2007	Scaffold	2.882	040729396-0004	11/28/2007	11/29/2007	NIOSH 7500 XRD	Silica-Quartz	<2	11/30/2007	No	No	
EMSL	FH-112607-33	#5 - 5TH FL SETBACK ROOF N. SIDE	11/26/2007	Scaffold	2.882	040729396-0005	11/28/2007	11/29/2007	NIOSH 7500 XRD	Silica-Quartz	<2	11/30/2007	No	No	
EMSL	FH-112607-34	#6 - 5TH FL SETBACK ROOF SW SIDE	11/26/2007	Scaffold	2.882	040729396-0006	11/28/2007	11/29/2007	NIOSH 7500 XRD	Silica-Quartz	<2	11/30/2007	No	No	
EMSL	FH-112607-35	#7 - 5TH FL SCAFFOLD AT SE CORNER	11/26/2007	Scaffold	2.882	040729396-0007	11/28/2007	11/29/2007	NIOSH 7500 XRD	Silica-Quartz	<2	11/30/2007	No	No	
EMSL	FH-112607-36	#8 - 5TH FL SCAFFOLD AT NE CORNER	11/26/2007	Scaffold	2.890	040729396-0008	11/28/2007	11/29/2007	NIOSH 7500 XRD	Silica-Quartz	<2	11/30/2007	No	No	
EMSL	FH-112707-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/27/2007	Scaffold	2.896	040729497-0001	11/29/2007	11/29/2007	NIOSH 7500 XRD	Silica-Quartz	<2	11/30/2007	No	No	
EMSL	FH-112707-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/27/2007	Scaffold	2.896	040729497-0002	11/29/2007	11/29/2007	NIOSH 7500 XRD	Silica-Quartz	<2	11/30/2007	No	No	
EMSL	FH-112707-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/27/2007	Scaffold	2.896	040729497-0003	11/29/2007	11/29/2007	NIOSH 7500 XRD	Silica-Quartz	<2	11/30/2007	No	No	
EMSL	FH-112707-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/27/2007	Scaffold	2.898	040729497-0004	11/29/2007	11/29/2007	NIOSH 7500 XRD	Silica-Quartz	<2	11/30/2007	No	No	
EMSL	FH-112707-33	#5 - 5TH FL SETBACK ROOF N. SIDE	11/27/2007	Scaffold	2.896	040729497-0005	11/29/2007	11/29/2007	NIOSH 7500 XRD	Silica-Quartz	<2	11/30/2007	No	No	
EMSL	FH-112707-34	#6 - 5TH FL SETBACK ROOF SW SIDE	11/27/2007	Scaffold	2.896	040729497-0006	11/29/2007	11/29/2007	NIOSH 7500 XRD	Silica-Quartz	<2	11/30/2007	No	No	
EMSL	FH-112707-35	#7 - 5TH FL SCAFFOLD AT SE CORNER	11/27/2007	Scaffold	2.896	040729497-0007	11/29/2007	11/29/2007	NIOSH 7500 XRD	Silica-Quartz	<2	11/30/2007	No	No	
EMSL	FH-112707-36	#8 - 5TH FL SCAFFOLD AT NE CORNER	11/27/2007	Scaffold	2.890	040729497-0008	11/29/2007	11/29/2007	NIOSH 7500 XRD	Silica-Quartz	3	11/30/2007	No	No	
EMSL	FH-112707-68	DUPLICATE (STATION #1)	11/27/2007	Scaffold	2.896	040729497-0010	11/29/2007	11/29/2007	NIOSH 7500 XRD	Silica-Quartz	<2	11/30/2007	No	No	
EMSL	FH-112807-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/28/2007	Scaffold	2.878	040729617-0001	11/30/2007	11/30/2007	NIOSH 7500 XRD	Silica-Quartz	<2	11/30/2007	No	No	
EMSL	FH-112807-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/28/2007	Scaffold	2.874	040729617-0002	11/30/2007	11/30/2007	NIOSH 7500 XRD	Silica-Quartz	<2	11/30/2007	No	No	
EMSL	FH-112807-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/28/2007	Scaffold	2.874	040729617-0003	11/30/2007	11/30/2007	NIOSH 7500 XRD	Silica-Quartz	2	11/30/2007	No	No	
EMSL	FH-112807-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/28/2007	Scaffold	2.872	040729617-0004	11/30/2007	11/30/2007	NIOSH 7500 XRD	Silica-Quartz	<2	11/30/2007	No	No	
EMSL	FH-112807-33	#5 - 5TH FL SETBACK ROOF N. SIDE	11/28/2007	Scaffold	2.874	040729617-0005	11/30/2007	11/30/2007	NIOSH 7500 XRD	Silica-Quartz	<2	11/30/2007	No	No	
EMSL	FH-112807-34	#6 - 5TH FL SETBACK ROOF SW SIDE	11/28/2007	Scaffold	2.874	040729617-0006	11/30/2007	11/30/2007	NIOSH 7500 XRD	Silica-Quartz	<2	11/30/2007	No	No	
EMSL	FH-112807-35	#7 - 5TH FL SCAFFOLD AT SE CORNER	11/28/2007	Scaffold	2.872	040729617-0007	11/30/2007	11/30/2007	NIOSH 7500 XRD	Silica-Quartz	<2	11/30/2007	No	No	
EMSL	FH-112807-36	#8 - 5TH FL SCAFFOLD AT NE CORNER	11/28/2007	Scaffold	2.876	040729617-0008	11/30/2007	11/30/2007	NIOSH 7500 XRD	Silica-Quartz	<2	11/30/2007	No	No	
EMSL	FH-112907-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/29/2007	Scaffold	2.890	040729742-0001	11/30/2007	12/01/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/03/2007	No	No	
EMSL	FH-112907-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/29/2007	Scaffold	2.894	040729742-0002	11/30/2007	12/01/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/03/2007	No	No	
EMSL	FH-112907-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/29/2007	Scaffold	2.890	040729742-0003	11/30/2007	12/01/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/03/2007	No	No	
EMSL	FH-112907-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/29/2007	Scaffold	2.862	040729742-0004	11/30/2007	12/01/2007	NIOSH 7500 XRD	Silica-Quartz	2	12/03/2007	No	No	
EMSL	FH-112907-33	#5 - 5TH FL SETBACK ROOF N. SIDE	11/29/2007	Scaffold	2.894	040729742-0005	11/30/2007	12/01/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/03/2007	No	No	
EMSL	FH-112907-34	#6 - 5TH FL SETBACK ROOF SW SIDE	11/29/2007	Scaffold	2.894	040729742-0006	11/30/2007	12/01/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/03/2007	No	No	
EMSL	FH-112907-35	#7 - 5TH FL SCAFFOLD AT SE CORNER	11/29/2007	Scaffold	2.894	040729742-0007	11/30/2007	12/01/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/03/2007	No	No	
EMSL	FH-112907-36	#8 - 5TH FL SCAFFOLD AT NE CORNER	11/29/2007	Scaffold	2.894	040729742-0008	11/30/2007	12/01/2007	NIOSH 7500 XRD	Silica-Quartz	4	12/03/2007	No	No	
EMSL	FH-113007-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	11/30/2007	Scaffold	2.876	040729876-0001	12/04/2007	12/05/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/06/2007	No	No	
EMSL	FH-113007-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	11/30/2007	Scaffold	2.876	040729876-0002	12/04/2007	12/05/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/06/2007	No	No	
EMSL	FH-113007-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	11/30/2007	Scaffold	2.876	040729876-0003	12/04/2007	12/05/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/06/2007	No	No	
EMSL	FH-113007-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	11/30/2007	Scaffold	2.876	040729876-0004	12/04/2007	12/05/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/06/2007	No	No	
EMSL	FH-113007-33	#5 - 5TH FL SETBACK ROOF N. SIDE	11/30/2007	Scaffold	2.876	040729876-0005	12/04/2007	12/05/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/06/2007	No	No	
EMSL	FH-113007-34	#6 - 5TH FL SETBACK ROOF SW SIDE	11/30/2007	Scaffold	2.876	040729876-0006	12/04/2007	12/05/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/06/2007	No	No	
EMSL	FH-113007-35	#7 - 5TH FL SCAFFOLD AT SE CORNER	11/30/2007	Scaffold	2.876	040729876-0007	12/04/2007	12/05/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/06/2007	No	No	
EMSL	FH-113007-36	#8 - 5TH FL SCAFFOLD AT NE CORNER	11/30/2007	Scaffold	2.876	040729876-0008	12/04/2007	12/05/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/06/2007	No	No	
EMSL	FH-120107-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	12/01/2007	Scaffold	2.860	040729881-0001	12/04/2007	12/05/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/06/2007	No	No	
EMSL	FH-120107-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	12/01/2007	Scaffold	2.854	040729881-0002	12/04/2007	12/05/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/06/2007	No	No	
EMSL	FH-120107-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	12/01/2007	Scaffold	2.862	040729881-0003	12/04/2007	12/05/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/06/2007	No	No	
EMSL	FH-120107-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	12/01/2007	Scaffold	2.850	040729881-0004	12/04/2007	12/05/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/06/2007	No	No	
EMSL	FH-120107-33	#5 - 5TH FL SETBACK ROOF N. SIDE	12/01/2007	Scaffold	2.854	040729881-0005	12/04/2007	12/05/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/06/2007	No	No	
EMSL	FH-120107-34	#6 - 5TH FL SETBACK ROOF SW SIDE	12/01/2007	Scaffold	2.858	040729881-0006	12/04/2007	12/05/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/06/2007	No	No	
EMSL	FH-120107-35	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/01/2007	Scaffold	2.834	040729881-0007	12/04/2007	12/05/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/06/2007	No	No	
EMSL	FH-120107-36	#8 - 5TH FL SCAFFOLD AT NE CORNER	12/01/2007	Scaffold	2.858	040729881-0008	12/04/2007	12/05/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/06/2007	No	No	
EMSL	FH-120207-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	12/02/2007	Scaffold	2.884	040729870-0001	12/04/2007	12/06/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/06/2007	No	No	
EMSL	FH-120207-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	12/02/2007	Scaffold	2.882	040729870-0002	12/04/2007	12/06/2007	NIOSH 7500 XRD	Silica-Quartz	12	12/06/2007	Yes	Yes	See Note 1
EMSL	FH-120207-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	12/02/2007	Scaffold	2.874	040729870-0003	12/04/2007	12/06/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/06/2007	No	No	
EMSL	FH-120207-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	12/02/2007	Scaffold	2.870	040729870-0004	12/04/2007	12/06/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/06/2007	No	No	
EMSL	FH-120207-33	#5 - 5TH FL SETBACK ROOF N. SIDE	12/02/2007	Scaffold	2.862	040729870-0005	12/04/2007	12/06/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/06/2007	No	No	
EMSL	FH-120207-34	#6 - 5TH FL SETBACK ROOF SW SIDE	12/02/2007	Scaffold	2.858	040729870-0006	12/04/2007	12/06/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/06/2007	No	No	
EMSL	FH-120207-35	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/02/2007	Scaffold	2.856	040729870-0007	12/04/2007	12/06/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/06/2007	No	No	
EMSL	FH-120207-36	#8 - 5TH FL SCAFFOLD AT NE CORNER	12/02/2007	Scaffold	2.856	040729870-0008	12/04/2007	12/06/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/06/2007	No	No	

Note 1: Exceedance of the USEPA Site Specific Trigger Level for silica at Station #2 (Sidewalk bridge level SW corner) occurred on Sunday, December 2, 2007. Fugitive emissions likely attribute to one or more off site properties directly impacted silica concentrations. After review of all of the information including meteorological data, PM 10 data, site activities logs (no site work on the date of exceedance) and off site visual observations, it has been determined that the silica exceedance measured at Station #2 on December 2, 2007 was not attributable to work activities at 30 West Broadway. Exceedance reported to USEPA.

Submittal Summary - Scaffold Phase Week 31 (11/26/07 to 12/02/07)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	Dioxin/Furans Concentration (ng/m ³)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											0.00025				
EPA Site Specific Trigger Levels											0.025				
STL-SAC	FH-113007-44	#7 - 5TH FL SCAFFOLD AT SE CORNER	11/30/2007	Scaffold	360	G7L040274007	12/04/2007	12/10/2007	TO-9	Toxicity Equivalent Quotient (TEQ)	0.000033	12/17/2007	No	No	

Submittal Summary - Scaffold Phase Week 31 (11/26/07 to 12/02/07)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	PAHs Concentration (ug/m3)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											0.034				
EPA Site Specific Trigger Levels											3.4				
STL-SAC	FH-113007-53	#7 - 5TH FL SCAFFOLD AT SE CORNER	11/30/2007	Scaffold	360	G7L040278007	12/04/2007	12/12/2007	8270C SIM	BAP-equivalent	<0.007	12/18/2007	No	No	

Submittal Summary - Scaffold Phase Week 31 (11/26/07 to 12/02/07)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	PCBs Concentration (ug/m3)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											0.12				
EPA Site Specific Trigger Levels											12				
STL-SAC	FH-113007-62	#7 - 5TH FL SCAFFOLD AT SE CORNER	11/30/2007	Scaffold	360	G7L040300007	12/04/2007	12/07/2007	TO-4	Aroclor 1016	<0.0021	12/17/2007	No	No	
STL-SAC	FH-113007-62	#7 - 5TH FL SCAFFOLD AT SE CORNER	11/30/2007	Scaffold	360	G7L040300007	12/04/2007	12/07/2007	TO-4	Aroclor 1221	<0.0021	12/17/2007	No	No	
STL-SAC	FH-113007-62	#7 - 5TH FL SCAFFOLD AT SE CORNER	11/30/2007	Scaffold	360	G7L040300007	12/04/2007	12/07/2007	TO-4	Aroclor 1232	<0.0021	12/17/2007	No	No	
STL-SAC	FH-113007-62	#7 - 5TH FL SCAFFOLD AT SE CORNER	11/30/2007	Scaffold	360	G7L040300007	12/04/2007	12/07/2007	TO-4	Aroclor 1242	<0.0021	12/17/2007	No	No	
STL-SAC	FH-113007-62	#7 - 5TH FL SCAFFOLD AT SE CORNER	11/30/2007	Scaffold	360	G7L040300007	12/04/2007	12/07/2007	TO-4	Aroclor 1248	<0.0021	12/17/2007	No	No	
STL-SAC	FH-113007-62	#7 - 5TH FL SCAFFOLD AT SE CORNER	11/30/2007	Scaffold	360	G7L040300007	12/04/2007	12/07/2007	TO-4	Aroclor 1254	<0.0021	12/17/2007	No	No	
STL-SAC	FH-113007-62	#7 - 5TH FL SCAFFOLD AT SE CORNER	11/30/2007	Scaffold	360	G7L040300007	12/04/2007	12/07/2007	TO-4	Aroclor 1260	<0.0021	12/17/2007	No	No	