

Submittal Summary - Scaffold Phase Week 32 (12/03/07 to 12/09/07)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Work Shift/Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	Asbestos PCME Concentration (f/cm ³)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels															
EPA Site Specific Trigger Levels															
											0.0009				
											N/A				
EMSL	FH-120307-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	12/3/2007	1/Scaffold	2.886	030737930-0001	12/3/2007	12/4/2007	PCME	ASBESTOS	<0.00086	12/4/2007	No	No	
EMSL	FH-120307-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	12/3/2007	1/Scaffold	2.892	030737930-0002	12/3/2007	12/4/2007	PCME	ASBESTOS	<0.00085	12/4/2007	No	No	
EMSL	FH-120307-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	12/3/2007	1/Scaffold	2.892	030737930-0003	12/3/2007	12/4/2007	PCME	ASBESTOS	<0.00085	12/4/2007	No	No	
EMSL	FH-120307-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	12/3/2007	1/Scaffold	2.928	030737930-0004	12/3/2007	12/4/2007	PCME	ASBESTOS	<0.00084	12/4/2007	No	No	
EMSL	FH-120307-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	12/3/2007	1/Scaffold	2.928	030737930-0005	12/3/2007	12/4/2007	PCME	ASBESTOS	<0.00084	12/4/2007	No	No	
EMSL	FH-120307-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	12/3/2007	1/Scaffold	2.922	030737930-0006	12/3/2007	12/4/2007	PCME	ASBESTOS	<0.00084	12/4/2007	No	No	
EMSL	FH-120307-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	12/3/2007	1/Scaffold	2.790	030737930-0007	12/3/2007	12/4/2007	PCME	ASBESTOS	<0.00088	12/4/2007	No	No	
EMSL	FH-120307-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	12/3/2007	1/Scaffold	2.928	030737930-0008	12/3/2007	12/4/2007	PCME	ASBESTOS	<0.00084	12/4/2007	No	No	
EMSL	FH-120407-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	12/4/2007	1/Scaffold	2.898	030738051-0001	12/4/2007	12/4/2007	PCME	ASBESTOS	<0.00085	12/5/2007	No	No	
EMSL	FH-120407-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	12/4/2007	1/Scaffold	2.898	030738051-0002	12/4/2007	12/4/2007	PCME	ASBESTOS	<0.00085	12/5/2007	No	No	
EMSL	FH-120407-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	12/4/2007	1/Scaffold	2.898	030738051-0003	12/4/2007	12/4/2007	PCME	ASBESTOS	<0.00085	12/5/2007	No	No	
EMSL	FH-120407-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	12/4/2007	1/Scaffold	2.898	030738051-0004	12/4/2007	12/4/2007	PCME	ASBESTOS	<0.00085	12/5/2007	No	No	
EMSL	FH-120407-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	12/4/2007	1/Scaffold	2.888	030738051-0005	12/4/2007	12/4/2007	PCME	ASBESTOS	<0.00085	12/5/2007	No	No	
EMSL	FH-120407-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	12/4/2007	1/Scaffold	2.888	030738051-0006	12/4/2007	12/4/2007	PCME	ASBESTOS	<0.00085	12/5/2007	No	No	
EMSL	FH-120407-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	12/4/2007	1/Scaffold	2.898	030738051-0007	12/4/2007	12/4/2007	PCME	ASBESTOS	<0.00085	12/5/2007	No	No	
EMSL	FH-120407-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	12/4/2007	1/Scaffold	2.888	030738051-0008	12/4/2007	12/4/2007	PCME	ASBESTOS	<0.00085	12/5/2007	No	No	
EMSL	FH-120407-65	DUPLICATE (STATION #1)	12/4/2007	1/Scaffold	2.898	030738051-0009	12/4/2007	12/4/2007	PCME	ASBESTOS	<0.00085	12/5/2007	No	No	
EMSL	FH-120507-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	12/5/2007	1/Scaffold	2.868	030738123-0001	12/5/2007	12/6/2007	PCME	ASBESTOS	<0.00086	12/6/2007	No	No	
EMSL	FH-120507-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	12/5/2007	1/Scaffold	2.874	030738123-0002	12/5/2007	12/6/2007	PCME	ASBESTOS	<0.00086	12/6/2007	No	No	
EMSL	FH-120507-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	12/5/2007	1/Scaffold	2.892	030738123-0003	12/5/2007	12/6/2007	PCME	ASBESTOS	<0.00085	12/6/2007	No	No	
EMSL	FH-120507-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	12/5/2007	1/Scaffold	2.874	030738123-0004	12/5/2007	12/6/2007	PCME	ASBESTOS	<0.00086	12/6/2007	No	No	
EMSL	FH-120507-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	12/5/2007	1/Scaffold	2.874	030738123-0005	12/5/2007	12/6/2007	PCME	ASBESTOS	<0.00086	12/6/2007	No	No	
EMSL	FH-120507-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	12/5/2007	1/Scaffold	2.898	030738123-0006	12/5/2007	12/6/2007	PCME	ASBESTOS	<0.00085	12/6/2007	No	No	
EMSL	FH-120507-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	12/5/2007	1/Scaffold	2.904	030738123-0007	12/5/2007	12/6/2007	PCME	ASBESTOS	<0.00085	12/6/2007	No	No	
EMSL	FH-120507-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	12/5/2007	1/Scaffold	2.904	030738123-0008	12/5/2007	12/6/2007	PCME	ASBESTOS	<0.00085	12/6/2007	No	No	
EMSL	FH-120607-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	12/6/2007	1/Scaffold	2.904	030738266-0001	12/6/2007	12/7/2007	PCME	ASBESTOS	<0.00085	12/7/2007	No	No	
EMSL	FH-120607-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	12/6/2007	1/Scaffold	2.898	030738266-0002	12/6/2007	12/7/2007	PCME	ASBESTOS	<0.00085	12/7/2007	No	No	
EMSL	FH-120607-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	12/6/2007	1/Scaffold	2.892	030738266-0003	12/6/2007	12/7/2007	PCME	ASBESTOS	<0.00085	12/7/2007	No	No	
EMSL	FH-120607-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	12/6/2007	1/Scaffold	2.904	030738266-0004	12/6/2007	12/7/2007	PCME	ASBESTOS	<0.00085	12/7/2007	No	No	
EMSL	FH-120607-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	12/6/2007	1/Scaffold	2.910	030738266-0005	12/6/2007	12/7/2007	PCME	ASBESTOS	<0.00085	12/7/2007	No	No	
EMSL	FH-120607-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	12/6/2007	1/Scaffold	2.910	030738266-0006	12/6/2007	12/7/2007	PCME	ASBESTOS	<0.00085	12/7/2007	No	No	
EMSL	FH-120607-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	12/6/2007	1/Scaffold	2.892	030738266-0007	12/6/2007	12/7/2007	PCME	ASBESTOS	<0.00085	12/7/2007	No	No	
EMSL	FH-120607-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	12/6/2007	1/Scaffold	2.898	030738266-0008	12/6/2007	12/7/2007	PCME	ASBESTOS	<0.00085	12/7/2007	No	No	
EMSL	FH-120707-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	12/7/2007	1/Scaffold	2.886	030738385-0001	12/7/2007	12/8/2007	PCME	ASBESTOS	<0.00086	12/10/2007	No	No	
EMSL	FH-120707-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	12/7/2007	1/Scaffold	2.880	030738385-0002	12/7/2007	12/8/2007	PCME	ASBESTOS	<0.00086	12/10/2007	No	No	
EMSL	FH-120707-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	12/7/2007	1/Scaffold	2.874	030738385-0003	12/7/2007	12/8/2007	PCME	ASBESTOS	<0.00086	12/10/2007	No	No	
EMSL	FH-120707-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	12/7/2007	1/Scaffold	2.922	030738385-0004	12/7/2007	12/8/2007	PCME	ASBESTOS	<0.00084	12/10/2007	No	No	
EMSL	FH-120707-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	12/7/2007	1/Scaffold	2.922	030738385-0005	12/7/2007	12/8/2007	PCME	ASBESTOS	<0.00084	12/10/2007	No	No	
EMSL	FH-120707-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	12/7/2007	1/Scaffold	2.922	030738385-0006	12/7/2007	12/8/2007	PCME	ASBESTOS	<0.00084	12/10/2007	No	No	
EMSL	FH-120707-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	12/7/2007	1/Scaffold	2.784	030738385-0007	12/7/2007	12/8/2007	PCME	ASBESTOS	<0.00089	12/10/2007	No	No	
EMSL	FH-120707-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	12/7/2007	1/Scaffold	2.922	030738385-0008	12/7/2007	12/8/2007	PCME	ASBESTOS	<0.00084	12/10/2007	No	No	
EMSL	FH-120807-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	12/8/2007	1/Scaffold	2.904	030738557-0001	12/10/2007	12/11/2007	PCME	ASBESTOS	<0.00085	12/11/2007	No	No	
EMSL	FH-120807-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	12/8/2007	1/Scaffold	2.904	030738557-0002	12/10/2007	12/11/2007	PCME	ASBESTOS	<0.00085	12/11/2007	No	No	
EMSL	FH-120807-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	12/8/2007	1/Scaffold	2.904	030738557-0003	12/10/2007	12/11/2007	PCME	ASBESTOS	<0.00085	12/11/2007	No	No	
EMSL	FH-120807-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	12/8/2007	1/Scaffold	2.904	030738557-0004	12/10/2007	12/11/2007	PCME	ASBESTOS	<0.00085	12/11/2007	No	No	
EMSL	FH-120807-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	12/8/2007	1/Scaffold	2.898	030738557-0005	12/10/2007	12/11/2007	PCME	ASBESTOS	<0.00085	12/11/2007	No	No	
EMSL	FH-120807-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	12/8/2007	1/Scaffold	2.898	030738557-0006	12/10/2007	12/11/2007	PCME	ASBESTOS	<0.00085	12/11/2007	No	No	
EMSL	FH-120807-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	12/8/2007	1/Scaffold	2.904	030738557-0007	12/10/2007	12/11/2007	PCME	ASBESTOS	<0.00085	12/11/2007	No	No	
EMSL	FH-120807-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	12/8/2007	1/Scaffold	2.898	030738557-0008	12/10/2007	12/11/2007	PCME	ASBESTOS	<0.00085	12/11/2007	No	No	
EMSL	FH-120907-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	12/9/2007	1/Scaffold	2.892	030738563-0001	12/10/2007	12/11/2007	PCME	ASBESTOS	<0.00085	12/12/2007	No	No	
EMSL	FH-120907-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	12/9/2007	1/Scaffold	2.892	030738563-0002	12/10/2007	12/11/2007	PCME	ASBESTOS	<0.00085	12/12/2007	No	No	
EMSL	FH-120907-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	12/9/2007	1/Scaffold	2.892	030738563-0003	12/10/2007	12/11/2007	PCME	ASBESTOS	<0.00085	12/12/2007	No	No	
EMSL	FH-120907-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	12/9/2007	1/Scaffold	2.886	030738563-0004	12/10/2007	12/11/2007	PCME	ASBESTOS	<0.00086	12/12/2007	No	No	
EMSL	FH-120907-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	12/9/2007	1/Scaffold	2.880	030738563-0005	12/10/2007	12/11/2007	PCME	ASBESTOS	<0.00086	12/12/2007	No	No	
EMSL	FH-120907-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	12/9/2007	1/Scaffold	2.880	030738563-0006	12/10/2007	12/11/2007	PCME	ASBESTOS	<0.00086	12/12/2007	No	No	
EMSL	FH-120907-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	12/9/2007	1/Scaffold	2.886	030738563-0007	12/10/2007	12/11/2007	PCME	ASBESTOS	<0.00086	12/12/2007	No	No	
EMSL	FH-120907-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	12/9/2007	1/Scaffold	2.880	030738563-0008	12/10/2007	12/11/2007	PCME	ASBESTOS	<0.00086	12/12/2007	No	No	

Submittal Summary - Scaffold Phase Week 32 (12/03/07 to 12/09/07)

Ohio Lumex Daily Mercury Readings

all readings are in ng/m³

Target air quality level: 300 ng/m³

USEPA site specific mercury trigger level: 3000 ng/m³

Exceedances: None
Exceedances: None

3 Site Tours Conducted per Work Shift

DATE: 12/3/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	10	10	11	12	11	10	10	9	9	10	9	9	10.00	
	1200-1205	Tour 2	9	9	9	10	10	10	11	10	10	10	9	8		9.58
	1500-1505	Tour 3	9	9	9	8	9	10	10	9	9	9	8	9		9.00
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	10	11	11	12	10	10	9	9	8	9	10	11	10.00	
	1210-1215	Tour 2	11	11	12	11	11	10	9	9	9	9	10	9		10.08
	1510-1515	Tour 3	11	11	11	12	11	11	12	12	13	10	10	9		11.08
ROOF PERIMETER	0925-0930	Tour 1	10	9	9	9	9	10	10	9	10	10	9	10	9.50	
	1225-1230	Tour 2	9	9	9	10	10	9	10	10	10	11	9	10		9.67
	1525-1530	Tour 3	9	9	9	10	9	9	10	8	8	9	10	9		9.08

DATE: 12/4/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	9	9	10	10	11	10	9	8	9	10	10	10	9.58	
	1200-1205	Tour 2	10	10	9	9	10	10	10	10	9	9	10	9		9.58
	1500-1505	Tour 3	8	8	8	9	10	10	9	10	10	10	10	9		9.25
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	9	10	10	10	11	10	9	9	9	10	9	10	9.67	
	1210-1215	Tour 2	8	9	9	10	10	9	10	10	10	9	9	8		9.25
	1510-1515	Tour 3	8	9	9	10	10	10	10	10	10	9	10	10		9.58
ROOF PERIMETER	0925-0930	Tour 1	11	10	10	10	9	10	10	8	8	9	10	10	9.58	
	1225-1230	Tour 2	10	10	8	8	8	8	9	8	10	10	9	9		8.92
	1525-1530	Tour 3	10	8	8	7	8	7	8	7	7	8	8	8		7.83

DATE: 12/5/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	10	9	9	10	10	9	9	10	10	8	7	10	9.25	
	1200-1205	Tour 2	10	10	10	11	9	9	9	9	7	7	7	8		8.83
	1500-1505	Tour 3	10	9	10	10	9	10	10	8	7	7	8	10		9.00
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	9	10	10	9	10	10	10	10	9	10	10	10	9.75	
	1210-1215	Tour 2	8	9	9	9	10	10	9	10	10	10	9	8		9.25
	1510-1515	Tour 3	10	9	9	8	8	9	7	8	7	10	10	9		8.67
ROOF PERIMETER	0925-0930	Tour 1	8	8	7	8	8	7	7	7	6	8	6	9	7.42	
	1225-1230	Tour 2	8	9	9	10	10	9	9	8	9	8	8	8		8.75
	1525-1530	Tour 3	8	9	9	10	9	9	10	10	9	8	9	9		9.08

DATE: 12/6/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	8	9	8	8	7	8	9	10	10	9	8	8	8.50	
	1200-1205	Tour 2	8	8	8	9	10	10	10	9	8	8	7	8		8.58
	1500-1505	Tour 3	8	9	9	10	10	9	9	10	7	7	8	9		8.75
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	8	7	7	8	9	9	10	10	10	9	8	10	8.75	
	1210-1215	Tour 2	8	7	8	7	7	7	8	8	9	10	9	9		8.08
	1510-1515	Tour 3	8	7	7	8	7	7	7	8	8	7	9	10		7.75
ROOF PERIMETER	0925-0930	Tour 1	9	8	8	7	8	9	9	9	10	9	9	10	8.75	
	1225-1230	Tour 2	7	8	7	7	8	7	8	8	9	10	10	8		8.08
	1525-1530	Tour 3	8	8	9	8	9	10	9	10	10	10	9	10		9.17

DATE: 12/7/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	10	9	9	8	9	8	10	8	8	9	8	8	8.67	
	1200-1205	Tour 2	9	9	8	8	9	7	8	7	7	7	8	7		7.83
	1500-1505	Tour 3	10	10	10	10	8	8	9	9	9	9	9	10		9.25
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	10	10	9	9	8	8	9	10	10	10	10	9	9.33	
	1210-1215	Tour 2	10	9	9	10	10	9	9	8	8	8	8	9		8.92
	1510-1515	Tour 3	9	9	8	8	10	10	10	8	8	7	7	8		8.50
ROOF PERIMETER	0925-0930	Tour 1	10	9	9	8	7	8	7	7	7	8	7	8	7.92	
	1225-1230	Tour 2	10	9	9	10	9	8	7	7	6	7	6	8		8.00
	1525-1530	Tour 3	10	10	10	11	8	8	8	7	8	8	8	9		8.75

DATE: 12/8/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	10	10	11	10	10	10	9	9	8	9	8	8	9.33	
	1200-1205	Tour 2	9	10	9	11	11	10	9	8	7	7	7	8		8.83
	1500-1505	Tour 3	10	8	7	7	8	8	8	7	9	9	9	8		8.17
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	10	10	9	8	8	7	8	8	10	10	9	10	8.92	
	1210-1215	Tour 2	9	9	9	9	9	8	8	7	9	9	9	9		8.67
	1510-1515	Tour 3	8	9	10	10	10	9	9	8	8	7	8	7		8.58
ROOF PERIMETER	0925-0930	Tour 1	10	10	10	11	11	12	10	9	9	9	8	10	9.92	
	1225-1230	Tour 2	9	9	8	8	7	7	7	7	7	8	8	8		7.75
	1525-1530	Tour 3	9	10	8	8	8	9	9	10	8	8	9	8		8.67

DATE: 12/9/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	10	10	9	8	9	9	7	8	8	7	7	8	8.33	
	1200-1205	Tour 2	9	10	10	10	10	8	8	8	9	9	8	8		8.92
	1500-1505	Tour 3	9	9	10	9	9	10	8	8	8	8	8	9		8.75
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	7	7	7	8	8	10	10	10	10	10	9	9	8.75	
	1210-1215	Tour 2	9	8	8	9	7	7	10	10	10	10	8	10		8.83
	1510-1515	Tour 3	10	10	9	9	9	10	10	8	8	8	8	8		8.92
ROOF PERIMETER	0925-0930	Tour 1	11	10	11	10	10	10	9	9	9	9	10	8	9.67	
	1225-1230	Tour 2	9	9	9	10	10	9	9	9	9	10	8	8		9.08
	1525-1530	Tour 3	8	8	10	9	9	10	10	10	10	10	9	9		9.33

Submittal Summary - Scaffold Phase Week 32 (12/03/07 to 12/09/07)

Lab Name	Field Sample ID	Sample Location	Date Collected	Project Phase	Sample Volume (m3)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Antimony Concentration (ng/m ³)	Barium Concentration (ng/m ³)	Beryllium Concentration (ng/m ³)	Cadmium Concentration (ng/m ³)	Chromium (Total) Concentration (ng/m ³)	Copper Concentration (ng/m ³)	Lead Concentration (ng/m ³)	Manganese Concentration (ng/m ³)	Nickel Concentration (ng/m ³)	Zinc Concentration (ng/m ³)	Unit	Flag	Qualifier	Date Reported	Exceeds Target Air Quality Level?	Exceeds EPA Site Specific Trigger Level?	Comments	
Target Air Quality Levels										5,000	5,000	20	50	2,000	500	1,000	500	1,000	16,000								
EPA Site Specific Trigger Levels										14,000	14,000	200	100,000	2,000	100,000	1,000	5,000	200	16,000								
STL-SAC	PH-120307-20	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	12/3/2007	Scaffold	5.772	GLT050155001	12/5/2007	12/6/2007	6020	<-34.6	<-1730	<-173	<-173	<-173	<-86.6	<-17.2	<-86.6	<-86.6	<-86.6	<-344	ng/m ³			12/10/2007	No	No	
STL-SAC	PH-120307-21	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	12/3/2007	Scaffold	5.776	GLT050155002	12/5/2007	12/6/2007	6020	<-34.6	<-1730	<-173	<-173	<-173	<-86.6	<-17.2	<-86.6	<-86.6	<-86.6	<-344	ng/m ³			12/10/2007	No	No	
STL-SAC	PH-120307-22	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	12/3/2007	Scaffold	5.778	GLT050155003	12/5/2007	12/6/2007	6020	<-34.6	<-1730	<-173	<-173	<-173	<-86.6	<-17.2	<-86.6	<-86.6	<-86.6	<-344	ng/m ³			12/10/2007	No	No	
STL-SAC	PH-120307-23	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	12/3/2007	Scaffold	5.812	GLT050155004	12/5/2007	12/6/2007	6020	<-34.4	<-1720	<-172	<-172	<-172	<-86.0	<-17.2	<-86.0	<-86.0	<-86.0	<-344	ng/m ³			12/10/2007	No	No	
STL-SAC	PH-120307-24	#5 - 5TH FLOOR SETBACK ROOF N SIDE	12/3/2007	Scaffold	5.820	GLT050155005	12/5/2007	12/6/2007	6020	<-34.4	<-1720	<-172	<-172	<-172	<-86.0	<-17.2	<-86.0	<-86.0	<-86.0	<-344	ng/m ³			12/10/2007	No	No	
STL-SAC	PH-120307-25	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	12/3/2007	Scaffold	5.816	GLT050155006	12/5/2007	12/6/2007	6020	<-34.4	<-1720	<-172	<-172	<-172	<-86.0	<-17.2	<-86.0	<-86.0	<-86.0	<-344	ng/m ³			12/10/2007	No	No	
STL-SAC	PH-120307-26	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	12/3/2007	Scaffold	5.884	GLT050155007	12/5/2007	12/6/2007	6020	<-36.2	<-1760	<-176	<-176	<-176	<-88.2	<-17.6	<-88.2	<-88.2	<-88.2	<-352	ng/m ³			12/10/2007	No	No	
STL-SAC	PH-120307-27	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	12/3/2007	Scaffold	5.82	GLT050155008	12/5/2007	12/6/2007	6020	<-34.4	<-1720	<-172	<-172	<-172	<-86.0	<-17.2	<-86.0	<-86.0	<-344	ng/m ³			12/10/2007	No	No		
STL-SAC	PH-120407-20	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	12/4/2007	Scaffold	5.764	GLT060145001	12/6/2007	12/10/2007	6020	<-34.7	<-1730	<-173	<-173	<-173	<-86.7	<-17.3	<-86.7	<-86.7	<-347	ng/m ³			12/11/2007	No	No		
STL-SAC	PH-120407-21	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	12/4/2007	Scaffold	5.776	GLT060145002	12/6/2007	12/10/2007	6020	<-34.6	<-1730	<-173	<-173	<-173	<-86.6	<-17.3	<-86.6	<-86.6	<-346	ng/m ³			12/11/2007	No	No		
STL-SAC	PH-120407-22	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	12/4/2007	Scaffold	5.776	GLT060145003	12/6/2007	12/10/2007	6020	<-34.6	<-1730	<-173	<-173	<-173	<-86.6	<-17.3	<-86.6	<-86.6	<-346	ng/m ³			12/11/2007	No	No		
STL-SAC	PH-120407-23	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	12/4/2007	Scaffold	5.778	GLT060145004	12/6/2007	12/10/2007	6020	<-34.6	<-1730	<-173	<-173	<-173	<-86.6	<-17.3	<-86.6	<-86.6	<-346	ng/m ³			12/11/2007	No	No		
STL-SAC	PH-120407-24	#5 - 5TH FLOOR SETBACK ROOF N SIDE	12/4/2007	Scaffold	5.776	GLT060145005	12/6/2007	12/10/2007	6020	<-34.6	<-1730	<-173	<-173	<-173	<-86.6	<-17.3	<-86.6	<-86.6	<-346	ng/m ³			12/11/2007	No	No		
STL-SAC	PH-120407-25	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	12/4/2007	Scaffold	5.778	GLT060145006	12/6/2007	12/10/2007	6020	<-34.6	<-1730	<-173	<-173	<-173	<-86.6	<-17.3	<-86.6	<-86.6	<-346	ng/m ³			12/11/2007	No	No		
STL-SAC	PH-120407-26	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	12/4/2007	Scaffold	5.776	GLT060145007	12/6/2007	12/10/2007	6020	<-34.6	<-1730	<-173	<-173	<-173	<-86.6	<-17.3	<-86.6	<-86.6	<-346	ng/m ³			12/11/2007	No	No		
STL-SAC	PH-120407-27	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	12/4/2007	Scaffold	5.776	GLT060145008	12/6/2007	12/10/2007	6020	<-34.6	<-1730	<-173	<-173	<-173	<-86.6	<-17.3	<-86.6	<-86.6	<-346	ng/m ³			12/11/2007	No	No		
STL-SAC	PH-120407-67	DUPLICATE (STATION #1)	12/4/2007	Scaffold	5.764	GLT060145010	12/6/2007	12/10/2007	6020	<-34.7	<-1730	<-173	<-173	<-173	<-86.7	<-17.3	<-86.7	<-86.7	<-347	ng/m ³			12/11/2007	No	No		
STL-SAC	PH-120507-20	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	12/5/2007	Scaffold	5.748	GLT070180001	12/7/2007	12/10/2007	6020	<-34.8	<-1740	<-174	<-174	<-174	<-86.8	<-17.4	<-86.8	<-86.8	<-348	ng/m ³			12/11/2007	No	No		
STL-SAC	PH-120507-21	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	12/5/2007	Scaffold	5.744	GLT070180002	12/7/2007	12/10/2007	6020	<-34.8	<-1740	<-174	<-174	<-174	<-86.8	<-17.4	<-86.8	<-86.8	<-348	ng/m ³			12/11/2007	No	No		
STL-SAC	PH-120507-22	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	12/5/2007	Scaffold	5.748	GLT070180003	12/7/2007	12/10/2007	6020	<-34.8	<-1740	<-174	<-174	<-174	<-86.8	<-17.4	<-86.8	<-86.8	<-348	ng/m ³			12/11/2007	No	No		
STL-SAC	PH-120507-23	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	12/5/2007	Scaffold	5.744	GLT070180004	12/7/2007	12/10/2007	6020	<-34.8	<-1740	<-174	<-174	<-174	<-86.8	<-17.4	<-86.8	<-86.8	<-348	ng/m ³			12/11/2007	No	No		
STL-SAC	PH-120507-24	#5 - 5TH FLOOR SETBACK ROOF N SIDE	12/5/2007	Scaffold	5.744	GLT070180005	12/7/2007	12/10/2007	6020	<-34.8	<-1740	<-174	<-174	<-174	<-86.8	<-17.4	<-86.8	<-86.8	<-348	ng/m ³			12/11/2007	No	No		
STL-SAC	PH-120507-25	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	12/5/2007	Scaffold	5.752	GLT070180006	12/7/2007	12/10/2007	6020	<-34.8	<-1740	<-174	<-174	<-174	<-86.8	<-17.4	<-86.8	<-86.8	<-348	ng/m ³			12/11/2007	No	No		
STL-SAC	PH-120507-26	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	12/5/2007	Scaffold	5.744	GLT070180007	12/7/2007	12/10/2007	6020	<-34.8	<-1740	<-174	<-174	<-174	<-86.8	<-17.4	<-86.8	<-86.8	<-348	ng/m ³			12/11/2007	No	No		
STL-SAC	PH-120507-27	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	12/5/2007	Scaffold	5.76	GLT070180008	12/7/2007	12/10/2007	6020	<-34.7	<-1740	<-174	<-174	<-174	<-86.8	<-17.4	<-86.8	<-86.8	<-347	ng/m ³			12/11/2007	No	No		
STL-SAC	PH-120607-20	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	12/6/2007	Scaffold	5.748	GLT080205001	12/8/2007	12/10/2007	6020	<-34.8	<-1740	<-174	<-174	<-174	<-86.8	<-17.4	<-86.8	<-86.8	<-348	ng/m ³			12/12/2007	No	No		
STL-SAC	PH-120607-21	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	12/6/2007	Scaffold	5.744	GLT080205002	12/8/2007	12/10/2007	6020	<-34.8	<-1740	<-174	<-174	<-174	<-86.8	<-17.4	<-86.8	<-86.8	<-348	ng/m ³			12/12/2007	No	No		
STL-SAC	PH-120607-22	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	12/6/2007	Scaffold	5.748	GLT080205003	12/8/2007	12/10/2007	6020	<-34.8	<-1740	<-174	<-174	<-174	<-86.8	<-17.4	<-86.8	<-86.8	<-348	ng/m ³			12/12/2007	No	No		
STL-SAC	PH-120607-23	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	12/6/2007	Scaffold	5.744	GLT080205004	12/8/2007	12/10/2007	6020	<-34.8	<-1740	<-174	<-174	<-174	<-86.8	<-17.4	<-86.8	<-86.8	<-348	ng/m ³			12/12/2007	No	No		
STL-SAC	PH-120607-24	#5 - 5TH FLOOR SETBACK ROOF N SIDE	12/6/2007	Scaffold	5.744	GLT080205005	12/8/2007	12/10/2007	6020	<-34.8	<-1740	<-174	<-174	<-174	<-86.8	<-17.4	<-86.8	<-86.8	<-348	ng/m ³			12/12/2007	No	No		
STL-SAC	PH-120607-25	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	12/6/2007	Scaffold	5.752	GLT080205006	12/8/2007	12/10/2007	6020	<-34.8	<-1740	<-174	<-174	<-174	<-86.8	<-17.4	<-86.8	<-86.8	<-348	ng/m ³			12/12/2007	No	No		
STL-SAC	PH-120607-26	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	12/6/2007	Scaffold	5.748	GLT080205007	12/8/2007	12/10/2007	6020	<-34.8	<-1740	<-174	<-174	<-174	<-86.8	<-17.4	<-86.8	<-86.8	<-348	ng/m ³			12/12/2007	No	No		
STL-SAC	PH-120607-27	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	12/6/2007	Scaffold	5.76	GLT080205008	12/8/2007	12/10/2007	6020	<-34.7	<-1740	<-174	<-174	<-174	<-86.8	<-17.4	<-86.8	<-86.8	<-347	ng/m ³			12/12/2007	No	No		
STL-SAC	PH-120707-20	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	12/7/2007	Scaffold	5.76	GLT120183001	12/12/2007	12/13/2007	6020	<-34.7	<-1740	<-174	<-174	<-174	<-86.8	<-17.4	<-86.8	<-86.8	<-347	ng/m ³			12/12/2007	No	No		
STL-SAC	PH-120707-21	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	12/7/2007	Scaffold	5.76	GLT120183002	12/12/2007	12/13/2007	6020	<-34.7	<-1740	<-174	<-174	<-174	<-86.8	<-17.4	<-86.8	<-86.8	<-347	ng/m ³			12/12/2007	No	No		
STL-SAC	PH-120707-22	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	12/7/2007	Scaffold	5.768	GLT120183003	12/12/2007	12/13/2007	6020	<-34.7	<-1740	<-174	<-174	<-174	<-86.8	<-17.4	<-86.8	<-86.8	<-347	ng/m ³			12/12/2007	No	No		
STL-SAC	PH-120707-23	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	12/7/2007	Scaffold	5.744	GLT120183004	12/12/2007	12/13																			

Submittal Summary - Scaffold Phase Week 32 (12/03/07 to 12/09/07)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	Dioxin/Furans Concentration (ng/m ³)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											0.00025				
EPA Site Specific Trigger Levels											0.025				
STL-SAC	FH-120607-44	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/6/2007	Scaffold	360	G7L100173007	12/08/2007	12/19/2007	TO-9	Toxicity Equivalent Quotient (TEQ)	0.000062	12/26/2007	No	No	

Submittal Summary - Scaffold Phase Week 32 (12/03/07 to 12/09/07)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	PAHs Concentration (ug/m3)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											0.034				
EPA Site Specific Trigger Levels											3.4				
STL-SAC	FH-120607-53	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/6/2007	Scaffold	360	G7L100177007	12/08/2007	12/13/2007	8270C SIM	BAP-equivalent	<0.007	12/26/2007	No	No	

Submittal Summary - Scaffold Phase Week 32 (12/03/07 to 12/09/07)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	PCBs Concentration (ug/m3)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											0.12				
EPA Site Specific Trigger Levels											12				
STL-SAC	FH-120607-62	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/6/2007	Scaffold	360	G7L100170007	12/08/2007	12/14/2007	TO-4	Aroclor 1016	<0.0021	12/26/2007	No	No	
STL-SAC	FH-120607-62	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/6/2007	Scaffold	360	G7L100170007	12/08/2007	12/14/2007	TO-4	Aroclor 1221	<0.0021	12/26/2007	No	No	
STL-SAC	FH-120607-62	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/6/2007	Scaffold	360	G7L100170007	12/08/2007	12/14/2007	TO-4	Aroclor 1232	<0.0021	12/26/2007	No	No	
STL-SAC	FH-120607-62	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/6/2007	Scaffold	360	G7L100170007	12/08/2007	12/14/2007	TO-4	Aroclor 1242	<0.0021	12/26/2007	No	No	
STL-SAC	FH-120607-62	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/6/2007	Scaffold	360	G7L100170007	12/08/2007	12/14/2007	TO-4	Aroclor 1248	<0.0021	12/26/2007	No	No	
STL-SAC	FH-120607-62	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/6/2007	Scaffold	360	G7L100170007	12/08/2007	12/14/2007	TO-4	Aroclor 1254	<0.0021	12/26/2007	No	No	
STL-SAC	FH-120607-62	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/6/2007	Scaffold	360	G7L100170007	12/08/2007	12/14/2007	TO-4	Aroclor 1260	<0.0021	12/26/2007	No	No	