

Submittal Summary - Scaffold Phase Week 33 (12/10/07 to 12/16/07)

Ohio Lumex Daily Mercury Readings

all readings are in ng/m³

Target air quality level: 300 ng/m³

USEPA site specific mercury trigger level: 3000 ng/m³

Exceedances: None
Exceedances: None

3 Site Tours Conducted per Work Shift

DATE: 12/10/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	10	11	11	11	12	10	9	10	10	9	9	10	10.17	
	1200-1205	Tour 2	10	11	11	11	11	11	10	10	10	10	9	10		10.33
	1500-1505	Tour 3	10	11	11	11	9	11	10	10	10	10	11	10		10.33
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	12	11	11	10	10	10	9	9	10	9	10	11	10.17	
	1210-1215	Tour 2	10	10	11	10	11	10	10	9	10	9	10	11		10.08
	1510-1515	Tour 3	11	11	12	11	11	12	12	11	12	11	10	10		11.17
ROOF PERIMETER	0925-0930	Tour 1	12	13	12	11	10	10	10	10	11	10	10	9	10.67	
	1225-1230	Tour 2	11	11	11	12	11	10	10	10	10	10	10	10		10.50
	1525-1530	Tour 3	10	10	9	10	9	9	10	10	10	11	10	10		9.83

DATE: 12/11/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	10	10	10	9	10	10	10	11	11	10	10	9	10.00	
	1200-1205	Tour 2	9	9	10	9	10	10	10	9	10	11	10	10		9.75
	1500-1505	Tour 3	10	10	10	9	10	9	10	9	9	9	10	9		9.50
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	10	10	10	9	9	9	10	9	10	8	9	9	9.33	
	1210-1215	Tour 2	8	9	9	10	10	9	10	9	10	10	10	8		9.33
	1510-1515	Tour 3	8	8	9	8	9	9	10	10	9	10	9	10		9.08
ROOF PERIMETER	0925-0930	Tour 1	10	9	9	10	9	9	8	8	9	10	10	9	9.17	
	1225-1230	Tour 2	10	9	9	10	10	10	10	8	8	8	10	9		9.25
	1525-1530	Tour 3	10	10	9	10	10	9	9	9	10	10	9	10		9.58

DATE: 12/12/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	12	12	12	11	9	11	9	10	11	12	11	11	10.92	
	1200-1205	Tour 2	11	11	10	10	10	11	9	9	9	11	10	10		10.08
	1500-1505	Tour 3	11	12	12	11	11	11	9	10	8	8	8	8		9.92
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	11	12	11	9	9	9	10	10	8	11	11	11	10.17	
	1210-1215	Tour 2	10	10	10	12	11	11	10	10	10	10	10	10		10.33
	1510-1515	Tour 3	9	11	9	9	9	10	11	11	11	12	11	12		10.42
ROOF PERIMETER	0925-0930	Tour 1	10	10	9	9	9	9	10	10	10	11	11	11	9.92	
	1225-1230	Tour 2	9	9	11	11	8	8	9	9	11	11	12	11		9.92
	1525-1530	Tour 3	11	12	12	11	10	10	11	10	11	9	9	9		10.42

DATE: 12/13/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	9	9	10	10	10	9	11	8	8	8	9	9	9.17	
	1200-1205	Tour 2	8	8	8	10	9	9	10	10	10	8	8	9.00		
	1500-1505	Tour 3	9	10	10	9	8	7	8	8	8	9	9	10		8.75
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	10	10	10	10	9	11	11	9	8	8	8	9	9.42	
	1210-1215	Tour 2	9	8	9	10	10	9	8	8	9	9	9	9		8.92
	1510-1515	Tour 3	10	10	10	8	8	9	9	9	8	8	7	8		8.67
ROOF PERIMETER	0925-0930	Tour 1	11	11	10	9	9	10	9	8	8	7	8	8	9.00	
	1225-1230	Tour 2	10	9	9	8	9	9	9	8	8	8	9	9		8.83
	1525-1530	Tour 3	8	8	8	9	9	8	10	11	9	9	9	10		9.00

DATE: 12/14/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	9	9	10	9	9	9	8	8	8	9	9	9	8.83	
	1200-1205	Tour 2	10	10	10	11	8	8	8	9	9	10	10	10		9.42
	1500-1505	Tour 3	11	10	9	9	9	10	10	9	9	9	10	9		9.50
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	8	7	9	9	7	8	8	8	8	9	9	10	8.33	
	1210-1215	Tour 2	10	10	9	10	10	10	10	9	9	9	9	9		9.50
	1510-1515	Tour 3	9	10	9	10	10	9	9	9	10	8	8	9		9.17
ROOF PERIMETER	0925-0930	Tour 1	10	10	10	10	9	9	9	10	10	8	9	9	9.42	
	1225-1230	Tour 2	9	9	9	10	10	9	10	10	9	9	9	9		9.33
	1525-1530	Tour 3	8	8	8	9	10	9	10	10	10	9	10	9		9.17

DATE: 12/15/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	10	10	10	9	9	10	8	8	8	9	10	9	9.17	
	1200-1205	Tour 2	9	9	10	10	10	8	10	9	9	9	10	10		9.42
	1500-1505	Tour 3	8	8	8	9	8	8	10	10	9	9	9	9		8.75
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	11	11	10	11	9	9	10	8	8	9	9	9	9.50	
	1210-1215	Tour 2	9	9	9	10	9	9	10	10	10	10	10	10		9.58
	1510-1515	Tour 3	9	9	10	10	10	8	8	10	9	9	9	9		9.17
ROOF PERIMETER	0925-0930	Tour 1	10	11	11	11	10	10	8	8	9	9	10	10	9.75	
	1225-1230	Tour 2	9	9	10	9	9	10	10	10	10	9	9	9		9.42
	1525-1530	Tour 3	10	8	8	10	10	10	9	10	9	10	9	10		9.42

DATE: 12/16/2007

AREA:	TIME:	Tour #:	TOUR AVERAGE:													
PERIMETER OF BUILDING	0900-0905	Tour 1	9	9	10	10	9	9	9	10	10	10	8	8	9.25	
	1200-1205	Tour 2	8	9	9	10	8	8	10	10	9	9	9	9		9.00
	1500-1505	Tour 3	10	10	10	9	9	8	9	11	11	11	9	8		9.58
5th FLOOR SETBACK ROOF PERIMETER	0910-0915	Tour 1	9	8	8	9	10	10	10	9	9	8	8	8	8.83	
	1210-1215	Tour 2	10	9	9	10	10	9	8	8	8	9	10	10		9.17
	1510-1515	Tour 3	11	11	9	8	8	8	9	9	10	10	9	9		9.25
ROOF PERIMETER	0925-0930	Tour 1	10	10	9	9	10	11	11	9	8	8	8	8	9.25	
	1225-1230	Tour 2	9	9	9	8	8	9	10	10	8	9	9	9		8.92
	1525-1530	Tour 3	11	11	10	11	9	10	9	10	10	10	10	9		10.00

Submittal Summary - Scaffold Phase Week 33 (12/10/07 to 12/16/07)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Work Shift/Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	Silica-Quartz Concentration (ug/m3)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels												10			
EPA Site Specific Trigger Levels												10			
EMSL	FH-121007-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	12/10/2007	Scaffold	2.884	040730548-0001	12/12/2007	12/12/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/13/2007	No	No	
EMSL	FH-121007-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	12/10/2007	Scaffold	2.886	040730548-0002	12/12/2007	12/12/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/13/2007	No	No	
EMSL	FH-121007-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	12/10/2007	Scaffold	2.886	040730548-0003	12/12/2007	12/12/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/13/2007	No	No	
EMSL	FH-121007-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	12/10/2007	Scaffold	2.884	040730548-0004	12/12/2007	12/12/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/13/2007	No	No	
EMSL	FH-121007-33	#5 - 5TH FL SETBACK ROOF N. SIDE	12/10/2007	Scaffold	2.880	040730548-0005	12/12/2007	12/12/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/13/2007	No	No	
EMSL	FH-121007-34	#6 - 5TH FL SETBACK ROOF SW SIDE	12/10/2007	Scaffold	2.880	040730548-0006	12/12/2007	12/12/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/13/2007	No	No	
EMSL	FH-121007-35	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/10/2007	Scaffold	2.884	040730548-0007	12/12/2007	12/12/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/13/2007	No	No	
EMSL	FH-121007-36	#8 - 5TH FL SCAFFOLD AT NE CORNER	12/10/2007	Scaffold	2.878	040730548-0008	12/12/2007	12/12/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/13/2007	No	No	
EMSL	FH-121107-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	12/11/2007	Scaffold	2.882	040730628-0001	12/13/2007	12/13/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/14/2007	No	No	
EMSL	FH-121107-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	12/11/2007	Scaffold	2.884	040730628-0002	12/13/2007	12/13/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/14/2007	No	No	
EMSL	FH-121107-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	12/11/2007	Scaffold	2.878	040730628-0003	12/13/2007	12/13/2007	NIOSH 7500 XRD	Silica-Quartz	2	12/14/2007	No	No	
EMSL	FH-121107-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	12/11/2007	Scaffold	2.880	040730628-0004	12/13/2007	12/13/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/14/2007	No	No	
EMSL	FH-121107-33	#5 - 5TH FL SETBACK ROOF N. SIDE	12/11/2007	Scaffold	2.884	040730628-0005	12/13/2007	12/13/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/14/2007	No	No	
EMSL	FH-121107-34	#6 - 5TH FL SETBACK ROOF SW SIDE	12/11/2007	Scaffold	2.884	040730628-0006	12/13/2007	12/13/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/14/2007	No	No	
EMSL	FH-121107-35	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/11/2007	Scaffold	2.878	040730628-0007	12/13/2007	12/13/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/14/2007	No	No	
EMSL	FH-121107-36	#8 - 5TH FL SCAFFOLD AT NE CORNER	12/11/2007	Scaffold	2.884	040730628-0008	12/13/2007	12/13/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/14/2007	No	No	
EMSL	FH-121107-68	DUPLICATE (STATION #1)	12/11/2007	Scaffold	2.882	040730628-0010	12/13/2007	12/13/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/14/2007	No	No	
EMSL	FH-121207-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	12/12/2007	Scaffold	2.878	040730731-0001	12/14/2007	12/14/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/15/2007	No	No	
EMSL	FH-121207-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	12/12/2007	Scaffold	2.874	040730731-0002	12/14/2007	12/14/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/15/2007	No	No	
EMSL	FH-121207-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	12/12/2007	Scaffold	2.880	040730731-0003	12/14/2007	12/14/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/15/2007	No	No	
EMSL	FH-121207-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	12/12/2007	Scaffold	2.880	040730731-0004	12/14/2007	12/14/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/15/2007	No	No	
EMSL	FH-121207-33	#5 - 5TH FL SETBACK ROOF N. SIDE	12/12/2007	Scaffold	2.878	040730731-0005	12/14/2007	12/14/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/15/2007	No	No	
EMSL	FH-121207-34	#6 - 5TH FL SETBACK ROOF SW SIDE	12/12/2007	Scaffold	2.882	040730731-0006	12/14/2007	12/14/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/15/2007	No	No	
EMSL	FH-121207-35	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/12/2007	Scaffold	2.882	040730731-0007	12/14/2007	12/14/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/15/2007	No	No	
EMSL	FH-121207-36	#8 - 5TH FL SCAFFOLD AT NE CORNER	12/12/2007	Scaffold	2.882	040730731-0008	12/14/2007	12/14/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/15/2007	No	No	
EMSL	FH-121307-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	12/13/2007	Scaffold	2.882	040730813-0001	12/15/2007	12/15/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/17/2007	No	No	
EMSL	FH-121307-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	12/13/2007	Scaffold	2.882	040730813-0002	12/15/2007	12/15/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/17/2007	No	No	
EMSL	FH-121307-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	12/13/2007	Scaffold	2.882	040730813-0003	12/15/2007	12/15/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/17/2007	No	No	
EMSL	FH-121307-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	12/13/2007	Scaffold	2.882	040730813-0004	12/15/2007	12/15/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/17/2007	No	No	
EMSL	FH-121307-33	#5 - 5TH FL SETBACK ROOF N. SIDE	12/13/2007	Scaffold	2.882	040730813-0005	12/15/2007	12/15/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/17/2007	No	No	
EMSL	FH-121307-34	#6 - 5TH FL SETBACK ROOF SW SIDE	12/13/2007	Scaffold	2.882	040730813-0006	12/15/2007	12/15/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/17/2007	No	No	
EMSL	FH-121307-35	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/13/2007	Scaffold	2.882	040730813-0007	12/15/2007	12/15/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/17/2007	No	No	
EMSL	FH-121307-36	#8 - 5TH FL SCAFFOLD AT NE CORNER	12/13/2007	Scaffold	2.882	040730813-0008	12/15/2007	12/15/2007	NIOSH 7500 XRD	Silica-Quartz	11	12/17/2007	Yes	Yes	See Note 1
EMSL	FH-121407-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	12/14/2007	Scaffold	2.874	040730984-0001	12/18/2007	12/19/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/20/2007	No	No	
EMSL	FH-121407-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	12/14/2007	Scaffold	2.874	040730984-0002	12/18/2007	12/19/2007	NIOSH 7500 XRD	Silica-Quartz	3	12/20/2007	No	No	
EMSL	FH-121407-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	12/14/2007	Scaffold	2.874	040730984-0003	12/18/2007	12/19/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/20/2007	No	No	
EMSL	FH-121407-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	12/14/2007	Scaffold	2.874	040730984-0004	12/18/2007	12/19/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/20/2007	No	No	
EMSL	FH-121407-33	#5 - 5TH FL SETBACK ROOF N. SIDE	12/14/2007	Scaffold	2.874	040730984-0005	12/18/2007	12/19/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/20/2007	No	No	
EMSL	FH-121407-34	#6 - 5TH FL SETBACK ROOF SW SIDE	12/14/2007	Scaffold	2.870	040730984-0006	12/18/2007	12/19/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/20/2007	No	No	
EMSL	FH-121407-35	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/14/2007	Scaffold	2.874	040730984-0007	12/18/2007	12/19/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/20/2007	No	No	
EMSL	FH-121407-36	#8 - 5TH FL SCAFFOLD AT NE CORNER	12/14/2007	Scaffold	2.870	040730984-0008	12/18/2007	12/19/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/20/2007	No	No	
EMSL	FH-121507-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	12/15/2007	Scaffold	2.884	040730979-0001	12/18/2007	12/19/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/20/2007	No	No	
EMSL	FH-121507-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	12/15/2007	Scaffold	2.886	040730979-0002	12/18/2007	12/19/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/20/2007	No	No	
EMSL	FH-121507-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	12/15/2007	Scaffold	2.886	040730979-0003	12/18/2007	12/19/2007	NIOSH 7500 XRD	Silica-Quartz	2	12/20/2007	No	No	
EMSL	FH-121507-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	12/15/2007	Scaffold	2.884	040730979-0004	12/18/2007	12/19/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/20/2007	No	No	
EMSL	FH-121507-33	#5 - 5TH FL SETBACK ROOF N. SIDE	12/15/2007	Scaffold	2.884	040730979-0005	12/18/2007	12/19/2007	NIOSH 7500 XRD	Silica-Quartz	2	12/20/2007	No	No	
EMSL	FH-121507-34	#6 - 5TH FL SETBACK ROOF SW SIDE	12/15/2007	Scaffold	2.884	040730979-0006	12/18/2007	12/19/2007	NIOSH 7500 XRD	Silica-Quartz	3	12/20/2007	No	No	
EMSL	FH-121507-35	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/15/2007	Scaffold	2.886	040730979-0007	12/18/2007	12/19/2007	NIOSH 7500 XRD	Silica-Quartz	3	12/20/2007	No	No	
EMSL	FH-121507-36	#8 - 5TH FL SCAFFOLD AT NE CORNER	12/15/2007	Scaffold	2.886	040730979-0008	12/18/2007	12/19/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/20/2007	No	No	
EMSL	FH-121607-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	12/16/2007	Scaffold	2.882	040730983-0001	12/18/2007	12/19/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/20/2007	No	No	
EMSL	FH-121607-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	12/16/2007	Scaffold	2.882	040730983-0002	12/18/2007	12/19/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/20/2007	No	No	
EMSL	FH-121607-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	12/16/2007	Scaffold	2.882	040730983-0003	12/18/2007	12/19/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/20/2007	No	No	
EMSL	FH-121607-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	12/16/2007	Scaffold	2.882	040730983-0004	12/18/2007	12/19/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/20/2007	No	No	
EMSL	FH-121607-33	#5 - 5TH FL SETBACK ROOF N. SIDE	12/16/2007	Scaffold	2.882	040730983-0005	12/18/2007	12/19/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/20/2007	No	No	
EMSL	FH-121607-34	#6 - 5TH FL SETBACK ROOF SW SIDE	12/16/2007	Scaffold	2.882	040730983-0006	12/18/2007	12/19/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/20/2007	No	No	
EMSL	FH-121607-35	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/16/2007	Scaffold	2.882	040730983-0007	12/18/2007	12/19/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/20/2007	No	No	
EMSL	FH-121607-36	#8 - 5TH FL SCAFFOLD AT NE CORNER	12/16/2007	Scaffold	2.882	040730983-0008	12/18/2007	12/19/2007	NIOSH 7500 XRD	Silica-Quartz	<2	12/20/2007	No	No	

Note 1: Exceedance of the USEPA Site Specific Trigger Level for silica at Station #8 (5th Floor scaffold at NE corner) occurred on Thursday, December 13, 2007. Fugitive emissions likely attribute to one or more off site properties directly impacted silica concentrations. After review of all of the information including meteorological data, PM 10 data, site activities logs and off site visual observations, it has been determined that the silica exceedance measured at Station #8 on December 13, 2007 was not attributable to work activities at 30 West Broadway. Exceedance reported to USEPA.

Submittal Summary - Scaffold Phase Week 33 (12/10/07 to 12/16/07)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	Dioxin/Furans Concentration (ng/m3)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											0.00025				
EPA Site Specific Trigger Levels											0.025				
STL-SAC	FH-121207-44	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/12/2007	Scaffold	360	G7L140221007	12/14/2007	01/01/2008	TO-9	Toxicity Equivalent Quotient (TEQ)	0.000087	01/03/2008	No	No	

Submittal Summary - Scaffold Phase Week 33 (12/10/07 to 12/16/07)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	PAHs Concentration (ug/m3)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											0.034				
EPA Site Specific Trigger Levels											3.4				
STL-SAC	FH-121207-53	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/12/2007	Scaffold	360	G7L140223007	12/14/2007	12/24/2007	8270C SIM	BAP-equivalent	<0.007	12/28/2007	No	No	

Submittal Summary - Scaffold Phase Week 33 (12/10/07 to 12/16/07)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	PCBs Concentration (ug/m3)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											0.12				
EPA Site Specific Trigger Levels											12				
STL-SAC	FH-121207-62	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/12/2007	Scaffold	360	G7L140216007	12/14/2007	12/26/2007	TO-4	Aroclor 1016	<0.0021	12/27/2007	No	No	
STL-SAC	FH-121207-62	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/12/2007	Scaffold	360	G7L140216007	12/14/2007	12/26/2007	TO-4	Aroclor 1221	<0.0021	12/27/2007	No	No	
STL-SAC	FH-121207-62	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/12/2007	Scaffold	360	G7L140216007	12/14/2007	12/26/2007	TO-4	Aroclor 1232	<0.0021	12/27/2007	No	No	
STL-SAC	FH-121207-62	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/12/2007	Scaffold	360	G7L140216007	12/14/2007	12/26/2007	TO-4	Aroclor 1242	<0.0021	12/27/2007	No	No	
STL-SAC	FH-121207-62	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/12/2007	Scaffold	360	G7L140216007	12/14/2007	12/26/2007	TO-4	Aroclor 1248	<0.0021	12/27/2007	No	No	
STL-SAC	FH-121207-62	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/12/2007	Scaffold	360	G7L140216007	12/14/2007	12/26/2007	TO-4	Aroclor 1254	<0.0021	12/27/2007	No	No	
STL-SAC	FH-121207-62	#7 - 5TH FL SCAFFOLD AT SE CORNER	12/12/2007	Scaffold	360	G7L140216007	12/14/2007	12/26/2007	TO-4	Aroclor 1260	<0.0021	12/27/2007	No	No	