

Submittal Summary - Remediation Phase Week 51 (04/14/08 to 04/20/08)

| Lab Name | Airtek Field Sample No. | Sample Location | Collection Start Date | Work Shift/Project Phase | Sample Volume (m ³) | Lab Sample ID | Date Received | Date Analyzed | Analytical Method | Parameter Name | Asbestos PCME Concentration (f/cm ³) | Date Reported | Exceeds Target Air Quality Levels? | Exceeds EPA Site Specific Trigger Levels? | Comments |
|----------------------------------|-------------------------|--------------------------------------|-----------------------|--------------------------|---------------------------------|----------------|---------------|---------------|-------------------|----------------|--|---------------|------------------------------------|---|----------|
| Target Air Quality Levels | | | | | | | | | | | | | | | |
| EPA Site Specific Trigger Levels | | | | | | | | | | | | | | | |
| | | | | | | | | | | | 0.0009 | | | | |
| EMSL | 2 FH-041408-01 | #1 - SIDEWALK BRIDGE LEVEL NW CORNER | 4/14/2008 | 2/Remediation | 3.234 | 030810853-0001 | 4/15/2008 | 4/15/2008 | PCME | ASBESTOS | <0.00076 | 4/15/2008 | No | No | |
| EMSL | 2 FH-041408-02 | #2 - SIDEWALK BRIDGE LEVEL SW CORNER | 4/14/2008 | 2/Remediation | 3.228 | 030810853-0002 | 4/15/2008 | 4/15/2008 | PCME | ASBESTOS | <0.00076 | 4/15/2008 | No | No | |
| EMSL | 2 FH-041408-03 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 4/14/2008 | 2/Remediation | 3.228 | 030810853-0003 | 4/15/2008 | 4/15/2008 | PCME | ASBESTOS | <0.00076 | 4/15/2008 | No | No | |
| EMSL | 2 FH-041408-04 | #4 - SIDEWALK BRIDGE LEVEL NE CORNER | 4/14/2008 | 2/Remediation | 3.228 | 030810853-0004 | 4/15/2008 | 4/15/2008 | PCME | ASBESTOS | <0.00076 | 4/15/2008 | No | No | |
| EMSL | 2 FH-041408-05 | #5 - 5TH FLOOR SETBACK ROOF N SIDE | 4/14/2008 | 2/Remediation | 3.240 | 030810853-0005 | 4/15/2008 | 4/15/2008 | PCME | ASBESTOS | <0.00076 | 4/15/2008 | No | No | |
| EMSL | 2 FH-041408-06 | #6 - 5TH FLOOR SETBACK ROOF SW SIDE | 4/14/2008 | 2/Remediation | 3.234 | 030810853-0006 | 4/15/2008 | 4/15/2008 | PCME | ASBESTOS | <0.00076 | 4/15/2008 | No | No | |
| EMSL | 2 FH-041408-07 | #7 - 5TH FLOOR SCAFFOLD AT SE CORNER | 4/14/2008 | 2/Remediation | 3.228 | 030810853-0007 | 4/15/2008 | 4/15/2008 | PCME | ASBESTOS | <0.00076 | 4/15/2008 | No | No | |
| EMSL | 2 FH-041408-08 | #8 - 5TH FLOOR SCAFFOLD AT NE CORNER | 4/14/2008 | 2/Remediation | 3.234 | 030810853-0008 | 4/15/2008 | 4/15/2008 | PCME | ASBESTOS | <0.00076 | 4/15/2008 | No | No | |
| EMSL | 2 FH-041508-01 | #1 - SIDEWALK BRIDGE LEVEL NW CORNER | 4/15/2008 | 2/Remediation | 3.240 | 030811012-0001 | 4/16/2008 | 4/16/2008 | PCME | ASBESTOS | <0.00083 | 4/17/2008 | No | No | |
| EMSL | 2 FH-041508-02 | #2 - SIDEWALK BRIDGE LEVEL SW CORNER | 4/15/2008 | 2/Remediation | 3.234 | 030811012-0002 | 4/16/2008 | 4/16/2008 | PCME | ASBESTOS | <0.00083 | 4/17/2008 | No | No | |
| EMSL | 2 FH-041508-03 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 4/15/2008 | 2/Remediation | 3.216 | 030811012-0003 | 4/16/2008 | 4/16/2008 | PCME | ASBESTOS | <0.00084 | 4/17/2008 | No | No | |
| EMSL | 2 FH-041508-04 | #4 - SIDEWALK BRIDGE LEVEL NE CORNER | 4/15/2008 | 2/Remediation | 3.216 | 030811012-0004 | 4/16/2008 | 4/16/2008 | PCME | ASBESTOS | <0.00084 | 4/17/2008 | No | No | |
| EMSL | 2 FH-041508-05 | #5 - 5TH FLOOR SETBACK ROOF N SIDE | 4/15/2008 | 2/Remediation | 3.216 | 030811012-0005 | 4/16/2008 | 4/16/2008 | PCME | ASBESTOS | <0.00084 | 4/17/2008 | No | No | |
| EMSL | 2 FH-041508-06 | #6 - 5TH FLOOR SETBACK ROOF SW SIDE | 4/15/2008 | 2/Remediation | 3.210 | 030811012-0006 | 4/16/2008 | 4/16/2008 | PCME | ASBESTOS | <0.00084 | 4/17/2008 | No | No | |
| EMSL | 2 FH-041508-07 | #7 - 5TH FLOOR SCAFFOLD AT SE CORNER | 4/15/2008 | 2/Remediation | 3.222 | 030811012-0007 | 4/16/2008 | 4/16/2008 | PCME | ASBESTOS | <0.00084 | 4/17/2008 | No | No | |
| EMSL | 2 FH-041508-08 | #8 - 5TH FLOOR SCAFFOLD AT NE CORNER | 4/15/2008 | 2/Remediation | 3.228 | 030811012-0008 | 4/16/2008 | 4/16/2008 | PCME | ASBESTOS | <0.00083 | 4/17/2008 | No | No | |
| EMSL | 2 FH-041508-65 | DUPLICATE (STATION #1) | 4/15/2008 | 2/Remediation | 3.240 | 030811012-0009 | 4/16/2008 | 4/16/2008 | PCME | ASBESTOS | <0.00083 | 4/17/2008 | No | No | |
| EMSL | 2 FH-041608-01 | #1 - SIDEWALK BRIDGE LEVEL NW CORNER | 4/16/2008 | 2/Remediation | 3.258 | 030811206-0001 | 4/17/2008 | 4/18/2008 | PCME | ASBESTOS | <0.00083 | 4/18/2008 | No | No | |
| EMSL | 2 FH-041608-02 | #2 - SIDEWALK BRIDGE LEVEL SW CORNER | 4/16/2008 | 2/Remediation | 3.252 | 030811206-0002 | 4/17/2008 | 4/18/2008 | PCME | ASBESTOS | <0.00083 | 4/18/2008 | No | No | |
| EMSL | 2 FH-041608-03 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 4/16/2008 | 2/Remediation | 3.240 | 030811206-0003 | 4/17/2008 | 4/18/2008 | PCME | ASBESTOS | <0.00083 | 4/18/2008 | No | No | |
| EMSL | 2 FH-041608-04 | #4 - SIDEWALK BRIDGE LEVEL NE CORNER | 4/16/2008 | 2/Remediation | 3.234 | 030811206-0004 | 4/17/2008 | 4/18/2008 | PCME | ASBESTOS | <0.00083 | 4/18/2008 | No | No | |
| EMSL | 2 FH-041608-05 | #5 - 5TH FLOOR SETBACK ROOF N SIDE | 4/16/2008 | 2/Remediation | 3.246 | 030811206-0005 | 4/17/2008 | 4/18/2008 | PCME | ASBESTOS | <0.00083 | 4/18/2008 | No | No | |
| EMSL | 2 FH-041608-06 | #6 - 5TH FLOOR SETBACK ROOF SW SIDE | 4/16/2008 | 2/Remediation | 3.240 | 030811206-0006 | 4/17/2008 | 4/18/2008 | PCME | ASBESTOS | <0.00083 | 4/18/2008 | No | No | |
| EMSL | 2 FH-041608-07 | #7 - 5TH FLOOR SCAFFOLD AT SE CORNER | 4/16/2008 | 2/Remediation | 3.246 | 030811206-0007 | 4/17/2008 | 4/18/2008 | PCME | ASBESTOS | <0.00083 | 4/18/2008 | No | No | |
| EMSL | 2 FH-041608-08 | #8 - 5TH FLOOR SCAFFOLD AT NE CORNER | 4/16/2008 | 2/Remediation | 3.240 | 030811206-0008 | 4/17/2008 | 4/18/2008 | PCME | ASBESTOS | <0.00083 | 4/18/2008 | No | No | |
| EMSL | 2 FH-041708-01 | #1 - SIDEWALK BRIDGE LEVEL NW CORNER | 4/17/2008 | 2/Remediation | 3.240 | 030811321-0001 | 4/18/2008 | 4/18/2008 | PCME | ASBESTOS | <0.00083 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041708-02 | #2 - SIDEWALK BRIDGE LEVEL SW CORNER | 4/17/2008 | 2/Remediation | 3.246 | 030811321-0002 | 4/18/2008 | 4/18/2008 | PCME | ASBESTOS | <0.00083 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041708-03 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 4/17/2008 | 2/Remediation | 3.240 | 030811321-0003 | 4/18/2008 | 4/18/2008 | PCME | ASBESTOS | <0.00083 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041708-04 | #4 - SIDEWALK BRIDGE LEVEL NE CORNER | 4/17/2008 | 2/Remediation | 3.240 | 030811321-0004 | 4/18/2008 | 4/18/2008 | PCME | ASBESTOS | <0.00083 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041708-05 | #5 - 5TH FLOOR SETBACK ROOF N SIDE | 4/17/2008 | 2/Remediation | 3.246 | 030811321-0005 | 4/18/2008 | 4/18/2008 | PCME | ASBESTOS | <0.00083 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041708-06 | #6 - 5TH FLOOR SETBACK ROOF SW SIDE | 4/17/2008 | 2/Remediation | 3.240 | 030811321-0006 | 4/18/2008 | 4/18/2008 | PCME | ASBESTOS | <0.00083 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041708-07 | #7 - 5TH FLOOR SCAFFOLD AT SE CORNER | 4/17/2008 | 2/Remediation | 3.240 | 030811321-0007 | 4/18/2008 | 4/18/2008 | PCME | ASBESTOS | <0.00083 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041708-08 | #8 - 5TH FLOOR SCAFFOLD AT NE CORNER | 4/17/2008 | 2/Remediation | 3.240 | 030811321-0008 | 4/18/2008 | 4/18/2008 | PCME | ASBESTOS | <0.00083 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041808-01 | #1 - SIDEWALK BRIDGE LEVEL NW CORNER | 4/18/2008 | 2/Remediation | 3.246 | 030811476-0001 | 4/19/2008 | 4/20/2008 | PCME | ASBESTOS | <0.00083 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041808-02 | #2 - SIDEWALK BRIDGE LEVEL SW CORNER | 4/18/2008 | 2/Remediation | 3.246 | 030811476-0002 | 4/19/2008 | 4/20/2008 | PCME | ASBESTOS | <0.00083 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041808-03 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 4/18/2008 | 2/Remediation | 3.240 | 030811476-0003 | 4/19/2008 | 4/20/2008 | PCME | ASBESTOS | <0.00083 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041808-04 | #4 - SIDEWALK BRIDGE LEVEL NE CORNER | 4/18/2008 | 2/Remediation | 3.246 | 030811476-0004 | 4/19/2008 | 4/20/2008 | PCME | ASBESTOS | <0.00083 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041808-05 | #5 - 5TH FLOOR SETBACK ROOF N SIDE | 4/18/2008 | 2/Remediation | 3.246 | 030811476-0005 | 4/19/2008 | 4/20/2008 | PCME | ASBESTOS | <0.00083 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041808-06 | #6 - 5TH FLOOR SETBACK ROOF SW SIDE | 4/18/2008 | 2/Remediation | 3.246 | 030811476-0006 | 4/19/2008 | 4/20/2008 | PCME | ASBESTOS | <0.00083 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041808-07 | #7 - 5TH FLOOR SCAFFOLD AT SE CORNER | 4/18/2008 | 2/Remediation | 3.246 | 030811476-0007 | 4/19/2008 | 4/20/2008 | PCME | ASBESTOS | <0.00083 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041808-08 | #8 - 5TH FLOOR SCAFFOLD AT NE CORNER | 4/18/2008 | 2/Remediation | 3.246 | 030811476-0008 | 4/19/2008 | 4/20/2008 | PCME | ASBESTOS | <0.00083 | 4/20/2008 | No | No | |

Submittal Summary - Remediation Phase Week 51 (04/14/08 to 04/20/08)

| Lab Name | Airtek Field Sample No. | Sample Location | Collection Start Date | Work Shift/Project Phase | Sample Volume (m ³) | Lab Sample ID | Date Received | Date Analyzed | Analytical Method | Parameter Name | Asbestos AHERA Concentration (S/mm ²) | Date Reported | Exceeds Target Air Quality Levels? | Exceeds EPA Site Specific Trigger Levels? | Comments |
|---|-------------------------|--------------------------------------|-----------------------|--------------------------|---------------------------------|----------------|---------------|---------------|---------------------------------|----------------|---|---------------|------------------------------------|---|----------|
| Target Air Quality Levels | | | | | | | | | | | N/A | | | | |
| EPA Site Specific Trigger Levels | | | | | | | | | | | 70 | | | | |
| EMSL | 2 FH-041408-01 | #1 - SIDEWALK BRIDGE LEVEL NW CORNER | 4/14/2008 | 2/Remediation | 3.234 | 030810853-0001 | 4/15/2008 | 4/15/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <13.00 | 4/15/2008 | No | No | |
| EMSL | 2 FH-041408-02 | #2 - SIDEWALK BRIDGE LEVEL SW CORNER | 4/14/2008 | 2/Remediation | 3.228 | 030810853-0002 | 4/15/2008 | 4/15/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <13.00 | 4/15/2008 | No | No | |
| EMSL | 2 FH-041408-03 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 4/14/2008 | 2/Remediation | 3.228 | 030810853-0003 | 4/15/2008 | 4/15/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <13.00 | 4/15/2008 | No | No | |
| EMSL | 2 FH-041408-04 | #4 - SIDEWALK BRIDGE LEVEL NE CORNER | 4/14/2008 | 2/Remediation | 3.228 | 030810853-0004 | 4/15/2008 | 4/15/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <13.00 | 4/15/2008 | No | No | |
| EMSL | 2 FH-041408-05 | #5 - 5TH FLOOR SETBACK ROOF N SIDE | 4/14/2008 | 2/Remediation | 3.240 | 030810853-0005 | 4/15/2008 | 4/15/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <13.00 | 4/15/2008 | No | No | |
| EMSL | 2 FH-041408-06 | #6 - 5TH FLOOR SETBACK ROOF SW SIDE | 4/14/2008 | 2/Remediation | 3.234 | 030810853-0006 | 4/15/2008 | 4/15/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <13.00 | 4/15/2008 | No | No | |
| EMSL | 2 FH-041408-07 | #7 - 5TH FLOOR SCAFFOLD AT SE CORNER | 4/14/2008 | 2/Remediation | 3.228 | 030810853-0007 | 4/15/2008 | 4/15/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <13.00 | 4/15/2008 | No | No | |
| EMSL | 2 FH-041408-08 | #8 - 5TH FLOOR SCAFFOLD AT NE CORNER | 4/14/2008 | 2/Remediation | 3.234 | 030810853-0008 | 4/15/2008 | 4/15/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <13.00 | 4/15/2008 | No | No | |
| EMSL | 2 FH-041508-01 | #1 - SIDEWALK BRIDGE LEVEL NW CORNER | 4/15/2008 | 2/Remediation | 3.240 | 030811012-0001 | 4/16/2008 | 4/16/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/17/2008 | No | No | |
| EMSL | 2 FH-041508-02 | #2 - SIDEWALK BRIDGE LEVEL SW CORNER | 4/15/2008 | 2/Remediation | 3.234 | 030811012-0002 | 4/16/2008 | 4/16/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/17/2008 | No | No | |
| EMSL | 2 FH-041508-03 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 4/15/2008 | 2/Remediation | 3.216 | 030811012-0003 | 4/16/2008 | 4/16/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/17/2008 | No | No | |
| EMSL | 2 FH-041508-04 | #4 - SIDEWALK BRIDGE LEVEL NE CORNER | 4/15/2008 | 2/Remediation | 3.216 | 030811012-0004 | 4/16/2008 | 4/16/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/17/2008 | No | No | |
| EMSL | 2 FH-041508-05 | #5 - 5TH FLOOR SETBACK ROOF N SIDE | 4/15/2008 | 2/Remediation | 3.216 | 030811012-0005 | 4/16/2008 | 4/16/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/17/2008 | No | No | |
| EMSL | 2 FH-041508-06 | #6 - 5TH FLOOR SETBACK ROOF SW SIDE | 4/15/2008 | 2/Remediation | 3.210 | 030811012-0006 | 4/16/2008 | 4/16/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/17/2008 | No | No | |
| EMSL | 2 FH-041508-07 | #7 - 5TH FLOOR SCAFFOLD AT SE CORNER | 4/15/2008 | 2/Remediation | 3.222 | 030811012-0007 | 4/16/2008 | 4/16/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/17/2008 | No | No | |
| EMSL | 2 FH-041508-08 | #8 - 5TH FLOOR SCAFFOLD AT NE CORNER | 4/15/2008 | 2/Remediation | 3.228 | 030811012-0008 | 4/16/2008 | 4/16/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/17/2008 | No | No | |
| EMSL | 2 FH-041508-05 | DUPLICATE (STATION #1) | 4/15/2008 | 2/Remediation | 3.240 | 030811012-0009 | 4/16/2008 | 4/16/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/17/2008 | No | No | |
| EMSL | 2 FH-041608-01 | #1 - SIDEWALK BRIDGE LEVEL NW CORNER | 4/16/2008 | 2/Remediation | 3.258 | 030811206-0001 | 4/17/2008 | 4/18/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/18/2008 | No | No | |
| EMSL | 2 FH-041608-02 | #2 - SIDEWALK BRIDGE LEVEL SW CORNER | 4/16/2008 | 2/Remediation | 3.252 | 030811206-0002 | 4/17/2008 | 4/18/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/18/2008 | No | No | |
| EMSL | 2 FH-041608-03 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 4/16/2008 | 2/Remediation | 3.240 | 030811206-0003 | 4/17/2008 | 4/18/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/18/2008 | No | No | |
| EMSL | 2 FH-041608-04 | #4 - SIDEWALK BRIDGE LEVEL NE CORNER | 4/16/2008 | 2/Remediation | 3.234 | 030811206-0004 | 4/17/2008 | 4/18/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/18/2008 | No | No | |
| EMSL | 2 FH-041608-05 | #5 - 5TH FLOOR SETBACK ROOF N SIDE | 4/16/2008 | 2/Remediation | 3.246 | 030811206-0005 | 4/17/2008 | 4/18/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/18/2008 | No | No | |
| EMSL | 2 FH-041608-06 | #6 - 5TH FLOOR SETBACK ROOF SW SIDE | 4/16/2008 | 2/Remediation | 3.240 | 030811206-0006 | 4/17/2008 | 4/18/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/18/2008 | No | No | |
| EMSL | 2 FH-041608-07 | #7 - 5TH FLOOR SCAFFOLD AT SE CORNER | 4/16/2008 | 2/Remediation | 3.246 | 030811206-0007 | 4/17/2008 | 4/18/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/18/2008 | No | No | |
| EMSL | 2 FH-041608-08 | #8 - 5TH FLOOR SCAFFOLD AT NE CORNER | 4/16/2008 | 2/Remediation | 3.240 | 030811206-0008 | 4/17/2008 | 4/18/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/18/2008 | No | No | |
| EMSL | 2 FH-041708-01 | #1 - SIDEWALK BRIDGE LEVEL NW CORNER | 4/17/2008 | 2/Remediation | 3.240 | 030811321-0001 | 4/18/2008 | 4/18/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041708-02 | #2 - SIDEWALK BRIDGE LEVEL SW CORNER | 4/17/2008 | 2/Remediation | 3.246 | 030811321-0002 | 4/18/2008 | 4/18/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041708-03 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 4/17/2008 | 2/Remediation | 3.240 | 030811321-0003 | 4/18/2008 | 4/18/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | 15.00 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041708-04 | #4 - SIDEWALK BRIDGE LEVEL NE CORNER | 4/17/2008 | 2/Remediation | 3.240 | 030811321-0004 | 4/18/2008 | 4/18/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041708-05 | #5 - 5TH FLOOR SETBACK ROOF N SIDE | 4/17/2008 | 2/Remediation | 3.246 | 030811321-0005 | 4/18/2008 | 4/18/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041708-06 | #6 - 5TH FLOOR SETBACK ROOF SW SIDE | 4/17/2008 | 2/Remediation | 3.240 | 030811321-0006 | 4/18/2008 | 4/18/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041708-07 | #7 - 5TH FLOOR SCAFFOLD AT SE CORNER | 4/17/2008 | 2/Remediation | 3.240 | 030811321-0007 | 4/18/2008 | 4/18/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041708-08 | #8 - 5TH FLOOR SCAFFOLD AT NE CORNER | 4/17/2008 | 2/Remediation | 3.240 | 030811321-0008 | 4/18/2008 | 4/18/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041808-01 | #1 - SIDEWALK BRIDGE LEVEL NW CORNER | 4/18/2008 | 2/Remediation | 3.246 | 030811476-0001 | 4/19/2008 | 4/20/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041808-02 | #2 - SIDEWALK BRIDGE LEVEL SW CORNER | 4/18/2008 | 2/Remediation | 3.246 | 030811476-0002 | 4/19/2008 | 4/20/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041808-03 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 4/18/2008 | 2/Remediation | 3.240 | 030811476-0003 | 4/19/2008 | 4/20/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041808-04 | #4 - SIDEWALK BRIDGE LEVEL NE CORNER | 4/18/2008 | 2/Remediation | 3.246 | 030811476-0004 | 4/19/2008 | 4/20/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041808-05 | #5 - 5TH FLOOR SETBACK ROOF N SIDE | 4/18/2008 | 2/Remediation | 3.246 | 030811476-0005 | 4/19/2008 | 4/20/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041808-06 | #6 - 5TH FLOOR SETBACK ROOF SW SIDE | 4/18/2008 | 2/Remediation | 3.246 | 030811476-0006 | 4/19/2008 | 4/20/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041808-07 | #7 - 5TH FLOOR SCAFFOLD AT SE CORNER | 4/18/2008 | 2/Remediation | 3.246 | 030811476-0007 | 4/19/2008 | 4/20/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/20/2008 | No | No | |
| EMSL | 2 FH-041808-08 | #8 - 5TH FLOOR SCAFFOLD AT NE CORNER | 4/18/2008 | 2/Remediation | 3.246 | 030811476-0008 | 4/19/2008 | 4/20/2008 | TEM EPA 40 CFR PART 763 (AHERA) | ASBESTOS | <15.00 | 4/20/2008 | No | No | |

Submittal Summary - Remediation Phase Week 51 (04/14/08 to 04/20/08)

Ohio Lumex Daily Mercury Readings
all readings are in ng/m³

Target air quality level: 300 ng/m³

USEPA site specific mercury trigger level: 3000 ng/m³

Exceedances: None
Exceedances: None

3 Site Tours Conducted per Work Shift

DATE: 4/14/2008

| AREA: | TIME: | Tour #: | TOUR AVERAGE: | | | | | | | | | | | | |
|-----------------------|-----------|---------|---------------|----|----|----|----|----|----|----|----|----|----|----|-------|
| PERIMETER OF BUILDING | 0900-0905 | Tour 1 | 13 | 14 | 14 | 13 | 11 | 10 | 11 | 12 | 14 | 10 | 12 | 11 | 12.09 |
| | 1200-1205 | Tour 2 | 10 | 11 | 9 | 10 | 15 | 12 | 14 | 15 | 13 | 11 | 10 | 11 | 11.67 |
| | 1500-1505 | Tour 3 | 15 | 15 | 14 | 15 | 13 | 10 | 13 | 14 | 14 | 12 | 10 | 15 | 13.33 |
| 5th FLOOR | 0910-0915 | Tour 1 | 12 | 14 | 10 | 8 | 14 | 12 | 12 | 10 | 10 | 10 | 14 | 8 | 11.17 |
| | 1210-1215 | Tour 2 | 15 | 13 | 9 | 13 | 12 | 11 | 11 | 12 | 14 | 10 | 11 | 15 | 12.17 |
| | 1510-1515 | Tour 3 | 12 | 12 | 13 | 9 | 12 | 8 | 15 | 14 | 12 | 10 | 12 | 11 | 11.67 |
| ROOF PERIMETER | 0925-0930 | Tour 1 | 17 | 11 | 9 | 15 | 15 | 13 | 14 | 16 | 9 | 10 | 13 | 12 | 12.83 |
| | 1225-1230 | Tour 2 | 8 | 10 | 10 | 17 | 15 | 13 | 15 | 14 | 14 | 10 | 15 | 17 | 13.17 |
| | 1525-1530 | Tour 3 | 18 | 17 | 17 | 10 | 15 | 14 | 14 | 12 | 11 | 11 | 13 | 14 | 13.53 |

DATE: 4/14/2008 2nd SHIFT

| AREA: | TIME: | Tour #: | TOUR AVERAGE: | | | | | | | | | | | | |
|-----------------------|-----------|---------|---------------|----|----|----|----|----|----|----|----|----|----|----|-------|
| PERIMETER OF BUILDING | 1700-1705 | Tour 1 | 11 | 11 | 10 | 10 | 10 | 12 | 12 | 13 | 10 | 10 | 11 | 11 | 10.32 |
| | 2000-2005 | Tour 2 | 9 | 10 | 10 | 10 | 9 | 9 | 8 | 9 | 8 | 8 | 8 | 10 | 9.00 |
| | 2300-2305 | Tour 3 | 9 | 8 | 8 | 8 | 9 | 10 | 9 | 9 | 10 | 11 | 10 | 10 | 9.25 |
| 5th FLOOR | 1710-1715 | Tour 1 | 12 | 12 | 12 | 10 | 10 | 11 | 11 | 12 | 11 | 12 | 12 | 12 | 11.25 |
| | 2010-2015 | Tour 2 | 8 | 8 | 9 | 9 | 8 | 10 | 10 | 10 | 9 | 11 | 11 | 9 | 9.33 |
| | 2310-2315 | Tour 3 | 10 | 9 | 10 | 10 | 8 | 8 | 8 | 10 | 11 | 11 | 8 | 9 | 17.58 |
| ROOF PERIMETER | 1725-1730 | Tour 1 | 11 | 11 | 11 | 12 | 11 | 13 | 14 | 13 | 12 | 13 | 13 | 11 | 12.08 |
| | 2025-2030 | Tour 2 | 10 | 9 | 9 | 8 | 8 | 10 | 10 | 9 | 11 | 11 | 9 | 10 | 9.50 |
| | 0025-0030 | Tour 3 | 10 | 11 | 10 | 9 | 9 | 10 | 9 | 9 | 8 | 10 | 10 | 10 | 9.58 |

DATE: 4/15/2008

| AREA: | TIME: | Tour #: | TOUR AVERAGE: | | | | | | | | | | | | |
|-----------------------|-----------|---------|---------------|----|----|----|----|----|----|----|----|----|----|----|-------|
| PERIMETER OF BUILDING | 0900-0905 | Tour 1 | 10 | 16 | 13 | 8 | 10 | 11 | 12 | 11 | 11 | 14 | 7 | 9 | 11.00 |
| | 1200-1205 | Tour 2 | 13 | 13 | 9 | 11 | 12 | 8 | 11 | 11 | 10 | 10 | 9 | 11 | 10.67 |
| | 1500-1505 | Tour 3 | 14 | 14 | 9 | 11 | 12 | 9 | 13 | 10 | 7 | 10 | 10 | 9 | 10.67 |
| 5th FLOOR | 0910-0915 | Tour 1 | 10 | 11 | 12 | 12 | 16 | 10 | 10 | 9 | 10 | 9 | 8 | 11 | 10.67 |
| | 1210-1215 | Tour 2 | 11 | 12 | 12 | 10 | 9 | 8 | 11 | 11 | 12 | 13 | 14 | 10 | 11.08 |
| | 1510-1515 | Tour 3 | 10 | 11 | 11 | 12 | 12 | 13 | 14 | 9 | 8 | 8 | 9 | 10 | 10.58 |
| ROOF PERIMETER | 0925-0930 | Tour 1 | 9 | 8 | 9 | 10 | 11 | 11 | 12 | 13 | 9 | 8 | 8 | 10 | 9.83 |
| | 1225-1230 | Tour 2 | 11 | 11 | 11 | 11 | 11 | 12 | 14 | 12 | 11 | 10 | 9 | 12 | 11.50 |
| | 1525-1530 | Tour 3 | 9 | 8 | 8 | 8 | 9 | 11 | 11 | 14 | 16 | 13 | 10 | 9 | 10.50 |

DATE: 4/15/2008 2nd SHIFT

| AREA: | TIME: | Tour #: | TOUR AVERAGE: | | | | | | | | | | | | |
|-----------------------|-----------|---------|---------------|----|----|----|----|----|----|----|----|----|----|----|-------|
| PERIMETER OF BUILDING | 1700-1705 | Tour 1 | 11 | 11 | 12 | 12 | 12 | 11 | 11 | 13 | 13 | 10 | 11 | 11 | 11.50 |
| | 2000-2005 | Tour 2 | 11 | 10 | 11 | 11 | 10 | 9 | 9 | 9 | 10 | 10 | 9 | 10 | 9.92 |
| | 2300-2305 | Tour 3 | 10 | 9 | 9 | 9 | 10 | 10 | 9 | 11 | 11 | 9 | 9 | 9 | 9.67 |
| 5th FLOOR | 1710-1715 | Tour 1 | 12 | 12 | 11 | 12 | 13 | 13 | 13 | 11 | 11 | 9 | 11 | 12 | 11.67 |
| | 2010-2015 | Tour 2 | 11 | 11 | 11 | 9 | 9 | 9 | 10 | 10 | 9 | 10 | 11 | 9 | 9.92 |
| | 2310-2315 | Tour 3 | 9 | 9 | 10 | 10 | 10 | 8 | 6 | 9 | 9 | 9 | 10 | 9 | 9.00 |
| ROOF PERIMETER | 1725-1730 | Tour 1 | 9 | 9 | 10 | 10 | 9 | 11 | 11 | 11 | 13 | 10 | 10 | 11 | 10.33 |
| | 2025-2030 | Tour 2 | 12 | 10 | 10 | 11 | 11 | 12 | 10 | 10 | 9 | 10 | 10 | 10 | 10.42 |
| | 0025-0030 | Tour 3 | 8 | 8 | 9 | 8 | 10 | 10 | 10 | 9 | 9 | 9 | 10 | 8 | 9.00 |

DATE: 4/16/2008

| AREA: | TIME: | Tour #: | TOUR AVERAGE: | | | | | | | | | | | | |
|-----------------------|-----------|---------|---------------|----|----|----|----|----|----|----|----|----|----|----|-------|
| PERIMETER OF BUILDING | 0900-0905 | Tour 1 | 9 | 8 | 10 | 11 | 9 | 12 | 11 | 16 | 10 | 9 | 11 | 11 | 10.75 |
| | 1200-1205 | Tour 2 | 12 | 13 | 8 | 13 | 11 | 10 | 9 | 10 | 11 | 11 | 9 | 12 | 10.75 |
| | 1500-1505 | Tour 3 | 11 | 12 | 12 | 11 | 11 | 11 | 13 | 13 | 12 | 14 | 13 | 11 | 12.00 |
| 5th FLOOR | 0910-0915 | Tour 1 | 15 | 15 | 13 | 10 | 9 | 14 | 8 | 11 | 12 | 12 | 14 | 11 | 12.00 |
| | 1210-1215 | Tour 2 | 9 | 8 | 7 | 10 | 12 | 11 | 10 | 12 | 8 | 10 | 11 | 9 | 9.75 |
| | 1510-1515 | Tour 3 | 12 | 13 | 13 | 13 | 12 | 12 | 15 | 13 | 13 | 14 | 14 | 13 | 13.08 |
| ROOF PERIMETER | 0925-0930 | Tour 1 | 8 | 8 | 10 | 12 | 7 | 13 | 9 | 10 | 11 | 15 | 13 | 14 | 10.83 |
| | 1225-1230 | Tour 2 | 14 | 14 | 12 | 8 | 13 | 15 | 13 | 12 | 11 | 10 | 9 | 10 | 11.75 |
| | 1525-1530 | Tour 3 | 13 | 13 | 13 | 14 | 13 | 14 | 14 | 12 | 12 | 14 | 13 | 13 | 13.17 |

DATE: 4/16/2008 2nd SHIFT

| AREA: | TIME: | Tour #: | TOUR AVERAGE: | | | | | | | | | | | | |
|-----------------------|-----------|---------|---------------|----|----|----|----|----|----|----|----|----|----|----|-------|
| PERIMETER OF BUILDING | 1700-1705 | Tour 1 | 12 | 12 | 13 | 12 | 12 | 13 | 13 | 12 | 12 | 13 | 12 | 13 | 12.42 |
| | 2000-2005 | Tour 2 | 9 | 8 | 9 | 9 | 9 | 8 | 10 | 10 | 8 | 8 | 8 | 10 | 8.83 |
| | 2300-2305 | Tour 3 | 8 | 8 | 8 | 9 | 9 | 8 | 9 | 10 | 10 | 9 | 9 | 9 | 8.58 |
| 5th FLOOR | 1710-1715 | Tour 1 | 12 | 12 | 11 | 11 | 11 | 13 | 13 | 12 | 14 | 13 | 13 | 13 | 12.33 |
| | 2010-2015 | Tour 2 | 8 | 8 | 10 | 9 | 9 | 12 | 10 | 9 | 10 | 10 | 9 | 8 | 9.33 |
| | 2310-2315 | Tour 3 | 9 | 8 | 8 | 8 | 10 | 10 | 9 | 9 | 8 | 8 | 10 | 9 | 8.83 |
| ROOF PERIMETER | 1725-1730 | Tour 1 | 13 | 12 | 12 | 12 | 13 | 11 | 11 | 13 | 11 | 12 | 12 | 13 | 12.08 |
| | 2025-2030 | Tour 2 | 9 | 9 | 10 | 10 | 10 | 9 | 9 | 8 | 8 | 8 | 8 | 9 | 8.92 |
| | 0025-0030 | Tour 3 | 8 | 8 | 8 | 8 | 10 | 9 | 10 | 10 | 10 | 9 | 8 | 9 | 9.00 |

DATE: 4/17/2008

| AREA: | TIME: | Tour #: | TOUR AVERAGE: | | | | | | | | | | | | |
|-----------------------|-----------|---------|---------------|----|----|----|----|----|----|----|----|----|----|----|-------|
| PERIMETER OF BUILDING | 0900-0905 | Tour 1 | 8 | 8 | 10 | 12 | 10 | 9 | 9 | 10 | 11 | 11 | 10 | 9 | 9.75 |
| | 1200-1205 | Tour 2 | 12 | 13 | 10 | 8 | 12 | 12 | 8 | 11 | 10 | 9 | 12 | 11 | 10.67 |
| | 1500-1505 | Tour 3 | 12 | 12 | 12 | 9 | 10 | 12 | 11 | 11 | 11 | 11 | 9 | 10 | 10.83 |
| 5th FLOOR | 0910-0915 | Tour 1 | 11 | 11 | 18 | 11 | 12 | 12 | 10 | 11 | 12 | 11 | 10 | 10 | 11.58 |
| | 1210-1215 | Tour 2 | 14 | 11 | 15 | 10 | 9 | 10 | 8 | 11 | 12 | 13 | 14 | 15 | 11.83 |
| | 1510-1515 | Tour 3 | 13 | 13 | 12 | 11 | 13 | 12 | 10 | 9 | 10 | 10 | 11 | 12 | 11.33 |
| ROOF PERIMETER | 0925-0930 | Tour 1 | 15 | 15 | 13 | 14 | 8 | 11 | 15 | 14 | 10 | 10 | 11 | 13 | 12.42 |
| | 1225-1230 | Tour 2 | 10 | 15 | 11 | 15 | 14 | 14 | 11 | 14 | 13 | 15 | 11 | 9 | 13.17 |
| | 1525-1530 | Tour 3 | 15 | 15 | 15 | 14 | 14 | 13 | 13 | 13 | 11 | 9 | 12 | 12 | 13.00 |

DATE: 4/17/2008 2nd SHIFT

| AREA: | TIME: | Tour #: | TOUR AVERAGE: | | | | | | | | | | | | |
|-----------------------|-----------|---------|---------------|----|----|----|----|----|----|----|----|----|----|----|-------|
| PERIMETER OF BUILDING | 1700-1705 | Tour 1 | 14 | 14 | 14 | 13 | 15 | 14 | 14 | 15 | 15 | 14 | 13 | 14 | 14.08 |
| | 2000-2005 | Tour 2 | 13 | 14 | 14 | 14 | 14 | 14 | 13 | 13 | 14 | 14 | 14 | 14 | 13.58 |
| | 2300-2305 | Tour 3 | 12 | 13 | 12 | 12 | 13 | 14 | 14 | 12 | 11 | 12 | 12 | 11 | 12.33 |
| 5th FLOOR | 1710-1715 | Tour 1 | 14 | 15 | 14 | 14 | 14 | 12 | 13 | 14 | 13 | 13 | 15 | 15 | 13.83 |
| | 2010-2015 | Tour 2 | 13 | 14 | 14 | 14 | 12 | 13 | 13 | 13 | 13 | 14 | 13 | 13 | 13.17 |
| | 2310-2315 | Tour 3 | 12 | 12 | 12 | 12 | 11 | 11 | 10 | 10 | 11 | 11 | 11 | 13 | 11.33 |
| ROOF PERIMETER | 1725-1730 | Tour 1 | 13 | 13 | 14 | 13 | 15 | 14 | 14 | 15 | 14 | 14 | 12 | 14 | 13.75 |
| | 2025-2030 | Tour 2 | 14 | 13 | 14 | 13 | 13 | 13 | 15 | 15 | 15 | 13 | 13 | 14 | 13.75 |
| | 0025-0030 | Tour 3 | 11 | 11 | 0 | 11 | 10 | 10 | 11 | 12 | 11 | 11 | 9 | 10 | 9.25 |

DATE: 4/18/2008

| AREA: | TIME: | Tour #: | TOUR AVERAGE: | | | | | | | | | | | | |
|-----------------------|-----------|---------|---------------|----|----|----|----|----|----|----|----|----|----|----|-------|
| PERIMETER OF BUILDING | 0900-0905 | Tour 1 | 9 | 8 | 10 | 10 | 10 | 11 | 8 | 12 | 9 | 9 | 10 | 11 | 9.75 |
| | 1200-1205 | Tour 2 | 12 | 11 | 9 | 8 | 9 | 9 | 10 | 11 | 11 | 9 | 12 | 11 | 10.17 |
| | 1500-1505 | Tour 3 | 11 | 11 | 10 | 13 | 13 | 10 | 13 | 12 | 11 | 12 | 10 | 9 | 11.25 |
| 5th FLOOR | 0910-0915 | Tour 1 | 11 | 11 | 12 | 9 | 13 | 10 | 10 | 11 | 12 | 10 | 11 | 9 | 10.75 |
| | 1210-1215 | Tour 2 | 12 | 12 | 13 | 12 | 13 | 10 | 9 | 11 | 10 | 12 | 11 | 9 | 11.17 |
| | 1510-1515 | Tour 3 | 13 | 13 | 13 | 9 | 10 | 12 | 11 | 11 | 12 | 13 | 12 | 11 | 11.67 |
| ROOF PERIMETER | 0925-0930 | Tour 1 | 15 | 15 | 14 | 10 | 13 | 13 | 12 | 8 | 11 | 12 | 15 | 11 | 12.42 |
| | 1225-1230 | Tour 2 | 15 | 15 | 13 | 12 | 11 | 15 | 14 | 10 | 13 | 11 | 12 | 10 | 12.58 |
| | 1525-1530 | Tour 3 | 15 | 13 | 15 | 12 | 12 | 12 | 10 | 14 | 10 | 9 | 8 | 10 | 11.67 |

DATE: 4/18/2008 2nd SHIFT

| AREA: | TIME: | Tour #: | TOUR AVERAGE: | | | | | | | | | | | | |
|-----------------------|-----------|---------|---------------|----|----|----|----|----|----|----|----|----|----|----|-------|
| PERIMETER OF BUILDING | 1700-1705 | Tour 1 | 14 | 14 | 15 | 15 | 14 | 16 | 15 | 15 | 13 | 13 | 13 | 15 | 14.33 |
| | 2000-2005 | Tour 2 | 12 | 13 | | | | | | | | | | | |

Submittal Summary - Remediation Phase Week 51 (04/14/08 to 04/20/08)

| Lab Name | Field Sample ID | Sample Location | Date Collected | Project Phase | Sample Volume (mL) | Lab Sample ID | Date Received | Date Analyzed | Analytical Method | Antimony Concentration (ng/m ³) | Barium Concentration (ng/m ³) | Beryllium Concentration (ng/m ³) | Cadmium Concentration (ng/m ³) | Chromium (Total) Concentration (ng/m ³) | Copper Concentration (ng/m ³) | Lead Concentration (ng/m ³) | Manganese Concentration (ng/m ³) | Nickel Concentration (ng/m ³) | Zinc Concentration (ng/m ³) | Unit | Flag | Qualifier | Date Reported | Exceeds Target Air Quality Level? | Exceeds EPA Site Specific Trigger Level? | Comments | | | |
|----------------------------------|-----------------|--------------------------------------|----------------|---------------|--------------------|---------------|---------------|---------------|-------------------|---|---|--|--|---|---|---|--|---|---|------|-------------------|-------------------|-------------------|-----------------------------------|--|-----------|----|----|--|
| Target Air Quality Levels | | | | | | | | | | 5,000 | 5,000 | 20 | 50 | 100,000 | 1,000 | 1,000 | 500 | 10,000 | 16,000 | | | | | | | | | | |
| EPA Site Specific Trigger Levels | | | | | | | | | | 14,000 | 14,000 | 200 | 2,000 | 600 | 100,000 | 1,000 | 500 | 10,000 | 16,000 | | | | | | | | | | |
| STL-SAC | PH-041408-20 | #1 - SIDEWALK BRIDGE LEVEL NW CORNER | 4/14/2008 | Remediation | 5.776 | GBD160289001 | 4/16/2008 | 4/18/2008 | 6020 | -34.6 | -1730 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | ng/m ³ | | | 4/21/2008 | No | No | | | |
| STL-SAC | PH-041408-21 | #2 - SIDEWALK BRIDGE LEVEL SW CORNER | 4/14/2008 | Remediation | 5.620 | GBD160289002 | 4/16/2008 | 4/18/2008 | 6020 | -34.1 | -1730 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | ng/m ³ | | | 4/21/2008 | No | No | | |
| STL-SAC | PH-041408-22 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 4/14/2008 | Remediation | 5.728 | GBD160289003 | 4/16/2008 | 4/18/2008 | 6020 | -34.9 | -1740 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | ng/m ³ | | | 4/21/2008 | No | No | | |
| STL-SAC | PH-041408-23 | #4 - SIDEWALK BRIDGE LEVEL NE CORNER | 4/14/2008 | Remediation | 5.798 | GBD160289004 | 4/16/2008 | 4/18/2008 | 6020 | -34.9 | -1740 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | ng/m ³ | | | 4/21/2008 | No | No | | |
| STL-SAC | PH-041408-24 | #5 - 5TH FLOOR SETBACK ROOF N SIDE | 4/14/2008 | Remediation | 5.756 | GBD160289005 | 4/16/2008 | 4/18/2008 | 6020 | -34.7 | -1740 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | ng/m ³ | | | 4/21/2008 | No | No | | |
| STL-SAC | PH-041408-25 | #6 - 5TH FLOOR SETBACK ROOF SW SIDE | 4/14/2008 | Remediation | 5.748 | GBD160289006 | 4/16/2008 | 4/18/2008 | 6020 | -34.8 | -1740 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | ng/m ³ | | | 4/21/2008 | No | No | | |
| STL-SAC | PH-041408-26 | #7 - 5TH FLOOR SCAFFOLD AT SE CORNER | 4/14/2008 | Remediation | 5.772 | GBD160289007 | 4/16/2008 | 4/18/2008 | 6020 | -35.0 | -1750 | -175 | -175 | -175 | -175 | -175 | -175 | -175 | -175 | -175 | -175 | ng/m ³ | | | 4/21/2008 | No | No | | |
| STL-SAC | PH-041408-27 | #8 - 5TH FLOOR SCAFFOLD AT NE CORNER | 4/14/2008 | Remediation | 5.768 | GBD160289008 | 4/16/2008 | 4/18/2008 | 6020 | -34.7 | -1730 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | ng/m ³ | | | 4/21/2008 | No | No | | |
| STL-SAC | PH-041508-20 | #1 - SIDEWALK BRIDGE LEVEL NW CORNER | 4/15/2008 | Remediation | 5.784 | GBD170188001 | 4/17/2008 | 4/19/2008 | 6020 | -34.6 | -1730 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | ng/m ³ | | | 4/22/2008 | No | No | | |
| STL-SAC | PH-041508-21 | #2 - SIDEWALK BRIDGE LEVEL SW CORNER | 4/15/2008 | Remediation | 5.82 | GBD170188002 | 4/17/2008 | 4/19/2008 | 6020 | -34.4 | -1720 | -172 | -172 | -172 | -172 | -172 | -172 | -172 | -172 | -172 | -172 | ng/m ³ | | | 4/22/2008 | No | No | | |
| STL-SAC | PH-041508-22 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 4/15/2008 | Remediation | 5.8 | GBD170188003 | 4/17/2008 | 4/19/2008 | 6020 | -34.5 | -1720 | -172 | -172 | -172 | -172 | -172 | -172 | -172 | -172 | -172 | -172 | ng/m ³ | | | 4/22/2008 | No | No | | |
| STL-SAC | PH-041508-23 | #4 - SIDEWALK BRIDGE LEVEL NE CORNER | 4/15/2008 | Remediation | 5.796 | GBD170188004 | 4/17/2008 | 4/19/2008 | 6020 | -34.5 | -1720 | -172 | -172 | -172 | -172 | -172 | -172 | -172 | -172 | -172 | -172 | ng/m ³ | | | 4/22/2008 | No | No | | |
| STL-SAC | PH-041508-24 | #5 - 5TH FLOOR SETBACK ROOF N SIDE | 4/15/2008 | Remediation | 5.798 | GBD170188005 | 4/17/2008 | 4/19/2008 | 6020 | -34.6 | -1730 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | ng/m ³ | | | 4/22/2008 | No | No | | |
| STL-SAC | PH-041508-25 | #6 - 5TH FLOOR SETBACK ROOF SW SIDE | 4/15/2008 | Remediation | 5.796 | GBD170188006 | 4/17/2008 | 4/19/2008 | 6020 | -34.5 | -1720 | -172 | -172 | -172 | -172 | -172 | -172 | -172 | -172 | -172 | -172 | ng/m ³ | | | 4/22/2008 | No | No | | |
| STL-SAC | PH-041508-26 | #7 - 5TH FLOOR SCAFFOLD AT SE CORNER | 4/15/2008 | Remediation | 5.804 | GBD170188007 | 4/17/2008 | 4/19/2008 | 6020 | -34.4 | -1720 | -172 | -172 | -172 | -172 | -172 | -172 | -172 | -172 | -172 | -172 | ng/m ³ | | | 4/22/2008 | No | No | | |
| STL-SAC | PH-041508-27 | #8 - 5TH FLOOR SCAFFOLD AT NE CORNER | 4/15/2008 | Remediation | 5.784 | GBD170188008 | 4/17/2008 | 4/19/2008 | 6020 | -34.6 | -1730 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | ng/m ³ | | | 4/22/2008 | No | No | | |
| STL-SAC | PH-041508-67 | DUPLICATE (STATION #1) | 4/15/2008 | Remediation | 5.796 | GBD170188010 | 4/17/2008 | 4/19/2008 | 6020 | -34.5 | -1720 | -172 | -172 | -172 | -172 | -172 | -172 | -172 | -172 | -172 | -172 | ng/m ³ | | | 4/22/2008 | No | No | | |
| STL-SAC | PH-041608-20 | #1 - SIDEWALK BRIDGE LEVEL NW CORNER | 4/16/2008 | Remediation | 5.768 | GBD180187001 | 4/18/2008 | 4/21/2008 | 6020 | -34.7 | -1730 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | ng/m ³ | | | 4/23/2008 | No | No | | |
| STL-SAC | PH-041608-21 | #2 - SIDEWALK BRIDGE LEVEL SW CORNER | 4/16/2008 | Remediation | 5.744 | GBD180187002 | 4/18/2008 | 4/21/2008 | 6020 | -34.8 | -1740 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | ng/m ³ | | | 4/23/2008 | No | No | | |
| STL-SAC | PH-041608-22 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 4/16/2008 | Remediation | 5.764 | GBD180187003 | 4/18/2008 | 4/21/2008 | 6020 | -34.7 | -1730 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | ng/m ³ | | | 4/23/2008 | No | No | | |
| STL-SAC | PH-041608-23 | #4 - SIDEWALK BRIDGE LEVEL NE CORNER | 4/16/2008 | Remediation | 5.764 | GBD180187004 | 4/18/2008 | 4/21/2008 | 6020 | -34.7 | -1730 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | ng/m ³ | | | 4/23/2008 | No | No | | |
| STL-SAC | PH-041608-24 | #5 - 5TH FLOOR SETBACK ROOF N SIDE | 4/16/2008 | Remediation | 5.768 | GBD180187005 | 4/18/2008 | 4/21/2008 | 6020 | -34.7 | -1730 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | ng/m ³ | | | 4/23/2008 | No | No | | |
| STL-SAC | PH-041608-25 | #6 - 5TH FLOOR SETBACK ROOF SW SIDE | 4/16/2008 | Remediation | 5.764 | GBD180187006 | 4/18/2008 | 4/21/2008 | 6020 | -34.7 | -1730 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | ng/m ³ | | | 4/23/2008 | No | No | | |
| STL-SAC | PH-041608-26 | #7 - 5TH FLOOR SCAFFOLD AT SE CORNER | 4/16/2008 | Remediation | 5.752 | GBD180187007 | 4/18/2008 | 4/21/2008 | 6020 | -34.8 | -1740 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | ng/m ³ | | | 4/23/2008 | No | No | | |
| STL-SAC | PH-041608-27 | #8 - 5TH FLOOR SCAFFOLD AT NE CORNER | 4/16/2008 | Remediation | 5.768 | GBD180187008 | 4/18/2008 | 4/21/2008 | 6020 | -34.7 | -1730 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | ng/m ³ | | | 4/23/2008 | No | No | | |
| STL-SAC | PH-041708-20 | #1 - SIDEWALK BRIDGE LEVEL NW CORNER | 4/17/2008 | Remediation | 5.748 | GBD210149001 | 4/21/2008 | 4/23/2008 | 6020 | -34.8 | -1740 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | ng/m ³ | | | 4/24/2008 | No | No | | |
| STL-SAC | PH-041708-21 | #2 - SIDEWALK BRIDGE LEVEL SW CORNER | 4/17/2008 | Remediation | 5.772 | GBD210149002 | 4/21/2008 | 4/23/2008 | 6020 | -34.6 | -1730 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | ng/m ³ | | | 4/24/2008 | No | No | | |
| STL-SAC | PH-041708-22 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 4/17/2008 | Remediation | 5.752 | GBD210149003 | 4/21/2008 | 4/23/2008 | 6020 | -34.8 | -1740 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | ng/m ³ | | | 4/24/2008 | No | No | | |
| STL-SAC | PH-041708-23 | #4 - SIDEWALK BRIDGE LEVEL NE CORNER | 4/17/2008 | Remediation | 5.752 | GBD210149004 | 4/21/2008 | 4/23/2008 | 6020 | -34.8 | -1740 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | ng/m ³ | | | 4/24/2008 | No | No | | |
| STL-SAC | PH-041708-24 | #5 - 5TH FLOOR SETBACK ROOF N SIDE | 4/17/2008 | Remediation | 5.748 | GBD210149005 | 4/21/2008 | 4/23/2008 | 6020 | -34.8 | -1740 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | ng/m ³ | | | 4/24/2008 | No | No | | |
| STL-SAC | PH-041708-25 | #6 - 5TH FLOOR SETBACK ROOF SW SIDE | 4/17/2008 | Remediation | 5.748 | GBD210149006 | 4/21/2008 | 4/23/2008 | 6020 | -34.8 | -1740 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | ng/m ³ | | | 4/24/2008 | No | No | | |
| STL-SAC | PH-041708-26 | #7 - 5TH FLOOR SCAFFOLD AT SE CORNER | 4/17/2008 | Remediation | 5.76 | GBD210149007 | 4/21/2008 | 4/23/2008 | 6020 | -34.7 | -1740 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | ng/m ³ | | | 4/24/2008 | No | No | | |
| STL-SAC | PH-041708-27 | #8 - 5TH FLOOR SCAFFOLD AT NE CORNER | 4/17/2008 | Remediation | 5.748 | GBD210149008 | 4/21/2008 | 4/23/2008 | 6020 | -34.8 | -1740 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | -174 | ng/m ³ | | | 4/24/2008 | No | No | |
| STL-SAC | PH-041808-20 | #1 - SIDEWALK BRIDGE LEVEL NW CORNER | 4/18/2008 | Remediation | 5.764 | GBD230156001 | 4/23/2008 | 4/24/2008 | 6020 | -34.6 | -1730 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | ng/m ³ | | | 4/28/2008 | No | No | | |
| STL-SAC | PH-041808-21 | #2 - SIDEWALK BRIDGE LEVEL SW CORNER | 4/18/2008 | Remediation | 5.772 | GBD230156002 | 4/23/2008 | 4/24/2008 | 6020 | -34.7 | -1730 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | ng/m ³ | | | 4/28/2008 | No | No | | |
| STL-SAC | PH-041808-22 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 4/18/2008 | Remediation | 5.772 | GBD230156003 | 4/23/2008 | 4/24/2008 | 6020 | -34.6 | -1730 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | ng/m ³ | | | 4/28/2008 | No | No | | |
| STL-SAC | PH-041808-23 | #4 - SIDEWALK BRIDGE LEVEL NE CORNER | 4/18/2008 | Remediation | 5.776 | GBD230156004 | 4/23/2008 | 4/24/2008 | 6020 | -34.6 | -1730 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | -173 | ng/m ³ | | | 4/28/2008 | No | No | | |
| STL-SAC | PH-041808-24 | #5 - 5TH FLOOR SETBACK ROOF N SIDE | 4/18/2008 | Remediation | 5.772 | GBD230156005 | 4/23/2008 | | | | | | | | | | | | | | | | | | | | | | |

Submittal Summary - Remediation Phase Week 51 (04/14/08 to 04/20/08)

| Lab Name | Airtek Field Sample No. | Sample Location | Collection Start Date | Work Shift/Project Phase | Sample Volume (m ³) | Lab Sample ID | Date Received | Date Analyzed | Analytical Method | Parameter Name | Silica-Quartz Concentration (ug/m3) | Date Reported | Exceeds Target Air Quality Levels? | Exceeds EPA Site Specific Trigger Levels? | Comments |
|----------------------------------|-------------------------|--------------------------------------|-----------------------|--------------------------|---------------------------------|----------------|---------------|---------------|-------------------|----------------|-------------------------------------|---------------|------------------------------------|---|------------|
| Target Air Quality Levels | | | | | | | | | | | | 10 | | | |
| EPA Site Specific Trigger Levels | | | | | | | | | | | | 10 | | | |
| EMSL | FH-041408-29 | #1 - SIDEWALK BRIDGE LEVEL NW CORNER | 04/14/2008 | Remediation | 2.888 | 040808895-0001 | 04/16/2008 | 04/19/2008 | NIOSH 7500 XRD | Silica-Quartz | 2 | 04/21/2008 | No | No | |
| EMSL | FH-041408-30 | #2 - SIDEWALK BRIDGE LEVEL SW CORNER | 04/14/2008 | Remediation | 2.846 | 040808895-0002 | 04/16/2008 | 04/19/2008 | NIOSH 7500 XRD | Silica-Quartz | <2 | 04/21/2008 | No | No | |
| EMSL | FH-041408-31 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 04/14/2008 | Remediation | 2.864 | 040808895-0003 | 04/16/2008 | 04/19/2008 | NIOSH 7500 XRD | Silica-Quartz | <2 | 04/21/2008 | No | No | |
| EMSL | FH-041408-32 | #4 - SIDEWALK BRIDGE LEVEL NE CORNER | 04/14/2008 | Remediation | 2.868 | 040808895-0004 | 04/16/2008 | 04/19/2008 | NIOSH 7500 XRD | Silica-Quartz | 2 | 04/21/2008 | No | No | |
| EMSL | FH-041408-33 | #5 - 5TH FL SETBACK ROOF N. SIDE | 04/14/2008 | Remediation | 2.878 | 040808895-0005 | 04/16/2008 | 04/19/2008 | NIOSH 7500 XRD | Silica-Quartz | 3 | 04/21/2008 | No | No | |
| EMSL | FH-041408-34 | #6 - 5TH FL SETBACK ROOF SW SIDE | 04/14/2008 | Remediation | 2.844 | 040808895-0006 | 04/16/2008 | 04/19/2008 | NIOSH 7500 XRD | Silica-Quartz | <2 | 04/21/2008 | No | No | |
| EMSL | FH-041408-35 | #7 - 5TH FL SCAFFOLD AT SE CORNER | 04/14/2008 | Remediation | 2.860 | 040808895-0007 | 04/16/2008 | 04/19/2008 | NIOSH 7500 XRD | Silica-Quartz | <2 | 04/21/2008 | No | No | |
| EMSL | FH-041408-36 | #8 - 5TH FL SCAFFOLD AT NE CORNER | 04/14/2008 | Remediation | 2.884 | 040808895-0008 | 04/16/2008 | 04/19/2008 | NIOSH 7500 XRD | Silica-Quartz | 2 | 04/21/2008 | No | No | |
| EMSL | FH-041508-29 | #1 - SIDEWALK BRIDGE LEVEL NW CORNER | 04/15/2008 | Remediation | 2.892 | 040809007-0001 | 04/17/2008 | 04/19/2008 | NIOSH 7500 XRD | Silica-Quartz | <2 | 04/21/2008 | No | No | |
| EMSL | FH-041508-30 | #2 - SIDEWALK BRIDGE LEVEL SW CORNER | 04/15/2008 | Remediation | 2.910 | 040809007-0002 | 04/17/2008 | 04/19/2008 | NIOSH 7500 XRD | Silica-Quartz | <2 | 04/21/2008 | No | No | |
| EMSL | FH-041508-31 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 04/15/2008 | Remediation | 2.900 | 040809007-0003 | 04/17/2008 | 04/19/2008 | NIOSH 7500 XRD | Silica-Quartz | <2 | 04/21/2008 | No | No | |
| EMSL | FH-041508-32 | #4 - SIDEWALK BRIDGE LEVEL NE CORNER | 04/15/2008 | Remediation | 2.898 | 040809007-0004 | 04/17/2008 | 04/19/2008 | NIOSH 7500 XRD | Silica-Quartz | <2 | 04/21/2008 | No | No | |
| EMSL | FH-041508-33 | #5 - 5TH FL SETBACK ROOF N. SIDE | 04/15/2008 | Remediation | 2.894 | 040809007-0005 | 04/17/2008 | 04/19/2008 | NIOSH 7500 XRD | Silica-Quartz | 3 | 04/21/2008 | No | No | |
| EMSL | FH-041508-34 | #6 - 5TH FL SETBACK ROOF SW SIDE | 04/15/2008 | Remediation | 2.898 | 040809007-0006 | 04/17/2008 | 04/19/2008 | NIOSH 7500 XRD | Silica-Quartz | 2 | 04/21/2008 | No | No | |
| EMSL | FH-041508-35 | #7 - 5TH FL SCAFFOLD AT SE CORNER | 04/15/2008 | Remediation | 2.902 | 040809007-0007 | 04/17/2008 | 04/19/2008 | NIOSH 7500 XRD | Silica-Quartz | <2 | 04/21/2008 | No | No | |
| EMSL | FH-041508-36 | #8 - 5TH FL SCAFFOLD AT NE CORNER | 04/15/2008 | Remediation | 2.892 | 040809007-0008 | 04/17/2008 | 04/19/2008 | NIOSH 7500 XRD | Silica-Quartz | <2 | 04/21/2008 | No | No | |
| EMSL | FH-041508-68 | DUPLICATE (STATION #1) | 04/15/2008 | Remediation | 2.902 | 040809007-0010 | 04/17/2008 | 04/19/2008 | NIOSH 7500 XRD | Silica-Quartz | <2 | 04/21/2008 | No | No | |
| EMSL | FH-041608-29 | #1 - SIDEWALK BRIDGE LEVEL NW CORNER | 04/16/2008 | Remediation | 2.892 | 040809130-0001 | 04/18/2008 | 04/21/2008 | NIOSH 7500 XRD | Silica-Quartz | <2 | 04/21/2008 | No | No | |
| EMSL | FH-041608-30 | #2 - SIDEWALK BRIDGE LEVEL SW CORNER | 04/16/2008 | Remediation | 2.910 | 040809130-0002 | 04/18/2008 | 04/21/2008 | NIOSH 7500 XRD | Silica-Quartz | <2 | 04/21/2008 | No | No | |
| EMSL | FH-041608-31 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 04/16/2008 | Remediation | 2.900 | 040809130-0003 | 04/18/2008 | 04/21/2008 | NIOSH 7500 XRD | Silica-Quartz | 3 | 04/21/2008 | No | No | |
| EMSL | FH-041608-32 | #4 - SIDEWALK BRIDGE LEVEL NE CORNER | 04/16/2008 | Remediation | 2.898 | 040809130-0004 | 04/18/2008 | 04/21/2008 | NIOSH 7500 XRD | Silica-Quartz | <2 | 04/21/2008 | No | No | |
| EMSL | FH-041608-33 | #5 - 5TH FL SETBACK ROOF N. SIDE | 04/16/2008 | Remediation | 2.894 | 040809130-0005 | 04/18/2008 | 04/21/2008 | NIOSH 7500 XRD | Silica-Quartz | 2 | 04/21/2008 | No | No | |
| EMSL | FH-041608-34 | #6 - 5TH FL SETBACK ROOF SW SIDE | 04/16/2008 | Remediation | 2.898 | 040809130-0006 | 04/18/2008 | 04/21/2008 | NIOSH 7500 XRD | Silica-Quartz | <2 | 04/21/2008 | No | No | |
| EMSL | FH-041608-35 | #7 - 5TH FL SCAFFOLD AT SE CORNER | 04/16/2008 | Remediation | 2.902 | 040809130-0007 | 04/18/2008 | 04/21/2008 | NIOSH 7500 XRD | Silica-Quartz | <7 | 04/21/2008 | No | No | See Note 1 |
| EMSL | FH-041608-36 | #8 - 5TH FL SCAFFOLD AT NE CORNER | 04/16/2008 | Remediation | 2.892 | 040809130-0008 | 04/18/2008 | 04/21/2008 | NIOSH 7500 XRD | Silica-Quartz | 2 | 04/21/2008 | No | No | |
| EMSL | FH-041708-29 | #1 - SIDEWALK BRIDGE LEVEL NW CORNER | 04/17/2008 | Remediation | 2.874 | 040809249-0001 | 04/19/2008 | 04/21/2008 | NIOSH 7500 XRD | Silica-Quartz | <2 | 04/22/2008 | No | No | |
| EMSL | FH-041708-30 | #2 - SIDEWALK BRIDGE LEVEL SW CORNER | 04/17/2008 | Remediation | 2.884 | 040809249-0002 | 04/19/2008 | 04/21/2008 | NIOSH 7500 XRD | Silica-Quartz | <2 | 04/22/2008 | No | No | |
| EMSL | FH-041708-31 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 04/17/2008 | Remediation | 2.878 | 040809249-0003 | 04/19/2008 | 04/21/2008 | NIOSH 7500 XRD | Silica-Quartz | 8 | 04/22/2008 | No | No | |
| EMSL | FH-041708-32 | #4 - SIDEWALK BRIDGE LEVEL NE CORNER | 04/17/2008 | Remediation | 2.876 | 040809249-0004 | 04/19/2008 | 04/21/2008 | NIOSH 7500 XRD | Silica-Quartz | <2 | 04/22/2008 | No | No | |
| EMSL | FH-041708-33 | #5 - 5TH FL SETBACK ROOF N. SIDE | 04/17/2008 | Remediation | 2.874 | 040809249-0005 | 04/19/2008 | 04/21/2008 | NIOSH 7500 XRD | Silica-Quartz | 7 | 04/22/2008 | No | No | |
| EMSL | FH-041708-34 | #6 - 5TH FL SETBACK ROOF SW SIDE | 04/17/2008 | Remediation | 2.874 | 040809249-0006 | 04/19/2008 | 04/21/2008 | NIOSH 7500 XRD | Silica-Quartz | 2 | 04/22/2008 | No | No | |
| EMSL | FH-041708-35 | #7 - 5TH FL SCAFFOLD AT SE CORNER | 04/17/2008 | Remediation | 2.880 | 040809249-0007 | 04/19/2008 | 04/21/2008 | NIOSH 7500 XRD | Silica-Quartz | 5 | 04/22/2008 | No | No | |
| EMSL | FH-041708-36 | #8 - 5TH FL SCAFFOLD AT NE CORNER | 04/17/2008 | Remediation | 2.874 | 040809249-0008 | 04/19/2008 | 04/21/2008 | NIOSH 7500 XRD | Silica-Quartz | <7 | 04/22/2008 | No | No | See Note 1 |
| EMSL | FH-041808-29 | #1 - SIDEWALK BRIDGE LEVEL NW CORNER | 04/18/2008 | Remediation | 2.882 | 040809319-0001 | 04/21/2008 | 04/23/2008 | NIOSH 7500 XRD | Silica-Quartz | <7 | 04/23/2008 | No | No | See Note 1 |
| EMSL | FH-041808-30 | #2 - SIDEWALK BRIDGE LEVEL SW CORNER | 04/18/2008 | Remediation | 2.888 | 040809319-0002 | 04/21/2008 | 04/23/2008 | NIOSH 7500 XRD | Silica-Quartz | 5 | 04/23/2008 | No | No | |
| EMSL | FH-041808-31 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 04/18/2008 | Remediation | 2.884 | 040809319-0003 | 04/21/2008 | 04/23/2008 | NIOSH 7500 XRD | Silica-Quartz | 17 | 04/23/2008 | Yes | Yes | See Note 2 |
| EMSL | FH-041808-32 | #4 - SIDEWALK BRIDGE LEVEL NE CORNER | 04/18/2008 | Remediation | 2.888 | 040809319-0004 | 04/21/2008 | 04/23/2008 | NIOSH 7500 XRD | Silica-Quartz | 9 | 04/23/2008 | No | No | |
| EMSL | FH-041808-33 | #5 - 5TH FL SETBACK ROOF N. SIDE | 04/18/2008 | Remediation | 2.886 | 040809319-0005 | 04/21/2008 | 04/23/2008 | NIOSH 7500 XRD | Silica-Quartz | 6 | 04/23/2008 | No | No | |
| EMSL | FH-041808-34 | #6 - 5TH FL SETBACK ROOF SW SIDE | 04/18/2008 | Remediation | 2.888 | 040809319-0006 | 04/21/2008 | 04/23/2008 | NIOSH 7500 XRD | Silica-Quartz | 3 | 04/23/2008 | No | No | |
| EMSL | FH-041808-35 | #7 - 5TH FL SCAFFOLD AT SE CORNER | 04/18/2008 | Remediation | 2.886 | 040809319-0007 | 04/21/2008 | 04/23/2008 | NIOSH 7500 XRD | Silica-Quartz | 5 | 04/23/2008 | No | No | |
| EMSL | FH-041808-36 | #8 - 5TH FL SCAFFOLD AT NE CORNER | 04/18/2008 | Remediation | 2.884 | 040809319-0008 | 04/21/2008 | 04/23/2008 | NIOSH 7500 XRD | Silica-Quartz | 8 | 04/23/2008 | No | No | |
| EMSL | FH-041908-29 | #1 - SIDEWALK BRIDGE LEVEL NW CORNER | 04/19/2008 | Remediation | 2.874 | 040809305-0001 | 04/21/2008 | 04/23/2008 | NIOSH 7500 XRD | Silica-Quartz | <2 | 04/24/2008 | No | No | |
| EMSL | FH-041908-30 | #2 - SIDEWALK BRIDGE LEVEL SW CORNER | 04/19/2008 | Remediation | 2.884 | 040809305-0002 | 04/21/2008 | 04/23/2008 | NIOSH 7500 XRD | Silica-Quartz | <2 | 04/24/2008 | No | No | |
| EMSL | FH-041908-31 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 04/19/2008 | Remediation | 2.874 | 040809305-0003 | 04/21/2008 | 04/23/2008 | NIOSH 7500 XRD | Silica-Quartz | 4 | 04/24/2008 | No | No | |
| EMSL | FH-041908-32 | #4 - SIDEWALK BRIDGE LEVEL NE CORNER | 04/19/2008 | Remediation | 2.874 | 040809305-0004 | 04/21/2008 | 04/23/2008 | NIOSH 7500 XRD | Silica-Quartz | 3 | 04/24/2008 | No | No | |
| EMSL | FH-041908-33 | #5 - 5TH FL SETBACK ROOF N. SIDE | 04/19/2008 | Remediation | 2.874 | 040809305-0005 | 04/21/2008 | 04/23/2008 | NIOSH 7500 XRD | Silica-Quartz | 3 | 04/24/2008 | No | No | |
| EMSL | FH-041908-34 | #6 - 5TH FL SETBACK ROOF SW SIDE | 04/19/2008 | Remediation | 2.872 | 040809305-0006 | 04/21/2008 | 04/23/2008 | NIOSH 7500 XRD | Silica-Quartz | <2 | 04/24/2008 | No | No | |
| EMSL | FH-041908-35 | #7 - 5TH FL SCAFFOLD AT SE CORNER | 04/19/2008 | Remediation | 2.880 | 040809305-0007 | 04/21/2008 | 04/23/2008 | NIOSH 7500 XRD | Silica-Quartz | <2 | 04/24/2008 | No | No | |
| EMSL | FH-041908-36 | #8 - 5TH FL SCAFFOLD AT NE CORNER | 04/19/2008 | Remediation | 2.874 | 040809305-0008 | 04/21/2008 | 04/23/2008 | NIOSH 7500 XRD | Silica-Quartz | 2 | 04/24/2008 | No | No | |
| EMSL | FH-042008-29 | #1 - SIDEWALK BRIDGE LEVEL NW CORNER | 04/20/2008 | Remediation | 2.884 | 040809412-0001 | 04/22/2008 | 04/24/2008 | NIOSH 7500 XRD | Silica-Quartz | <2 | 04/25/2008 | No | No | |
| EMSL | FH-042008-30 | #2 - SIDEWALK BRIDGE LEVEL SW CORNER | 04/20/2008 | Remediation | 2.880 | 040809412-0002 | 04/22/2008 | 04/24/2008 | NIOSH 7500 XRD | Silica-Quartz | <2 | 04/25/2008 | No | No | |
| EMSL | FH-042008-31 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 04/20/2008 | Remediation | 2.884 | 040809412-0003 | 04/22/2008 | 04/24/2008 | NIOSH 7500 XRD | Silica-Quartz | 4 | 04/25/2008 | No | No | |
| EMSL | FH-042008-32 | #4 - SIDEWALK BRIDGE LEVEL NE CORNER | 04/20/2008 | Remediation | 2.884 | 040809412-0004 | 04/22/2008 | 04/24/2008 | NIOSH 7500 XRD | Silica-Quartz | 2 | 04/25/2008 | No | No | |
| EMSL | FH-042008-33 | #5 - 5TH FL SETBACK ROOF N. SIDE | 04/20/2008 | Remediation | 2.884 | 040809412-0005 | 04/22/2008 | 04/24/2008 | NIOSH 7500 XRD | Silica-Quartz | 2 | 04/25/2008 | No | No | |
| EMSL | FH-042008-34 | #6 - 5TH FL SETBACK ROOF SW SIDE | 04/20/2008 | Remediation | 2.886 | 040809412-0006 | 04/22/2008 | 04/24/2008 | NIOSH 7500 XRD | Silica-Quartz | 2 | 04/25/2008 | No | No | |
| EMSL | FH-042008-35 | #7 - 5TH FL SCAFFOLD AT SE CORNER | 04/20/2008 | Remediation | 2.880 | 040809412-0007 | 04/22/2008 | 04/24/2008 | NIOSH 7500 XRD | Silica-Quartz | 5 | 04/25/2008 | No | No | |
| EMSL | FH-042008-36 | #8 - 5TH FL SCAFFOLD AT NE CORNER | 04/20/2008 | Remediation | 2.884 | 040809412-0008 | 04/22/2008 | 04/24/2008 | NIOSH 7500 XRD | Silica-Quartz | 2 | 04/25/2008 | No | No | |

Note 1: Secondary quartz peak used for sample due to suspected primary peak interference.

Note 2: Exceedance of the USEPA Site Specific Trigger Level for silica at Station #3 (Sidewalk Bridge Level SE Corner) occurred on Friday, April 18, 2008. Fugitive emissions likely attribute to one or more off site properties directly impacted silica concentrations. After review of all of the information including meteorological data, PM 10 data, site activities logs and off site visual observations, it has been determined that the silica exceedance measured at Station #3 on April 18, 2008 was not attributable to work activities at 30 West Broadway. Exceedance reported to USEPA.

Submittal Summary - Remediation Phase Week 51 (04/14/08 to 04/20/08)

| Lab Name | Airtek Field Sample No. | Sample Location | Collection Start Date | Project Phase | Sample Volume (m ³) | Lab Sample ID | Date Received | Date Analyzed | Analytical Method | Parameter Name | Dioxin/Furans Concentration (ng/m ³) | Date Reported | Exceeds Target Air Quality Levels? | Exceeds EPA Site Specific Trigger Levels? | Comments |
|----------------------------------|-------------------------|--------------------------------------|-----------------------|---------------|---------------------------------|---------------|---------------|---------------|-------------------|------------------------------------|--|---------------|------------------------------------|---|----------|
| Target Air Quality Levels | | | | | | | | | | | 0.00025 | | | | |
| EPA Site Specific Trigger Levels | | | | | | | | | | | 0.025 | | | | |
| STL-SAC | FH-041908-40 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 4/19/2008 | Remediation | 360 | G8D230349003 | 04/23/2008 | 05/10/2008 | TO-9 | Toxicity Equivalent Quotient (TEQ) | 0.000014 | 05/12/2008 | No | No | |

Submittal Summary - Remediation Phase Week 51 (04/14/08 to 04/20/08)

| Lab Name | Airtek Field Sample No. | Sample Location | Collection Start Date | Project Phase | Sample Volume (m ³) | Lab Sample ID | Date Received | Date Analyzed | Analytical Method | Parameter Name | PAHs Concentration (ug/m3) | Date Reported | Exceeds Target Air Quality Levels? | Exceeds EPA Site Specific Trigger Levels? | Comments |
|----------------------------------|-------------------------|--------------------------------------|-----------------------|---------------|---------------------------------|---------------|---------------|---------------|-------------------|----------------|----------------------------|---------------|------------------------------------|---|----------|
| Target Air Quality Levels | | | | | | | | | | | 0.034 | | | | |
| EPA Site Specific Trigger Levels | | | | | | | | | | | 3.4 | | | | |
| STL-SAC | FH-041908-49 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 4/19/2008 | Remediation | 360 | G8D230344003 | 04/23/2008 | 04/29/2008 | 8270C SIM | BAP-equivalent | <0.007 | 05/05/2008 | No | No | |

Submittal Summary - Remediation Phase Week 51 (04/14/08 to 04/20/08)

| Lab Name | Airtek Field Sample No. | Sample Location | Collection Start Date | Project Phase | Sample Volume (m ³) | Lab Sample ID | Date Received | Date Analyzed | Analytical Method | Parameter Name | PCBs Concentration (ug/m3) | Date Reported | Exceeds Target Air Quality Levels? | Exceeds EPA Site Specific Trigger Levels? | Comments |
|---|-------------------------|--------------------------------------|-----------------------|---------------|---------------------------------|---------------|---------------|---------------|-------------------|----------------|----------------------------|---------------|------------------------------------|---|----------|
| Target Air Quality Levels | | | | | | | | | | | 0.12 | | | | |
| EPA Site Specific Trigger Levels | | | | | | | | | | | 12 | | | | |
| STL-SAC | FH-041908-58 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 4/19/2008 | Remediation | 360 | G8D230338003 | 04/23/2008 | 05/06/2008 | TO-4 | Aroclor 1016 | <0.0021 | 05/07/2008 | No | No | |
| STL-SAC | FH-041908-58 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 4/19/2008 | Remediation | 360 | G8D230338003 | 04/23/2008 | 05/06/2008 | TO-4 | Aroclor 1221 | <0.0021 | 05/07/2008 | No | No | |
| STL-SAC | FH-041908-58 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 4/19/2008 | Remediation | 360 | G8D230338003 | 04/23/2008 | 05/06/2008 | TO-4 | Aroclor 1232 | <0.0021 | 05/07/2008 | No | No | |
| STL-SAC | FH-041908-58 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 4/19/2008 | Remediation | 360 | G8D230338003 | 04/23/2008 | 05/06/2008 | TO-4 | Aroclor 1242 | <0.0021 | 05/07/2008 | No | No | |
| STL-SAC | FH-041908-58 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 4/19/2008 | Remediation | 360 | G8D230338003 | 04/23/2008 | 05/06/2008 | TO-4 | Aroclor 1248 | <0.0021 | 05/07/2008 | No | No | |
| STL-SAC | FH-041908-58 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 4/19/2008 | Remediation | 360 | G8D230338003 | 04/23/2008 | 05/06/2008 | TO-4 | Aroclor 1254 | <0.0021 | 05/07/2008 | No | No | |
| STL-SAC | FH-041908-58 | #3 - SIDEWALK BRIDGE LEVEL SE CORNER | 4/19/2008 | Remediation | 360 | G8D230338003 | 04/23/2008 | 05/06/2008 | TO-4 | Aroclor 1260 | <0.0021 | 05/07/2008 | No | No | |