

Submittal Summary - Remediation Phase Week 54 (05/05/08 to 05/11/08)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Work Shift/Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	Asbestos PCME Concentration (f/cm ³)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels															
EPA Site Specific Trigger Levels															
											0.0009				
											N/A				
EMSL	FH-050508-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	5/5/2008	1/Remediation	2.946	030813657-0001	5/5/2008	5/6/2008	PCME	ASBESTOS	<0.00084	5/7/2008	No	No	
EMSL	FH-050508-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/5/2008	1/Remediation	2.952	030813657-0002	5/5/2008	5/6/2008	PCME	ASBESTOS	<0.00084	5/7/2008	No	No	
EMSL	FH-050508-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/5/2008	1/Remediation	2.952	030813657-0003	5/5/2008	5/6/2008	PCME	ASBESTOS	<0.00084	5/7/2008	No	No	
EMSL	FH-050508-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	5/5/2008	1/Remediation	2.946	030813657-0004	5/5/2008	5/6/2008	PCME	ASBESTOS	<0.00084	5/7/2008	No	No	
EMSL	FH-050508-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	5/5/2008	1/Remediation	2.946	030813657-0005	5/5/2008	5/6/2008	PCME	ASBESTOS	<0.00084	5/7/2008	No	No	
EMSL	FH-050508-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	5/5/2008	1/Remediation	2.946	030813657-0006	5/5/2008	5/6/2008	PCME	ASBESTOS	<0.00084	5/7/2008	No	No	
EMSL	FH-050508-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	5/5/2008	1/Remediation	2.952	030813657-0007	5/5/2008	5/6/2008	PCME	ASBESTOS	<0.00084	5/7/2008	No	No	
EMSL	FH-050508-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	5/5/2008	1/Remediation	2.946	030813657-0008	5/5/2008	5/6/2008	PCME	ASBESTOS	<0.00084	5/7/2008	No	No	
EMSL	FH-050608-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	5/6/2008	1/Remediation	2.898	030813765-0001	5/6/2008	5/7/2008	PCME	ASBESTOS	<0.00085	5/8/2008	No	No	
EMSL	FH-050608-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/6/2008	1/Remediation	2.874	030813765-0002	5/6/2008	5/7/2008	PCME	ASBESTOS	<0.00086	5/8/2008	No	No	
EMSL	FH-050608-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/6/2008	1/Remediation	2.880	030813765-0003	5/6/2008	5/7/2008	PCME	ASBESTOS	<0.00086	5/8/2008	No	No	
EMSL	FH-050608-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	5/6/2008	1/Remediation	2.886	030813765-0004	5/6/2008	5/7/2008	PCME	ASBESTOS	<0.00086	5/8/2008	No	No	
EMSL	FH-050608-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	5/6/2008	1/Remediation	2.892	030813765-0005	5/6/2008	5/7/2008	PCME	ASBESTOS	<0.00085	5/8/2008	No	No	
EMSL	FH-050608-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	5/6/2008	1/Remediation	2.892	030813765-0006	5/6/2008	5/7/2008	PCME	ASBESTOS	0.00085	5/8/2008	No	No	
EMSL	FH-050608-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	5/6/2008	1/Remediation	2.880	030813765-0007	5/6/2008	5/7/2008	PCME	ASBESTOS	<0.00086	5/8/2008	No	No	
EMSL	FH-050608-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	5/6/2008	1/Remediation	2.898	030813765-0008	5/6/2008	5/7/2008	PCME	ASBESTOS	<0.00085	5/8/2008	No	No	
EMSL	FH-050608-65	DUPLICATE (STATION #1)	5/6/2008	1/Remediation	2.898	030813765-0009	5/6/2008	5/7/2008	PCME	ASBESTOS	<0.00085	5/8/2008	No	No	
EMSL	FH-050708-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	5/7/2008	1/Remediation	2.916	030813926-0001	5/7/2008	5/8/2008	PCME	ASBESTOS	<0.00085	5/8/2008	No	No	
EMSL	FH-050708-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/7/2008	1/Remediation	2.922	030813926-0002	5/7/2008	5/8/2008	PCME	ASBESTOS	<0.00084	5/8/2008	No	No	
EMSL	FH-050708-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/7/2008	1/Remediation	2.922	030813926-0003	5/7/2008	5/8/2008	PCME	ASBESTOS	<0.00084	5/8/2008	No	No	
EMSL	FH-050708-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	5/7/2008	1/Remediation	2.916	030813926-0004	5/7/2008	5/8/2008	PCME	ASBESTOS	<0.00085	5/8/2008	No	No	
EMSL	FH-050708-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	5/7/2008	1/Remediation	2.916	030813926-0005	5/7/2008	5/8/2008	PCME	ASBESTOS	<0.00085	5/8/2008	No	No	
EMSL	FH-050708-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	5/7/2008	1/Remediation	2.916	030813926-0006	5/7/2008	5/8/2008	PCME	ASBESTOS	<0.00085	5/8/2008	No	No	
EMSL	FH-050708-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	5/7/2008	1/Remediation	2.922	030813926-0007	5/7/2008	5/8/2008	PCME	ASBESTOS	<0.00084	5/8/2008	No	No	
EMSL	FH-050708-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	5/7/2008	1/Remediation	2.916	030813926-0008	5/7/2008	5/8/2008	PCME	ASBESTOS	<0.00085	5/8/2008	No	No	
EMSL	FH-050808-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	5/8/2008	1/Remediation	2.892	030814081-0001	5/8/2008	5/9/2008	PCME	ASBESTOS	<0.00085	5/9/2008	No	No	
EMSL	FH-050808-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/8/2008	1/Remediation	2.856	030814081-0002	5/8/2008	5/9/2008	PCME	ASBESTOS	<0.00086	5/9/2008	No	No	
EMSL	FH-050808-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/8/2008	1/Remediation	2.862	030814081-0003	5/8/2008	5/9/2008	PCME	ASBESTOS	<0.00086	5/9/2008	No	No	
EMSL	FH-050808-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	5/8/2008	1/Remediation	2.874	030814081-0004	5/8/2008	5/9/2008	PCME	ASBESTOS	<0.00086	5/9/2008	No	No	
EMSL	FH-050808-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	5/8/2008	1/Remediation	2.880	030814081-0005	5/8/2008	5/9/2008	PCME	ASBESTOS	<0.00086	5/9/2008	No	No	
EMSL	FH-050808-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	5/8/2008	1/Remediation	2.874	030814081-0006	5/8/2008	5/9/2008	PCME	ASBESTOS	<0.00086	5/9/2008	No	No	
EMSL	FH-050808-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	5/8/2008	1/Remediation	2.856	030814081-0007	5/8/2008	5/9/2008	PCME	ASBESTOS	<0.00086	5/9/2008	No	No	
EMSL	FH-050808-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	5/8/2008	1/Remediation	2.886	030814081-0008	5/8/2008	5/9/2008	PCME	ASBESTOS	<0.00086	5/9/2008	No	No	
EMSL	FH-050908-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	5/9/2008	1/Remediation	2.850	030814187-0001	5/9/2008	5/10/2008	PCME	ASBESTOS	<0.00087	5/12/2008	No	No	
EMSL	FH-050908-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/9/2008	1/Remediation	2.832	030814187-0002	5/9/2008	5/10/2008	PCME	ASBESTOS	<0.00087	5/12/2008	No	No	
EMSL	FH-050908-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/9/2008	1/Remediation	2.832	030814187-0003	5/9/2008	5/10/2008	PCME	ASBESTOS	<0.00087	5/12/2008	No	No	
EMSL	FH-050908-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	5/9/2008	1/Remediation	2.838	030814187-0004	5/9/2008	5/10/2008	PCME	ASBESTOS	<0.00087	5/12/2008	No	No	
EMSL	FH-050908-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	5/9/2008	1/Remediation	2.844	030814187-0005	5/9/2008	5/10/2008	PCME	ASBESTOS	<0.00087	5/12/2008	No	No	
EMSL	FH-050908-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	5/9/2008	1/Remediation	2.844	030814187-0006	5/9/2008	5/10/2008	PCME	ASBESTOS	<0.00087	5/12/2008	No	No	
EMSL	FH-050908-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	5/9/2008	1/Remediation	2.826	030814187-0007	5/9/2008	5/10/2008	PCME	ASBESTOS	<0.00087	5/12/2008	No	No	
EMSL	FH-050908-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	5/9/2008	1/Remediation	2.850	030814187-0008	5/9/2008	5/10/2008	PCME	ASBESTOS	<0.00087	5/12/2008	No	No	
EMSL	FH-051008-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	5/10/2008	1/Remediation	2.850	030814393-0001	5/11/2008	5/12/2008	PCME	ASBESTOS	<0.00087	5/12/2008	No	No	
EMSL	FH-051008-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/10/2008	1/Remediation	2.874	030814393-0002	5/11/2008	5/12/2008	PCME	ASBESTOS	<0.00086	5/12/2008	No	No	
EMSL	FH-051008-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/10/2008	1/Remediation	2.874	030814393-0003	5/11/2008	5/12/2008	PCME	ASBESTOS	<0.00086	5/12/2008	No	No	
EMSL	FH-051008-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	5/10/2008	1/Remediation	2.862	030814393-0004	5/11/2008	5/12/2008	PCME	ASBESTOS	<0.00086	5/12/2008	No	No	
EMSL	FH-051008-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	5/10/2008	1/Remediation	2.862	030814393-0005	5/11/2008	5/12/2008	PCME	ASBESTOS	<0.00086	5/12/2008	No	No	
EMSL	FH-051008-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	5/10/2008	1/Remediation	2.868	030814393-0006	5/11/2008	5/12/2008	PCME	ASBESTOS	<0.00086	5/12/2008	No	No	
EMSL	FH-051008-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	5/10/2008	1/Remediation	2.874	030814393-0007	5/11/2008	5/12/2008	PCME	ASBESTOS	<0.00086	5/12/2008	No	No	
EMSL	FH-051008-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	5/10/2008	1/Remediation	2.850	030814393-0008	5/11/2008	5/12/2008	PCME	ASBESTOS	<0.00087	5/12/2008	No	No	
EMSL	FH-051108-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	5/11/2008	1/Remediation	2.886	030814394-0001	5/11/2008	5/12/2008	PCME	ASBESTOS	<0.00086	5/12/2008	No	No	
EMSL	FH-051108-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/11/2008	1/Remediation	2.886	030814394-0002	5/11/2008	5/12/2008	PCME	ASBESTOS	<0.00086	5/12/2008	No	No	
EMSL	FH-051108-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/11/2008	1/Remediation	2.880	030814394-0003	5/11/2008	5/12/2008	PCME	ASBESTOS	<0.00086	5/12/2008	No	No	
EMSL	FH-051108-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	5/11/2008	1/Remediation	2.880	030814394-0004	5/11/2008	5/12/2008	PCME	ASBESTOS	<0.00086	5/12/2008	No	No	
EMSL	FH-051108-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	5/11/2008	1/Remediation	2.886	030814394-0005	5/11/2008	5/12/2008	PCME	ASBESTOS	<0.00086	5/12/2008	No	No	
EMSL	FH-051108-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	5/11/2008	1/Remediation	2.880	030814394-0006	5/11/2008	5/12/2008	PCME	ASBESTOS	<0.00086	5/12/2008	No	No	
EMSL	FH-051108-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	5/11/2008	1/Remediation	2.886	030814394-0007	5/11/2008	5/12/2008	PCME	ASBESTOS	<0.00086	5/12/2008	No	No	
EMSL	FH-051108-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	5/11/2008	1/Remediation	2.880	030814394-0008	5/11/2008	5/12/2008	PCME	ASBESTOS	<0.00086	5/12/2008	No	No	

Submittal Summary - Remediation Phase Week 54 (05/05/08 to 05/11/08)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Work Shift/Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	Asbestos PCME Concentration (f/cm ³)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels															
EPA Site Specific Trigger Levels															
											0.0009				
EMSL	2 FH-050508-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	5/5/2008	2/Remediation	3.246	030813690-0001	5/6/2008	5/6/2008	PCME	ASBESTOS	<0.00083	5/8/2008	No	No	
EMSL	2 FH-050508-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/5/2008	2/Remediation	3.246	030813690-0002	5/6/2008	5/6/2008	PCME	ASBESTOS	<0.00083	5/8/2008	No	No	
EMSL	2 FH-050508-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/5/2008	2/Remediation	3.240	030813690-0003	5/6/2008	5/6/2008	PCME	ASBESTOS	<0.00083	5/8/2008	No	No	
EMSL	2 FH-050508-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	5/5/2008	2/Remediation	3.240	030813690-0004	5/6/2008	5/6/2008	PCME	ASBESTOS	<0.00083	5/8/2008	No	No	
EMSL	2 FH-050508-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	5/5/2008	2/Remediation	3.246	030813690-0005	5/6/2008	5/6/2008	PCME	ASBESTOS	<0.00083	5/8/2008	No	No	
EMSL	2 FH-050508-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	5/5/2008	2/Remediation	3.246	030813690-0006	5/6/2008	5/6/2008	PCME	ASBESTOS	<0.00083	5/8/2008	No	No	
EMSL	2 FH-050508-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	5/5/2008	2/Remediation	3.240	030813690-0007	5/6/2008	5/6/2008	PCME	ASBESTOS	<0.00083	5/8/2008	No	No	
EMSL	2 FH-050508-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	5/5/2008	2/Remediation	3.246	030813690-0008	5/6/2008	5/6/2008	PCME	ASBESTOS	<0.00083	5/8/2008	No	No	
EMSL	2 FH-050608-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	5/6/2008	2/Remediation	3.240	030813826-0001	5/7/2008	5/8/2008	PCME	ASBESTOS	<0.00083	5/8/2008	No	No	
EMSL	2 FH-050608-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/6/2008	2/Remediation	3.246	030813826-0002	5/7/2008	5/8/2008	PCME	ASBESTOS	<0.00083	5/8/2008	No	No	
EMSL	2 FH-050608-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/6/2008	2/Remediation	3.240	030813826-0003	5/7/2008	5/8/2008	PCME	ASBESTOS	<0.00083	5/8/2008	No	No	
EMSL	2 FH-050608-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	5/6/2008	2/Remediation	3.234	030813826-0004	5/7/2008	5/8/2008	PCME	ASBESTOS	<0.00083	5/8/2008	No	No	
EMSL	2 FH-050608-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	5/6/2008	2/Remediation	3.240	030813826-0005	5/7/2008	5/8/2008	PCME	ASBESTOS	<0.00083	5/8/2008	No	No	
EMSL	2 FH-050608-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	5/6/2008	2/Remediation	3.234	030813826-0006	5/7/2008	5/8/2008	PCME	ASBESTOS	<0.00083	5/8/2008	No	No	
EMSL	2 FH-050608-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	5/6/2008	2/Remediation	3.240	030813826-0007	5/7/2008	5/8/2008	PCME	ASBESTOS	<0.00083	5/8/2008	No	No	
EMSL	2 FH-050608-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	5/6/2008	2/Remediation	3.240	030813826-0008	5/7/2008	5/8/2008	PCME	ASBESTOS	<0.00083	5/8/2008	No	No	
EMSL	2 FH-050608-65	DUPLICATE (STATION #1)	5/6/2008	2/Remediation	3.240	030813826-0009	5/7/2008	5/8/2008	PCME	ASBESTOS	<0.00083	5/8/2008	No	No	
EMSL	2 FH-050708-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	5/7/2008	2/Remediation	3.252	030813992-0001	5/8/2008	5/8/2008	PCME	ASBESTOS	<0.00083	5/9/2008	No	No	
EMSL	2 FH-050708-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/7/2008	2/Remediation	3.240	030813992-0002	5/8/2008	5/8/2008	PCME	ASBESTOS	<0.00083	5/9/2008	No	No	
EMSL	2 FH-050708-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/7/2008	2/Remediation	3.234	030813992-0003	5/8/2008	5/8/2008	PCME	ASBESTOS	<0.00083	5/9/2008	No	No	
EMSL	2 FH-050708-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	5/7/2008	2/Remediation	3.234	030813992-0004	5/8/2008	5/8/2008	PCME	ASBESTOS	<0.00083	5/9/2008	No	No	
EMSL	2 FH-050708-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	5/7/2008	2/Remediation	3.240	030813992-0005	5/8/2008	5/8/2008	PCME	ASBESTOS	<0.00083	5/9/2008	No	No	
EMSL	2 FH-050708-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	5/7/2008	2/Remediation	3.234	030813992-0006	5/8/2008	5/8/2008	PCME	ASBESTOS	<0.00083	5/9/2008	No	No	
EMSL	2 FH-050708-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	5/7/2008	2/Remediation	3.240	030813992-0007	5/8/2008	5/8/2008	PCME	ASBESTOS	<0.00083	5/9/2008	No	No	
EMSL	2 FH-050708-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	5/7/2008	2/Remediation	3.252	030813992-0008	5/8/2008	5/8/2008	PCME	ASBESTOS	<0.00083	5/9/2008	No	No	
EMSL	2 FH-050808-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	5/8/2008	2/Remediation	3.240	030814110-0001	5/9/2008	5/10/2008	PCME	ASBESTOS	<0.00076	5/12/2008	No	No	
EMSL	2 FH-050808-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/8/2008	2/Remediation	3.240	030814110-0002	5/9/2008	5/10/2008	PCME	ASBESTOS	<0.00076	5/12/2008	No	No	
EMSL	2 FH-050808-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/8/2008	2/Remediation	3.240	030814110-0003	5/9/2008	5/10/2008	PCME	ASBESTOS	<0.00076	5/12/2008	No	No	
EMSL	2 FH-050808-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	5/8/2008	2/Remediation	3.234	030814110-0004	5/9/2008	5/10/2008	PCME	ASBESTOS	<0.00076	5/12/2008	No	No	
EMSL	2 FH-050808-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	5/8/2008	2/Remediation	3.240	030814110-0005	5/9/2008	5/10/2008	PCME	ASBESTOS	<0.00076	5/12/2008	No	No	
EMSL	2 FH-050808-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	5/8/2008	2/Remediation	3.239	030814110-0006	5/9/2008	5/10/2008	PCME	ASBESTOS	<0.00076	5/12/2008	No	No	
EMSL	2 FH-050808-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	5/8/2008	2/Remediation	3.240	030814110-0007	5/9/2008	5/10/2008	PCME	ASBESTOS	<0.00076	5/12/2008	No	No	
EMSL	2 FH-050808-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	5/8/2008	2/Remediation	3.240	030814110-0008	5/9/2008	5/10/2008	PCME	ASBESTOS	<0.00076	5/12/2008	No	No	
EMSL	2 FH-050908-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	5/9/2008	2/Remediation	3.240	030814255-0001	5/10/2008	5/10/2008	PCME	ASBESTOS	<0.00076	5/12/2008	No	No	
EMSL	2 FH-050908-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/9/2008	2/Remediation	3.234	030814255-0002	5/10/2008	5/10/2008	PCME	ASBESTOS	<0.00076	5/12/2008	No	No	
EMSL	2 FH-050908-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/9/2008	2/Remediation	3.228	030814255-0003	5/10/2008	5/10/2008	PCME	ASBESTOS	<0.00076	5/12/2008	No	No	
EMSL	2 FH-050908-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	5/9/2008	2/Remediation	3.228	030814255-0004	5/10/2008	5/10/2008	PCME	ASBESTOS	<0.00076	5/12/2008	No	No	
EMSL	2 FH-050908-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	5/9/2008	2/Remediation	3.240	030814255-0005	5/10/2008	5/10/2008	PCME	ASBESTOS	<0.00076	5/12/2008	No	No	
EMSL	2 FH-050908-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	5/9/2008	2/Remediation	3.228	030814255-0006	5/10/2008	5/10/2008	PCME	ASBESTOS	<0.00076	5/12/2008	No	No	
EMSL	2 FH-050908-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	5/9/2008	2/Remediation	3.234	030814255-0007	5/10/2008	5/10/2008	PCME	ASBESTOS	<0.00076	5/12/2008	No	No	
EMSL	2 FH-050908-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	5/9/2008	2/Remediation	3.240	030814255-0008	5/10/2008	5/10/2008	PCME	ASBESTOS	<0.00076	5/12/2008	No	No	

Submittal Summary - Remediation Phase Week 54 (05/05/08 to 05/11/08)

Lab Name	Airetek Field Sample No.	Sample Location	Collection Start Date	Work Shift/Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	Asbestos AHERA Concentration (S/mm ³)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											N/A				
EPA Site Specific Trigger Levels											70				
EMSL	2 FH-050508-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	5/5/2008	2/Remediation	3.246	030813690-0001	5/6/2008	5/6/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<15.00	5/8/2008	No	No	
EMSL	2 FH-050508-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/5/2008	2/Remediation	3.246	030813690-0002	5/6/2008	5/6/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<15.00	5/8/2008	No	No	
EMSL	2 FH-050508-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/5/2008	2/Remediation	3.240	030813690-0003	5/6/2008	5/6/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<15.00	5/8/2008	No	No	
EMSL	2 FH-050508-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	5/5/2008	2/Remediation	3.240	030813690-0004	5/6/2008	5/6/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<15.00	5/8/2008	No	No	
EMSL	2 FH-050508-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	5/5/2008	2/Remediation	3.246	030813690-0005	5/6/2008	5/6/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<15.00	5/8/2008	No	No	
EMSL	2 FH-050508-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	5/5/2008	2/Remediation	3.246	030813690-0006	5/6/2008	5/6/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<15.00	5/8/2008	No	No	
EMSL	2 FH-050508-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	5/5/2008	2/Remediation	3.240	030813690-0007	5/6/2008	5/6/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<15.00	5/8/2008	No	No	
EMSL	2 FH-050508-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	5/5/2008	2/Remediation	3.246	030813690-0008	5/6/2008	5/6/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<15.00	5/8/2008	No	No	
EMSL	2 FH-050608-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	5/6/2008	2/Remediation	3.240	030813826-0001	5/7/2008	5/8/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<15.00	5/8/2008	No	No	
EMSL	2 FH-050608-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/6/2008	2/Remediation	3.246	030813826-0002	5/7/2008	5/8/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<15.00	5/8/2008	No	No	
EMSL	2 FH-050608-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/6/2008	2/Remediation	3.240	030813826-0003	5/7/2008	5/8/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<15.00	5/8/2008	No	No	
EMSL	2 FH-050608-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	5/6/2008	2/Remediation	3.234	030813826-0004	5/7/2008	5/8/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<15.00	5/8/2008	No	No	
EMSL	2 FH-050608-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	5/6/2008	2/Remediation	3.240	030813826-0005	5/7/2008	5/8/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<15.00	5/8/2008	No	No	
EMSL	2 FH-050608-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	5/6/2008	2/Remediation	3.234	030813826-0006	5/7/2008	5/8/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<15.00	5/8/2008	No	No	
EMSL	2 FH-050608-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	5/6/2008	2/Remediation	3.240	030813826-0007	5/7/2008	5/8/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<15.00	5/8/2008	No	No	
EMSL	2 FH-050608-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	5/6/2008	2/Remediation	3.240	030813826-0008	5/7/2008	5/8/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<15.00	5/8/2008	No	No	
EMSL	2 FH-050608-05	DUPLICATE (STATION #1)	5/6/2008	2/Remediation	3.240	030813826-0009	5/7/2008	5/8/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<15.00	5/8/2008	No	No	
EMSL	2 FH-050708-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	5/7/2008	2/Remediation	3.252	030813992-0001	5/8/2008	5/8/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<15.00	5/9/2008	No	No	
EMSL	2 FH-050708-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/7/2008	2/Remediation	3.240	030813992-0002	5/8/2008	5/8/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<15.00	5/9/2008	No	No	
EMSL	2 FH-050708-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/7/2008	2/Remediation	3.234	030813992-0003	5/8/2008	5/8/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<15.00	5/9/2008	No	No	
EMSL	2 FH-050708-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	5/7/2008	2/Remediation	3.234	030813992-0004	5/8/2008	5/8/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<15.00	5/9/2008	No	No	
EMSL	2 FH-050708-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	5/7/2008	2/Remediation	3.240	030813992-0005	5/8/2008	5/8/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<15.00	5/9/2008	No	No	
EMSL	2 FH-050708-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	5/7/2008	2/Remediation	3.234	030813992-0006	5/8/2008	5/8/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<15.00	5/9/2008	No	No	
EMSL	2 FH-050708-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	5/7/2008	2/Remediation	3.240	030813992-0007	5/8/2008	5/8/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<15.00	5/9/2008	No	No	
EMSL	2 FH-050708-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	5/7/2008	2/Remediation	3.252	030813992-0008	5/8/2008	5/8/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<15.00	5/9/2008	No	No	
EMSL	2 FH-050808-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	5/8/2008	2/Remediation	3.240	030814110-0001	5/9/2008	5/10/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	5/12/2008	No	No	
EMSL	2 FH-050808-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/8/2008	2/Remediation	3.240	030814110-0002	5/9/2008	5/10/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	5/12/2008	No	No	
EMSL	2 FH-050808-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/8/2008	2/Remediation	3.240	030814110-0003	5/9/2008	5/10/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	5/12/2008	No	No	
EMSL	2 FH-050808-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	5/8/2008	2/Remediation	3.234	030814110-0004	5/9/2008	5/10/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	5/12/2008	No	No	
EMSL	2 FH-050808-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	5/8/2008	2/Remediation	3.240	030814110-0005	5/9/2008	5/10/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	5/12/2008	No	No	
EMSL	2 FH-050808-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	5/8/2008	2/Remediation	3.239	030814110-0006	5/9/2008	5/10/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	5/12/2008	No	No	
EMSL	2 FH-050808-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	5/8/2008	2/Remediation	3.240	030814110-0007	5/9/2008	5/10/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	5/12/2008	No	No	
EMSL	2 FH-050808-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	5/8/2008	2/Remediation	3.240	030814110-0008	5/9/2008	5/10/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	5/12/2008	No	No	
EMSL	2 FH-050908-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	5/9/2008	2/Remediation	3.240	030814255-0001	5/10/2008	5/10/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	5/12/2008	No	No	
EMSL	2 FH-050908-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/9/2008	2/Remediation	3.234	030814255-0002	5/10/2008	5/10/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	5/12/2008	No	No	
EMSL	2 FH-050908-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/9/2008	2/Remediation	3.228	030814255-0003	5/10/2008	5/10/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	5/12/2008	No	No	
EMSL	2 FH-050908-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	5/9/2008	2/Remediation	3.228	030814255-0004	5/10/2008	5/10/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	5/12/2008	No	No	
EMSL	2 FH-050908-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	5/9/2008	2/Remediation	3.240	030814255-0005	5/10/2008	5/10/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	5/12/2008	No	No	
EMSL	2 FH-050908-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	5/9/2008	2/Remediation	3.228	030814255-0006	5/10/2008	5/10/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	5/12/2008	No	No	
EMSL	2 FH-050908-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	5/9/2008	2/Remediation	3.234	030814255-0007	5/10/2008	5/10/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	5/12/2008	No	No	
EMSL	2 FH-050908-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	5/9/2008	2/Remediation	3.240	030814255-0008	5/10/2008	5/10/2008	TEM EPA 40 CFR PART 763 (AHERA)	ASBESTOS	<13.00	5/12/2008	No	No	

Submittal Summary - Remediation Phase Week 54 (05/05/08 to 05/11/08)

Airtek Field Sample No.	Sampling Location	Real-time Readings Date	Collection time (minutes)	Analyte	Analytical Method	Instrument	Particulate PM 10 (ug/m ³)	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
							150			
							150			
Target Air Quality Levels										
EPA Site Specific Trigger Levels										
FH-050508-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	5/5/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	22.48	No	No	
FH-050508-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/5/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	14.42	No	No	
FH-050508-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/5/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	29.44	No	No	
FH-050508-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	5/5/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	27.24	No	No	
FH-050508-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	5/5/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	17.03	No	No	
FH-050508-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	5/5/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	19.46	No	No	
FH-050508-EBAM10-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	5/5/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	19.85	No	No	
FH-050508-EBAM10-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	5/5/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	17.43	No	No	
FH-050508-TEOM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/5/2008	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	18.33	No	No	
FH-050608-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	5/6/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	28.08	No	No	
FH-050608-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/6/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	23.33	No	No	
FH-050608-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/6/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	37.03	No	No	
FH-050608-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	5/6/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	19.74	No	No	
FH-050608-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	5/6/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	23.49	No	No	
FH-050608-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	5/6/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	23.60	No	No	
FH-050608-EBAM10-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	5/6/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	34.15	No	No	
FH-050608-EBAM10-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	5/6/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	21.18	No	No	
FH-050608-TEOM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/6/2008	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	28.91	No	No	
FH-050708-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	5/7/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	13.66	No	No	
FH-050708-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/7/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	20.74	No	No	
FH-050708-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/7/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	47.51	No	No	
FH-050708-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	5/7/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	23.74	No	No	
FH-050708-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	5/7/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	23.23	No	No	
FH-050708-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	5/7/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	25.88	No	No	
FH-050708-EBAM10-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	5/7/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	28.76	No	No	
FH-050708-EBAM10-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	5/7/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	21.54	No	No	
FH-050708-TEOM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/7/2008	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	29.24	No	No	
FH-050808-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	5/8/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	31.94	No	No	
FH-050808-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/8/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	51.01	No	No	
FH-050808-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/8/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	35.03	No	No	
FH-050808-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	5/8/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	32.07	No	No	
FH-050808-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	5/8/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	51.64	No	No	
FH-050808-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	5/8/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	56.91	No	No	
FH-050808-EBAM10-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	5/8/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	56.15	No	No	
FH-050808-EBAM10-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	5/8/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	23.42	No	No	
FH-050808-TEOM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/8/2008	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	26.29	No	No	
FH-050908-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	5/9/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	6.70	No	No	
FH-050908-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/9/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	54.25	No	No	
FH-050908-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/9/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	32.26	No	No	
FH-050908-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	5/9/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	33.38	No	No	
FH-050908-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	5/9/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	41.53	No	No	
FH-050908-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	5/9/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	43.00	No	No	
FH-050908-EBAM10-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	5/9/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	21.47	No	No	
FH-050908-EBAM10-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	5/9/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	8.65	No	No	
FH-050908-TEOM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/9/2008	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	8.85	No	No	
FH-051008-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	5/10/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	9.69	No	No	
FH-051008-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/10/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	14.95	No	No	
FH-051008-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/10/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	15.90	No	No	
FH-051008-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	5/10/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	24.26	No	No	
FH-051008-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	5/10/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	10.40	No	No	
FH-051008-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	5/10/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	20.15	No	No	
FH-051008-EBAM10-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	5/10/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	15.95	No	No	
FH-051008-EBAM10-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	5/10/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	11.40	No	No	
FH-051008-TEOM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/10/2008	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	11.64	No	No	
FH-051108-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	5/11/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	17.15	No	No	
FH-051108-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/11/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	36.80	No	No	
FH-051108-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/11/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	14.57	No	No	
FH-051108-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	5/11/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	13.26	No	No	
FH-051108-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	5/11/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	10.99	No	No	
FH-051108-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	5/11/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	24.34	No	No	
FH-051108-EBAM10-07	#7 - 5TH FLOOR SCAFFOLD AT SE CORNER	5/11/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	17.47	No	No	
FH-051108-EBAM10-08	#8 - 5TH FLOOR SCAFFOLD AT NE CORNER	5/11/2008	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	10.91	No	No	
FH-051108-TEOM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	5/11/2008	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	9.92	No	No	

Submittal Summary - Remediation Phase Week 54 (05/05/08 to 05/11/08)

Ohio Lumex Daily Mercury Readings
all readings are in ng/m³

Target air quality level: 300 ng/m³

USEPA site specific mercury trigger level: 3000 ng/m³

Exceedances: None
Exceedances: None

3 Site Tours Conducted per Work Shift

DATE: 5/5/2008

AREA:	TIME:	Tour #:	TOUR AVERAGE:
PERIMETER OF BUILDING	0900-0905	Tour 1	10 10 9 8 11 12 7 11 11 10 9 10 9.83
	1200-1205	Tour 2	10 11 12 12 12 11 11 10 9 12 12 11 11.08
	1500-1505	Tour 3	11 11 11 12 13 10 9 8 11 12 11 12 10.92
5th FLOOR SETBACK	0910-0915	Tour 1	13 13 8 12 10 11 13 8 11 11 10 9 10.75
	1210-1215	Tour 2	13 13 12 10 11 12 11 10 11 11 8 9 10.93
	1510-1515	Tour 3	12 11 11 11 11 10 8 13 14 15 12 13 11.75
ROOF PERIMETER	0925-0930	Tour 1	15 15 13 12 11 10 9 6 10 12 11 11 11.25
	1225-1230	Tour 2	16 11 11 15 15 15 13 14 11 11 13 15 13.33
	1525-1530	Tour 3	15 15 15 14 13 11 11 15 13 15 8 13 13.17

DATE: 5/5/2008 2nd SHIFT

AREA:	TIME:	Tour #:	TOUR AVERAGE:
PERIMETER OF BUILDING	1700-1705	Tour 1	14 14 13 14 14 15 14 14 14 13 13 14 13.83
	2000-2005	Tour 2	13 13 13 14 14 13 13 13 15 15 13 13 13.50
	0000-0005	Tour 3	12 11 13 13 13 12 13 12 12 12 13 14 12.50
5th FLOOR SETBACK	1710-1715	Tour 1	14 13 14 14 14 13 13 13 14 14 13 14 13.58
	2010-2015	Tour 2	15 14 15 15 14 14 14 14 13 14 14 14 14.17
	0010-0015	Tour 3	13 13 13 13 14 13 14 12 12 12 13 13 12.92
ROOF PERIMETER	1725-1730	Tour 1	13 13 12 13 15 15 14 15 13 14 14 13 13.67
	2025-2030	Tour 2	12 12 12 14 13 13 12 12 12 14 13 14 12.75
	0025-0030	Tour 3	13 12 12 13 13 14 12 12 12 13 13 12 12.58

DATE: 5/6/2008

AREA:	TIME:	Tour #:	TOUR AVERAGE:
PERIMETER OF BUILDING	0900-0905	Tour 1	10 10 9 11 10 8 11 11 11 10 10 9 10.00
	1200-1205	Tour 2	9 9 12 13 12 10 12 12 13 11 12 11 11.33
	1500-1505	Tour 3	13 13 13 14 11 13 8 8 10 13 12 11 11.58
5th FLOOR SETBACK	0910-0915	Tour 1	9 12 12 12 11 12 13 10 9 10 11 12 11.08
	1210-1215	Tour 2	10 10 11 12 11 13 10 12 11 9 9 13 10.92
	1510-1515	Tour 3	10 11 11 10 13 12 13 15 11 16 8 15 12.08
ROOF PERIMETER	0925-0930	Tour 1	12 13 13 13 13 10 11 13 15 8 11 11 11.92
	1225-1230	Tour 2	15 15 10 15 13 12 10 15 14 14 13 15 13.42
	1525-1530	Tour 3	10 10 10 8 12 15 16 10 15 15 13 11 12.08

DATE: 5/6/2008 2nd SHIFT

AREA:	TIME:	Tour #:	TOUR AVERAGE:
PERIMETER OF BUILDING	1700-1705	Tour 1	14 13 14 15 15 15 14 14 13 14 14 15 14.17
	2000-2005	Tour 2	14 14 14 14 13 13 15 14 14 13 13 14 13.75
	0000-0005	Tour 3	13 13 14 13 13 15 14 14 13 13 13 13 13.42
5th FLOOR SETBACK	1710-1715	Tour 1	13 14 14 14 13 15 15 13 14 13 14 14 13.83
	2010-2015	Tour 2	14 14 14 13 13 15 13 14 14 11 13 13 13.42
	0010-0015	Tour 3	12 13 13 12 13 14 14 14 13 13 12 14 13.08
ROOF PERIMETER	1725-1730	Tour 1	14 13 14 14 14 14 13 13 14 13 14 13 13.58
	2025-2030	Tour 2	14 14 13 15 14 14 15 13 13 13 14 14 13.83
	0025-0030	Tour 3	13 13 15 11 11 13 13 14 13 14 14 14 13.17

DATE: 5/7/2008

AREA:	TIME:	Tour #:	TOUR AVERAGE:
PERIMETER OF BUILDING	0900-0905	Tour 1	10 9 9 8 11 12 10 10 10 11 9 10 9.92
	1200-1205	Tour 2	9 9 9 10 11 12 11 10 11 11 12 11 10.50
	1500-1505	Tour 3	13 13 12 10 13 13 13 10 11 9 12 10 11.58
5th FLOOR SETBACK	0910-0915	Tour 1	10 10 10 10 9 13 12 13 11 13 10 9 10.83
	1210-1215	Tour 2	12 12 12 12 8 11 12 12 10 12 12 12 11.42
	1510-1515	Tour 3	13 13 13 15 14 10 15 11 13 13 13 13 13.00
ROOF PERIMETER	0925-0930	Tour 1	10 15 16 11 13 12 15 10 11 12 10 9 12.00
	1225-1230	Tour 2	16 16 16 14 16 16 16 11 10 11 12 16 14.17
	1525-1530	Tour 3	17 16 17 16 16 16 16 10 11 8 15 14 14.33

DATE: 5/7/2008 2nd SHIFT

AREA:	TIME:	Tour #:	TOUR AVERAGE:
PERIMETER OF BUILDING	1700-1705	Tour 1	14 13 14 14 13 13 13 13 14 13 14 14 13.50
	2000-2005	Tour 2	11 11 11 13 14 13 13 13 12 12 13 14 12.50
	0000-0005	Tour 3	13 13 11 13 13 12 12 12 12 12 13 13 12.42
5th FLOOR SETBACK	1710-1715	Tour 1	13 14 14 13 13 13 14 14 14 13 14 14 13.58
	2010-2015	Tour 2	12 12 13 12 13 13 13 12 12 12 13 12 12.42
	0010-0015	Tour 3	11 12 12 12 11 11 13 14 13 13 14 13 12.42
ROOF PERIMETER	1725-1730	Tour 1	14 14 14 14 13 13 14 13 14 14 13 13 13.58
	2025-2030	Tour 2	13 14 13 13 12 13 12 12 12 13 14 14 12.92
	0025-0030	Tour 3	11 12 11 12 11 11 12 12 12 13 11 11 11.58

DATE: 5/8/2008

AREA:	TIME:	Tour #:	TOUR AVERAGE:
PERIMETER OF BUILDING	0900-0905	Tour 1	11 12 13 13 12 11 12 9 9 10 11 12 11.25
	1200-1205	Tour 2	11 12 13 13 13 13 10 13 10 11 11 12 11.83
	1500-1505	Tour 3	10 10 10 9 10 12 13 13 12 11 12 13 11.25
5th FLOOR SETBACK	0910-0915	Tour 1	12 12 12 13 11 11 10 9 10 11 12 13 11.33
	1210-1215	Tour 2	12 12 13 13 13 12 11 12 10 9 9 9 11.25
	1510-1515	Tour 3	9 10 10 11 12 12 13 14 13 11 12 10 11.42
ROOF PERIMETER	0925-0930	Tour 1	10 10 11 12 13 13 12 11 11 11 10 9 11.08
	1225-1230	Tour 2	11 11 12 13 14 15 14 14 13 13 12 12 12.83
	1525-1530	Tour 3	12 13 12 12 12 11 11 10 10 9 11 10 11.08

DATE: 5/8/2008 2nd SHIFT

AREA:	TIME:	Tour #:	TOUR AVERAGE:
PERIMETER OF BUILDING	1700-1705	Tour 1	13 13 12 13 14 13 13 14 13 14 14 13 13.25
	2000-2005	Tour 2	12 12 12 13 13 14 14 16 13 13 12 13 13.08
	0000-0005	Tour 3	13 11 12 12 12 12 13 13 12 12 13 11 12.17
5th FLOOR SETBACK	1710-1715	Tour 1	13 12 13 13 14 14 14 11 12 11 13 11 12.58
	2010-2015	Tour 2	13 13 13 13 12 12 13 13 13 11 13 12 12.58
	0010-0015	Tour 3	12 11 12 12 13 12 12 11 11 13 13 12 12.00
ROOF PERIMETER	1725-1730	Tour 1	11 12 12 11 12 13 13 12 12 13 12 11 12.00
	2025-2030	Tour 2	12 11 12 12 12 13 12 13 13 13 12 12 12.25
	0025-0030	Tour 3	12 13 12 12 12 11 11 10 10 9 11 10 11.58

DATE: 5/9/2008

AREA:	TIME:	Tour #:	TOUR AVERAGE:
PERIMETER OF BUILDING	0900-0905	Tour 1	10 10 10 8 10 10 11 11 10 9 10 9 9.33
	1200-1205	Tour 2	11 12 11 12 13 12 12 11 13 8 11 11 11.42
	1500-1505	Tour 3	12 12 11 12 13 12 8 12 13 12 11 10 11.50
5th FLOOR SETBACK	0910-0915	Tour 1	11 12 12 11 12 11 8 10 11 10 12 11 10.92
	1210-1215	Tour 2	13 8 13 13 13 11 10 8 7 8 13 13 10.83
	1510-1515	Tour 3	12 12 11 12 13 13 13 13 12 13 11 13 12.33
ROOF PERIMETER	0925-0930	Tour 1	13 14 10 15 8 15 15 14 16 15 11 10 13.00
	1225-1230	Tour 2	13 13 13 11 10 15 8 10 11 12 14 15 12.08
	1525-1530	Tour 3	15 14 13 12 11 15 14 13 13 13 12 11 13.00

DATE: 5/9/2008 2nd SHIFT

AREA:	TIME:	Tour #:	TOUR AVERAGE:
PERIMETER OF BUILDING	1700-1705	Tour 1	11 11 11 12 11 12 12 10 10 10 11 10 10.92
	2000-2005	Tour 2	10 10 10 9 10 9 9 10 11 10 11 9 9.83
	0000-0005	Tour 3	10 10 11 10 10 11 11 11 10 9 10 10 10.25
5th FLOOR SETBACK	1710-1715	Tour 1	10 9 10 10 9 9 9 11 10 11 10 11 9.92
	2010-2015	Tour 2	9 9 9 10 10 9 11 11 11 10 10 9 9.83
	0010-0015	Tour 3	10 9 10 10 10 9 9 10 10 10 11 10 9.83
ROOF PERIMETER	1725-1730	Tour 1	9 9 8 10 10 9 10 11 11 10 10 10 9.75
	2025-2030	Tour 2	9 10 9 10 9 9 9 10 11 11 10 11 9.83
	0025-0030	Tour 3	10 9 10 10 10 9 9 11 11 10 10 10 9.92

DATE: 5/10/2008

AREA:	TIME:	Tour #:	TOUR AVERAGE:
PERIMETER OF BUILDING	0900-0905	Tour 1	11 12 11 11 13 8 8 11 11 12 11 14 11.17
	1200-1205	Tour 2	10 11 11 12 11 11 13 11 11 10 11 12 11.17
	1500-1505	Tour 3	11 9 9 10 11 11 14 11 11 12 10 9 10.67
5th FLOOR SETBACK	0910-0915	Tour 1	10 11 12 12 12 13 12 12 11 11 12 11 11.58
	1210-1215	Tour 2	11 10 10 10 11 10 9 12 12 12 12 11 10.83
	1510-1515	Tour 3	13 11 11 11 10 11 10 11 10 10 13 12 11.08
ROOF PERIMETER	0925-0930	Tour 1	13 13 14 14 13 12 11 10 10 11 12 11 12.00
	1225-1230	Tour 2	11 13 13 15 13 12 12 11 11 10 9 11 11.75
	1525-1530	Tour 3	10 10 11 12 11 13 13 11 10 9 10 10 10.93

DATE: 5/11/2008

AREA:	TIME:	Tour #:	TOUR AVERAGE:
PERIMETER OF BUILDING	0900-0905	Tour 1	10 10 10 8 9 11 10 12 11 9 10 11 10.00
	1200-1205	Tour 2	11 11 8 12 13 11 10 10 10 10 9 10 10.42
	1500-1505	Tour 3	11 10 11 10 13 13 8 10 11 10 12 10 10.75
5th FLOOR SETBACK	0910-0915	Tour 1	10 13 14 15 10 8 9 11 12 11 13 11 11.42
	1210-1215	Tour 2	10 14 10 11 13 13 12 13 8 13 11 10 12.00
	1510-1515	Tour 3	11 11 14 11 10 12 11 16 11 13 8 9 11.42
ROOF PERIMETER	0925-0930	Tour 1	10 10 11 11 15 15 14 15 8 16 15 11 12.58
	1225-1230	Tour 2	16 16 10 15 14 13 12 11 8 10 15 16 13.00
	1525-1530	Tour 3	15 15 16 15 11 10 15 16 13 15 14 14 14.08

5th FLOOR SETBACK	1210-1215	Tour 2	13 13 12 12 12 13 14 14 14 13 12 14 13.00
ROOF PERIMETER	1510-1515	Tour 3	14 13 14 13 13 12 13 14 14 13 14 14 13.42
ROOF PERIMETER	0925-0930	Tour 1	12 12 11 11 11 12 12 13 11 12 12 13 11.83
ROOF PERIMETER	1225-1230	Tour 2	13 13 14 14 14 14 13 13 13 11 13 13 13.17
ROOF PERIMETER	1525-1530	Tour 3	13 14 14 14 13 13 12 12 13 14 14 13 13.25

Submittal Summary - Remediation Phase Week 54 (05/05/08 to 05/11/08)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Work Shift/Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	Silica-Quartz Concentration (ug/m ³)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											10				
EPA Site Specific Trigger Levels											10				
EMSL	FH-050508-30	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	05/05/2008	Remediation	2.880	040810871-0001	05/06/2008	05/08/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/09/2008	No	No	
EMSL	FH-050508-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	05/05/2008	Remediation	2.870	040810871-0002	05/06/2008	05/08/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/09/2008	No	No	
EMSL	FH-050508-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	05/05/2008	Remediation	2.874	040810871-0003	05/06/2008	05/08/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/09/2008	No	No	
EMSL	FH-050508-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	05/05/2008	Remediation	2.874	040810871-0004	05/06/2008	05/08/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/09/2008	No	No	
EMSL	FH-050508-33	#5 - 5TH FL SETBACK ROOF N. SIDE	05/05/2008	Remediation	2.876	040810871-0005	05/06/2008	05/08/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/09/2008	No	No	
EMSL	FH-050508-34	#6 - 5TH FL SETBACK ROOF SW SIDE	05/05/2008	Remediation	2.874	040810871-0006	05/06/2008	05/08/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/09/2008	No	No	
EMSL	FH-050508-35	#7 - 5TH FL SCAFFOLD AT SE CORNER	05/05/2008	Remediation	2.872	040810871-0007	05/06/2008	05/08/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/09/2008	No	No	
EMSL	FH-050508-36	#8 - 5TH FL SCAFFOLD AT NE CORNER	05/05/2008	Remediation	2.876	040810871-0008	05/06/2008	05/08/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/09/2008	No	No	
EMSL	FH-050608-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	05/06/2008	Remediation	2.888	040810998-0001	05/06/2008	05/09/2008	NIOSH 7500 XRD	Silica-Quartz	<7	05/09/2008	No	No	See Note 1
EMSL	FH-050608-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	05/06/2008	Remediation	2.884	040810998-0002	05/06/2008	05/09/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/09/2008	No	No	
EMSL	FH-050608-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	05/06/2008	Remediation	2.884	040810998-0003	05/06/2008	05/09/2008	NIOSH 7500 XRD	Silica-Quartz	3	05/09/2008	No	No	
EMSL	FH-050608-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	05/06/2008	Remediation	2.886	040810998-0004	05/06/2008	05/09/2008	NIOSH 7500 XRD	Silica-Quartz	4	05/09/2008	No	No	
EMSL	FH-050608-33	#5 - 5TH FL SETBACK ROOF N. SIDE	05/06/2008	Remediation	2.888	040810998-0005	05/06/2008	05/09/2008	NIOSH 7500 XRD	Silica-Quartz	3	05/09/2008	No	No	
EMSL	FH-050608-34	#6 - 5TH FL SETBACK ROOF SW SIDE	05/06/2008	Remediation	2.886	040810998-0006	05/06/2008	05/09/2008	NIOSH 7500 XRD	Silica-Quartz	5	05/09/2008	No	No	
EMSL	FH-050608-35	#7 - 5TH FL SCAFFOLD AT SE CORNER	05/06/2008	Remediation	2.882	040810998-0007	05/06/2008	05/09/2008	NIOSH 7500 XRD	Silica-Quartz	2	05/09/2008	No	No	
EMSL	FH-050608-36	#8 - 5TH FL SCAFFOLD AT NE CORNER	05/06/2008	Remediation	2.886	040810998-0008	05/06/2008	05/09/2008	NIOSH 7500 XRD	Silica-Quartz	3	05/09/2008	No	No	
EMSL	FH-050608-68	DUPLICATE (STATION #1)	05/06/2008	Remediation	2.888	040810998-0010	05/06/2008	05/09/2008	NIOSH 7500 XRD	Silica-Quartz	3	05/09/2008	No	No	
EMSL	FH-050708-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	05/07/2008	Remediation	2.870	040811134-0001	05/09/2008	05/12/2008	NIOSH 7500 XRD	Silica-Quartz	<7	05/09/2008	No	No	See Note 1
EMSL	FH-050708-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	05/07/2008	Remediation	2.878	040811134-0002	05/09/2008	05/12/2008	NIOSH 7500 XRD	Silica-Quartz	2	05/09/2008	No	No	
EMSL	FH-050708-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	05/07/2008	Remediation	2.876	040811134-0003	05/09/2008	05/12/2008	NIOSH 7500 XRD	Silica-Quartz	2	05/09/2008	No	No	
EMSL	FH-050708-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	05/07/2008	Remediation	2.874	040811134-0004	05/09/2008	05/12/2008	NIOSH 7500 XRD	Silica-Quartz	<7	05/09/2008	No	No	See Note 1
EMSL	FH-050708-33	#5 - 5TH FL SETBACK ROOF N. SIDE	05/07/2008	Remediation	2.872	040811134-0005	05/09/2008	05/12/2008	NIOSH 7500 XRD	Silica-Quartz	4	05/09/2008	No	No	
EMSL	FH-050708-34	#6 - 5TH FL SETBACK ROOF SW SIDE	05/07/2008	Remediation	2.874	040811134-0006	05/09/2008	05/12/2008	NIOSH 7500 XRD	Silica-Quartz	3	05/09/2008	No	No	
EMSL	FH-050708-35	#7 - 5TH FL SCAFFOLD AT SE CORNER	05/07/2008	Remediation	2.880	040811134-0007	05/09/2008	05/12/2008	NIOSH 7500 XRD	Silica-Quartz	<7	05/09/2008	No	No	See Note 1
EMSL	FH-050708-36	#8 - 5TH FL SCAFFOLD AT NE CORNER	05/07/2008	Remediation	2.874	040811134-0008	05/09/2008	05/12/2008	NIOSH 7500 XRD	Silica-Quartz	<7	05/09/2008	No	No	See Note 1
EMSL	FH-050808-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	05/08/2008	Remediation	2.866	040811268-0001	05/10/2008	05/13/2008	NIOSH 7500 XRD	Silica-Quartz	3	05/09/2008	No	No	
EMSL	FH-050808-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	05/08/2008	Remediation	2.872	040811268-0002	05/10/2008	05/13/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/09/2008	No	No	
EMSL	FH-050808-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	05/08/2008	Remediation	2.868	040811268-0003	05/10/2008	05/13/2008	NIOSH 7500 XRD	Silica-Quartz	2	05/09/2008	No	No	
EMSL	FH-050808-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	05/08/2008	Remediation	2.866	040811268-0004	05/10/2008	05/13/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/09/2008	No	No	
EMSL	FH-050808-33	#5 - 5TH FL SETBACK ROOF N. SIDE	05/08/2008	Remediation	2.870	040811268-0005	05/10/2008	05/13/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/09/2008	No	No	
EMSL	FH-050808-34	#6 - 5TH FL SETBACK ROOF SW SIDE	05/08/2008	Remediation	2.868	040811268-0006	05/10/2008	05/13/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/09/2008	No	No	
EMSL	FH-050808-35	#7 - 5TH FL SCAFFOLD AT SE CORNER	05/08/2008	Remediation	2.868	040811268-0007	05/10/2008	05/13/2008	NIOSH 7500 XRD	Silica-Quartz	2	05/09/2008	No	No	
EMSL	FH-050808-36	#8 - 5TH FL SCAFFOLD AT NE CORNER	05/08/2008	Remediation	2.868	040811268-0008	05/10/2008	05/13/2008	NIOSH 7500 XRD	Silica-Quartz	2	05/09/2008	No	No	
EMSL	FH-050908-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	05/09/2008	Remediation	2.888	040811399-0001	05/13/2008	05/15/2008	NIOSH 7500 XRD	Silica-Quartz	2	05/15/2008	No	No	
EMSL	FH-050908-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	05/09/2008	Remediation	2.876	040811399-0002	05/13/2008	05/15/2008	NIOSH 7500 XRD	Silica-Quartz	9	05/15/2008	No	No	
EMSL	FH-050908-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	05/09/2008	Remediation	2.878	040811399-0003	05/13/2008	05/15/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/15/2008	No	No	
EMSL	FH-050908-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	05/09/2008	Remediation	2.882	040811399-0004	05/13/2008	05/15/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/15/2008	No	No	
EMSL	FH-050908-33	#5 - 5TH FL SETBACK ROOF N. SIDE	05/09/2008	Remediation	2.882	040811399-0005	05/13/2008	05/15/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/15/2008	No	No	
EMSL	FH-050908-34	#6 - 5TH FL SETBACK ROOF SW SIDE	05/09/2008	Remediation	2.884	040811399-0006	05/13/2008	05/15/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/15/2008	No	No	
EMSL	FH-050908-35	#7 - 5TH FL SCAFFOLD AT SE CORNER	05/09/2008	Remediation	2.878	040811399-0007	05/13/2008	05/15/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/15/2008	No	No	
EMSL	FH-050908-36	#8 - 5TH FL SCAFFOLD AT NE CORNER	05/09/2008	Remediation	2.884	040811399-0008	05/13/2008	05/15/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/15/2008	No	No	
EMSL	FH-051008-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	05/10/2008	Remediation	2.886	040811406-0001	05/13/2008	05/15/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/15/2008	No	No	
EMSL	FH-051008-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	05/10/2008	Remediation	2.868	040811406-0002	05/13/2008	05/15/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/15/2008	No	No	
EMSL	FH-051008-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	05/10/2008	Remediation	2.876	040811406-0003	05/13/2008	05/15/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/15/2008	No	No	
EMSL	FH-051008-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	05/10/2008	Remediation	2.878	040811406-0004	05/13/2008	05/15/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/15/2008	No	No	
EMSL	FH-051008-33	#5 - 5TH FL SETBACK ROOF N. SIDE	05/10/2008	Remediation	2.882	040811406-0005	05/13/2008	05/15/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/15/2008	No	No	
EMSL	FH-051008-34	#6 - 5TH FL SETBACK ROOF SW SIDE	05/10/2008	Remediation	2.872	040811406-0006	05/13/2008	05/15/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/15/2008	No	No	
EMSL	FH-051008-35	#7 - 5TH FL SCAFFOLD AT SE CORNER	05/10/2008	Remediation	2.872	040811406-0007	05/13/2008	05/15/2008	NIOSH 7500 XRD	Silica-Quartz	2	05/15/2008	No	No	
EMSL	FH-051008-36	#8 - 5TH FL SCAFFOLD AT NE CORNER	05/10/2008	Remediation	2.886	040811406-0008	05/13/2008	05/15/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/15/2008	No	No	
EMSL	FH-051108-29	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	05/11/2008	Remediation	2.886	040811400-0001	05/13/2008	05/16/2008	NIOSH 7500 XRD	Silica-Quartz	2	05/16/2008	No	No	
EMSL	FH-051108-30	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	05/11/2008	Remediation	2.890	040811400-0002	05/13/2008	05/16/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/16/2008	No	No	
EMSL	FH-051108-31	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	05/11/2008	Remediation	2.886	040811400-0003	05/13/2008	05/16/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/16/2008	No	No	
EMSL	FH-051108-32	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	05/11/2008	Remediation	2.886	040811400-0004	05/13/2008	05/16/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/16/2008	No	No	
EMSL	FH-051108-33	#5 - 5TH FL SETBACK ROOF N. SIDE	05/11/2008	Remediation	2.886	040811400-0005	05/13/2008	05/16/2008	NIOSH 7500 XRD	Silica-Quartz	3	05/16/2008	No	No	
EMSL	FH-051108-34	#6 - 5TH FL SETBACK ROOF SW SIDE	05/11/2008	Remediation	2.884	040811400-0006	05/13/2008	05/16/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/16/2008	No	No	
EMSL	FH-051108-35	#7 - 5TH FL SCAFFOLD AT SE CORNER	05/11/2008	Remediation	2.888	040811400-0007	05/13/2008	05/16/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/16/2008	No	No	
EMSL	FH-051108-36	#8 - 5TH FL SCAFFOLD AT NE CORNER	05/11/2008	Remediation	2.886	040811400-0008	05/13/2008	05/16/2008	NIOSH 7500 XRD	Silica-Quartz	<2	05/16/2008	No	No	

Note 1: Secondary quartz peak used for sample due to suspected primary peak interference.

Submittal Summary - Remediation Phase Week 54 (05/05/08 to 05/11/08)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	Dioxin/Furans Concentration (ng/m ³)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											0.00025				
EPA Site Specific Trigger Levels											0.025				
STL-SAC	FH-050708-40	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/7/2008	Remediation	360	G8E090385003	05/09/2008	05/23/2008	TO-9	Toxicity Equivalent Quotient (TEQ)	0.0000174	05/27/2008	No	No	

Submittal Summary - Remediation Phase Week 54 (05/05/08 to 05/11/08)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	PAHs Concentration (ug/m3)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											0.034				
EPA Site Specific Trigger Levels											3.4				
STL-SAC	FH-050708-49	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/7/2008	Remediation	360	G8E090386003	05/09/2008	05/19/2008	8270C SIM	BAP-equivalent	<0.007	05/21/2008	No	No	

Submittal Summary - Remediation Phase Week 54 (05/05/08 to 05/11/08)

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m ³)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	PCBs Concentration (ug/m3)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											0.12				
EPA Site Specific Trigger Levels											12				
STL-SAC	FH-050708-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/7/2008	Remediation	360	G8E090384003	05/09/2008	05/21/2008	TO-4	Aroclor 1016	<0.0021	05/23/2008	No	No	
STL-SAC	FH-050708-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/7/2008	Remediation	360	G8E090384003	05/09/2008	05/21/2008	TO-4	Aroclor 1221	<0.0021	05/23/2008	No	No	
STL-SAC	FH-050708-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/7/2008	Remediation	360	G8E090384003	05/09/2008	05/21/2008	TO-4	Aroclor 1232	<0.0021	05/23/2008	No	No	
STL-SAC	FH-050708-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/7/2008	Remediation	360	G8E090384003	05/09/2008	05/21/2008	TO-4	Aroclor 1242	<0.0021	05/23/2008	No	No	
STL-SAC	FH-050708-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/7/2008	Remediation	360	G8E090384003	05/09/2008	05/21/2008	TO-4	Aroclor 1248	<0.0021	05/23/2008	No	No	
STL-SAC	FH-050708-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/7/2008	Remediation	360	G8E090384003	05/09/2008	05/21/2008	TO-4	Aroclor 1254	<0.0021	05/23/2008	No	No	
STL-SAC	FH-050708-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	5/7/2008	Remediation	360	G8E090384003	05/09/2008	05/21/2008	TO-4	Aroclor 1260	<0.0021	05/23/2008	No	No	