

**Submittal Summary - Scaffold Phase Week Seven (06/11/07 to 06/17/07)**

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Work Shift/Project Phase	Sample Volume (m <sup>3</sup> )	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	Asbestos PCME Concentration (f/cm <sup>3</sup> )	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											0.0009				
EPA Site Specific Trigger Levels											N/A				
EMSL	FH-061107-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/11/2007	1/Scaffold	2.880	030718757-0001	6/11/2007	6/13/2007	PCME	ASBESTOS	<0.00079	6/13/2007	No	No	
EMSL	FH-061107-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/11/2007	1/Scaffold	2.880	030718757-0002	6/11/2007	6/13/2007	PCME	ASBESTOS	<0.00079	6/13/2007	No	No	
EMSL	FH-061107-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/11/2007	1/Scaffold	2.880	030718757-0003	6/11/2007	6/13/2007	PCME	ASBESTOS	<0.00079	6/13/2007	No	No	
EMSL	FH-061107-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/11/2007	1/Scaffold	2.880	030718757-0004	6/11/2007	6/13/2007	PCME	ASBESTOS	<0.00079	6/13/2007	No	No	
EMSL	FH-061107-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/11/2007	1/Scaffold	2.880	030718757-0005	6/11/2007	6/13/2007	PCME	ASBESTOS	<0.00079	6/13/2007	No	No	
EMSL	FH-061107-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/11/2007	1/Scaffold	2.880	030718757-0006	6/11/2007	6/13/2007	PCME	ASBESTOS	<0.00079	6/13/2007	No	No	
EMSL	FH-061207-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/12/2007	1/Scaffold	2.880	030718927-0001	6/12/2007	6/14/2007	PCME	ASBESTOS	<0.00079	6/14/2007	No	No	
EMSL	FH-061207-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/12/2007	1/Scaffold	2.880	030718927-0002	6/12/2007	6/14/2007	PCME	ASBESTOS	<0.00079	6/14/2007	No	No	
EMSL	FH-061207-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/12/2007	1/Scaffold	2.880	030718927-0003	6/12/2007	6/14/2007	PCME	ASBESTOS	<0.00079	6/14/2007	No	No	
EMSL	FH-061207-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/12/2007	1/Scaffold	2.880	030718927-0004	6/12/2007	6/14/2007	PCME	ASBESTOS	<0.00079	6/14/2007	No	No	
EMSL	FH-061207-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/12/2007	1/Scaffold	2.880	030718927-0005	6/12/2007	6/14/2007	PCME	ASBESTOS	<0.00079	6/14/2007	No	No	
EMSL	FH-061207-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/12/2007	1/Scaffold	2.880	030718927-0006	6/12/2007	6/14/2007	PCME	ASBESTOS	<0.00079	6/14/2007	No	No	
EMSL	FH-061207-65	DUPLICATE (STATION #1)	6/12/2007	1/Scaffold	2.880	030718927-0007	6/12/2007	6/14/2007	PCME	ASBESTOS	<0.00079	6/14/2007	No	No	
EMSL	FH-061307-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/13/2007	1/Scaffold	2.880	030719084-0001	6/13/2007	6/14/2007	PCME	ASBESTOS	<0.00086	6/14/2007	No	No	
EMSL	FH-061307-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/13/2007	1/Scaffold	2.880	030719084-0002	6/13/2007	6/14/2007	PCME	ASBESTOS	<0.00086	6/14/2007	No	No	
EMSL	FH-061307-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/13/2007	1/Scaffold	2.880	030719084-0003	6/13/2007	6/14/2007	PCME	ASBESTOS	<0.00086	6/14/2007	No	No	
EMSL	FH-061307-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/13/2007	1/Scaffold	2.880	030719084-0004	6/13/2007	6/14/2007	PCME	ASBESTOS	<0.00086	6/14/2007	No	No	
EMSL	FH-061307-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/13/2007	1/Scaffold	2.880	030719084-0005	6/13/2007	6/14/2007	PCME	ASBESTOS	<0.00086	6/14/2007	No	No	
EMSL	FH-061307-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/13/2007	1/Scaffold	2.880	030719084-0006	6/13/2007	6/14/2007	PCME	ASBESTOS	<0.00086	6/14/2007	No	No	
EMSL	FH-061407-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/14/2007	1/Scaffold	2.880	030719238-0001	6/14/2007	6/15/2007	PCME	ASBESTOS	<0.00079	6/15/2007	No	No	
EMSL	FH-061407-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/14/2007	1/Scaffold	2.880	030719238-0002	6/14/2007	6/15/2007	PCME	ASBESTOS	<0.00086	6/15/2007	No	No	
EMSL	FH-061407-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/14/2007	1/Scaffold	2.880	030719238-0003	6/14/2007	6/15/2007	PCME	ASBESTOS	<0.00079	6/15/2007	No	No	
EMSL	FH-061407-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/14/2007	1/Scaffold	2.880	030719238-0004	6/14/2007	6/15/2007	PCME	ASBESTOS	<0.00086	6/15/2007	No	No	
EMSL	FH-061407-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/14/2007	1/Scaffold	2.880	030719238-0005	6/14/2007	6/15/2007	PCME	ASBESTOS	<0.00086	6/15/2007	No	No	
EMSL	FH-061407-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/14/2007	1/Scaffold	2.880	030719238-0006	6/14/2007	6/15/2007	PCME	ASBESTOS	<0.00086	6/15/2007	No	No	
EMSL	FH-061507-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/15/2007	1/Scaffold	2.880	030719389-0001	6/15/2007	6/16/2007	PCME	ASBESTOS	<0.00086	6/18/2007	No	No	
EMSL	FH-061507-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/15/2007	1/Scaffold	2.880	030719389-0002	6/15/2007	6/16/2007	PCME	ASBESTOS	<0.00086	6/18/2007	No	No	
EMSL	FH-061507-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/15/2007	1/Scaffold	2.880	030719389-0003	6/15/2007	6/16/2007	PCME	ASBESTOS	<0.00086	6/18/2007	No	No	
EMSL	FH-061507-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/15/2007	1/Scaffold	2.880	030719389-0004	6/15/2007	6/16/2007	PCME	ASBESTOS	<0.00086	6/18/2007	No	No	
EMSL	FH-061507-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/15/2007	1/Scaffold	2.880	030719389-0005	6/15/2007	6/16/2007	PCME	ASBESTOS	<0.00086	6/18/2007	No	No	
EMSL	FH-061507-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/15/2007	1/Scaffold	2.880	030719389-0006	6/15/2007	6/16/2007	PCME	ASBESTOS	<0.00086	6/18/2007	No	No	
EMSL	FH-061607-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/16/2007	1/Scaffold	2.880	030719706-0001	6/18/2007	6/19/2007	PCME	ASBESTOS	<0.00079	6/19/2007	No	No	
EMSL	FH-061607-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/16/2007	1/Scaffold	2.880	030719706-0002	6/18/2007	6/19/2007	PCME	ASBESTOS	<0.00079	6/19/2007	No	No	
EMSL	FH-061607-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/16/2007	1/Scaffold	2.880	030719706-0003	6/18/2007	6/19/2007	PCME	ASBESTOS	<0.00079	6/19/2007	No	No	
EMSL	FH-061607-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/16/2007	1/Scaffold	2.880	030719706-0004	6/18/2007	6/19/2007	PCME	ASBESTOS	<0.00079	6/19/2007	No	No	
EMSL	FH-061607-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/16/2007	1/Scaffold	2.880	030719706-0005	6/18/2007	6/19/2007	PCME	ASBESTOS	<0.00079	6/19/2007	No	No	
EMSL	FH-061607-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/16/2007	1/Scaffold	2.880	030719706-0006	6/18/2007	6/19/2007	PCME	ASBESTOS	<0.00079	6/19/2007	No	No	
EMSL	FH-061707-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/17/2007	1/Scaffold	2.880	030719709-0001	6/18/2007	6/19/2007	PCME	ASBESTOS	<0.00079	6/19/2007	No	No	
EMSL	FH-061707-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/17/2007	1/Scaffold	2.880	030719709-0002	6/18/2007	6/19/2007	PCME	ASBESTOS	<0.00079	6/19/2007	No	No	
EMSL	FH-061707-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/17/2007	1/Scaffold	2.880	030719709-0003	6/18/2007	6/19/2007	PCME	ASBESTOS	<0.00079	6/19/2007	No	No	
EMSL	FH-061707-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/17/2007	1/Scaffold	2.880	030719709-0004	6/18/2007	6/19/2007	PCME	ASBESTOS	<0.00079	6/19/2007	No	No	
EMSL	FH-061707-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/17/2007	1/Scaffold	2.880	030719709-0005	6/18/2007	6/19/2007	PCME	ASBESTOS	<0.00079	6/19/2007	No	No	
EMSL	FH-061707-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/17/2007	1/Scaffold	2.880	030719709-0006	6/18/2007	6/19/2007	PCME	ASBESTOS	<0.00079	6/19/2007	No	No	



**Submittal Summary - Scaffold Phase Week Seven (06/11/07 to 06/17/07)**

Airtek Field Sample No.	Sampling Location	Real-time Readings Date	Collection time (minutes)	Analyte	Analytical Method	Instrument	Particulate PM 2.5 (ug/m <sup>3</sup> )	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
<b>Target Air Quality Levels</b>							<b>40</b>			
<b>EPA Site Specific Trigger Levels</b>							<b>65</b>			
FH-061107-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/11/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	11.23	No	No	
FH-061107-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/11/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	13.86	No	No	
FH-061107-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/11/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	28.35	No	No	
FH-061107-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/11/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	15.48	No	No	
FH-061107-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/11/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	12.77	No	No	
FH-061107-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/11/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	11.99	No	No	
FH-061107-TEOM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/11/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	9.35	No	No	
FH-061207-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/12/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	15.26	No	No	
FH-061207-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/12/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	21.34	No	No	
FH-061207-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/12/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	39.12	No	No	
FH-061207-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/12/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	22.10	No	No	
FH-061207-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/12/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	16.79	No	No	
FH-061207-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/12/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	15.99	No	No	
FH-061207-TEOM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/12/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	9.09	No	No	
FH-061307-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/13/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	11.63	No	No	
FH-061307-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/13/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	12.68	No	No	
FH-061307-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/13/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	25.12	No	No	
FH-061307-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/13/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	18.25	No	No	
FH-061307-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/13/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	12.73	No	No	
FH-061307-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/13/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	11.98	No	No	
FH-061307-TEOM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/13/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	5.76	No	No	
FH-061407-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/14/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	6.15	No	No	
FH-061407-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/14/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	8.99	No	No	
FH-061407-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/14/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	23.63	No	No	
FH-061407-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/14/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	25.88	No	No	
FH-061407-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/14/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	11.18	No	No	
FH-061407-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/14/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	7.33	No	No	
FH-061407-TEOM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/14/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	5.43	No	No	
FH-061507-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/15/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	12.08	No	No	
FH-061507-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/15/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	19.00	No	No	
FH-061507-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/15/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	19.56	No	No	
FH-061507-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/15/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	18.88	No	No	
FH-061507-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/15/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	13.33	No	No	
FH-061507-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/15/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	11.20	No	No	
FH-061507-TEOM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/15/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	14.55	No	No	
FH-061607-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/16/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	18.24	No	No	
FH-061607-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/16/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	17.37	No	No	
FH-061607-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/16/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	29.85	No	No	
FH-061607-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/16/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	18.73	No	No	
FH-061607-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/16/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	21.22	No	No	
FH-061607-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/16/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	18.87	No	No	
FH-061607-TEOM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/16/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	14.94	No	No	
FH-061707-EBAM2.5-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/17/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	18.99	No	No	
FH-061707-EBAM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/17/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	14.28	No	No	
FH-061707-EBAM2.5-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/17/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	29.99	No	No	
FH-061707-EBAM2.5-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/17/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	25.94	No	No	
FH-061707-EBAM2.5-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/17/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	14.35	No	No	
FH-061707-EBAM2.5-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/17/2007	1440	Particulate 2.5	Direct Real-time Readings	MetOne EBAM PM 2.5	20.83	No	No	
FH-061707-TEOM2.5-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/17/2007	1440	Particulate 2.5	Direct Real-time Readings	TEOM PM 2.5	16.84	No	No	

**Submittal Summary - Scaffold Phase Week Seven (06/11/07 to 06/17/07)**

Airtek Field Sample No.	Sampling Location	Real-time Readings Date	Collection time (minutes)	Analyte	Analytical Method	Instrument	Particulate PM 10 (ug/m <sup>3</sup> )	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments	
							<b>150</b>				
<b>Target Air Quality Levels</b>											
<b>EPA Site Specific Trigger Levels</b>							<b>150</b>				
FH-061107-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/11/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	36.12	No	No		
FH-061107-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/11/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	34.41	No	No		
FH-061107-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/11/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	36.44	No	No		
FH-061107-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/11/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	27.21	No	No		
FH-061107-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/11/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	25.66	No	No		
FH-061107-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/11/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	25.88	No	No		
FH-061107-TEOM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/11/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	30.86	No	No		
FH-061207-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/12/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	64.90	No	No		
FH-061207-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/12/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	25.69	No	No		
FH-061207-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/12/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	28.19	No	No		
FH-061207-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/12/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	28.67	No	No		
FH-061207-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/12/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	26.90	No	No		
FH-061207-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/12/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	25.87	No	No		
FH-061207-TEOM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/12/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	33.41	No	No		
FH-061307-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/13/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	29.29	No	No		
FH-061307-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/13/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	18.99	No	No		
FH-061307-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/13/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	20.69	No	No		
FH-061307-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/13/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	19.85	No	No		
FH-061307-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/13/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	21.45	No	No		
FH-061307-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/13/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	19.02	No	No		
FH-061307-TEOM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/13/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	26.39	No	No		
FH-061407-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/14/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	17.78	No	No		
FH-061407-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/14/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	15.39	No	No		
FH-061407-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/14/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	18.81	No	No		
FH-061407-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/14/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	27.01	No	No		
FH-061407-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/14/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	17.57	No	No		
FH-061407-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/14/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	16.53	No	No		
FH-061407-TEOM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/14/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	21.40	No	No		
FH-061507-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/15/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	51.56	No	No		
FH-061507-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/15/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	40.77	No	No		
FH-061507-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/15/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	68.58	No	No		
FH-061507-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/15/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	44.51	No	No		
FH-061507-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/15/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	23.22	No	No		
FH-061507-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/15/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	26.88	No	No		
FH-061507-TEOM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/15/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	33.80	No	No		
FH-061607-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/16/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	47.55	No	No		
FH-061607-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/16/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	23.47	No	No		
FH-061607-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/16/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	29.16	No	No		
FH-061607-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/16/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	29.35	No	No		
FH-061607-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/16/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	39.17	No	No		
FH-061607-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/16/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	32.56	No	No		
FH-061607-TEOM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/16/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	39.42	No	No		
FH-061707-EBAM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/17/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	36.76	No	No		
FH-061707-EBAM10-02	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/17/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	10.53	No	No		
FH-061707-EBAM10-03	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/17/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	32.53	No	No		
FH-061707-EBAM10-04	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/17/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	29.99	No	No		
FH-061707-EBAM10-05	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/17/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	38.13	No	No		
FH-061707-EBAM10-06	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/17/2007	1440	Particulate 10	Direct Real-time Readings	MetOne EBAM PM 10	28.86	No	No		
FH-061707-TEOM10-01	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/17/2007	1440	Particulate 10	Direct Real-time Readings	TEOM PM 10	44.75	No	No		



**Submittal Summary - Scaffold Phase Week Seven (06/11/07 to 06/17/07)**

Ohio Lumex Daily Mercury Readings

all readings are in ng/m<sup>3</sup>

Target air quality level: 300 ng/m<sup>3</sup>

USEPA site specific mercury trigger level: 3000 ng/m<sup>3</sup>

Exceedances: None

Exceedances: None

3 Site Tours Conducted per Work Shift

**DATE: 06/11/2007**

AREA:	TIME:	Tour #:													TOUR AVERAGE:	
PERIMETER OF BUILDING	0900-0905	Tour 1	23	23	20	20	20	21	22	20	19	19	20	20	20.58	
	1200-1205	Tour 2	21	21	20	20	19	18	19	19	24	22	21	21		20.42
	1500-1505	Tour 3	20	20	20	19	20	19	21	21	22	23	23	20		20.67
5th FLOOR SETBACK	0910-0915	Tour 1	25	26	26	26	27	28	26	24	24	24	23	20	24.92	
	1210-1215	Tour 2	26	26	28	26	26	26	21	20	26	26	25	23		24.92
	1510-1515	Tour 3	25	25	24	25	26	24	23	23	20	24	24	23.83		
ROOF PERIMETER	0925-0930	Tour 1	30	30	31	30	29	29	28	31	30	30	30	30	29.83	
	1225-1230	Tour 2	30	31	31	30	29	28	28	29	31	31	31	30		29.92
	1525-1530	Tour 3	30	30	29	28	28	30	30	31	33	31	30	30		30.00

**DATE: 06/12/2007**

AREA:	TIME:	Tour #:													TOUR AVERAGE:	
PERIMETER OF BUILDING	0900-0905	Tour 1	25	25	24	23	20	20	23	20	21	22	20	20	21.92	
	1200-1205	Tour 2	26	25	25	25	23	30	28	25	24	23	20	21		24.58
	1500-1505	Tour 3	20	21	24	24	26	26	25	26	25	26	26	27		24.67
5th FLOOR SETBACK	0910-0915	Tour 1	26	26	23	23	24	23	26	27	28	27	26	26	25.42	
	1210-1215	Tour 2	26	25	25	23	26	25	26	26	27	26	26	26		25.58
	1510-1515	Tour 3	25	26	25	27	27	26	25	26	26	27	26	28		26.17
ROOF PERIMETER	0925-0930	Tour 1	30	30	29	28	28	27	29	30	30	34	30	31	29.67	
	1225-1230	Tour 2	30	30	29	29	30	31	30	30	30	29	28	29		29.58
	1525-1530	Tour 3	30	29	29	30	36	35	30	30	34	33	30	29		31.25

**DATE: 06/13/2007**

AREA:	TIME:	Tour #:													TOUR AVERAGE:	
PERIMETER OF BUILDING	0900-0905	Tour 1	23	23	22	21	20	20	20	23	23	23	22	23	21.92	
	1200-1205	Tour 2	25	23	23	20	21	20	19	19	20	23	23	24		21.67
	1500-1505	Tour 3	24	23	23	25	26	25	23	20	20	19	21	21		22.50
5th FLOOR SETBACK	0910-0915	Tour 1	26	26	25	26	26	23	27	28	26	26	27	28	26.17	
	1210-1215	Tour 2	28	27	28	28	26	27	26	28	25	25	26	26		26.67
	1510-1515	Tour 3	27	27	26	26	28	29	27	27	26	25	26	26		26.67
ROOF PERIMETER	0925-0930	Tour 1	29	30	30	30	30	29	28	28	29	30	30	30	29.42	
	1225-1230	Tour 2	30	31	30	30	30	29	28	29	30	30	31	30		29.83
	1525-1530	Tour 3	30	34	36	31	31	30	29	28	30	30	31	32		31.00

**DATE: 06/14/2007**

AREA:	TIME:	Tour #:													TOUR AVERAGE:	
PERIMETER OF BUILDING	0900-0905	Tour 1	21	22	21	23	24	20	22	21	21	23	22	22	21.83	
	1200-1205	Tour 2	20	22	20	21	21	23	21	22	22	22	21	20		21.25
	1500-1505	Tour 3	20	21	20	23	21	22	22	21	20	21	20	21		21.00
5th FLOOR SETBACK	0910-0915	Tour 1	26	24	26	24	25	27	26	28	26	25	26	27	25.83	
	1210-1215	Tour 2	25	25	27	26	27	28	27	27	26	25	26	26		26.25
	1510-1515	Tour 3	27	28	26	25	27	26	28	27	25	26	25	26		26.33
ROOF PERIMETER	0925-0930	Tour 1	29	29	30	29	31	30	32	31	33	30	31	30	30.42	
	1225-1230	Tour 2	31	30	29	31	33	32	33	31	30	32	32	33		31.42
	1525-1530	Tour 3	31	33	34	32	30	29	30	31	32	30	31	31		31.17

**DATE: 06/15/2007**

AREA:	TIME:	Tour #:													TOUR AVERAGE:	
PERIMETER OF BUILDING	0900-0905	Tour 1	20	21	21	20	21	23	22	21	20	21	23	23	21.33	
	1200-1205	Tour 2	20	20	21	23	22	23	24	22	22	23	21	21		21.83
	1500-1505	Tour 3	22	21	23	24	24	22	20	21	20	21	20	22		21.67
5th FLOOR SETBACK	0910-0915	Tour 1	24	26	27	26	25	26	24	25	27	26	27	27	25.83	
	1210-1215	Tour 2	24	25	26	25	24	25	27	26	28	26	25	26		25.58
	1510-1515	Tour 3	26	27	28	27	28	28	26	25	26	24	24	24		26.08
ROOF PERIMETER	0925-0930	Tour 1	31	30	32	33	32	34	32	30	31	33	32	34	32.00	
	1225-1230	Tour 2	33	34	33	35	32	33	31	30	30	30	31	31		31.92
	1525-1530	Tour 3	34	35	30	32	33	31	33	35	34	34	33	35		33.25

**DATE: 06/16/2007**

AREA:	TIME:	Tour #:													TOUR AVERAGE:	
PERIMETER OF BUILDING	0900-0905	Tour 1	20	19	19	20	21	22	22	23	20	20	19	19	20.33	
	1200-1205	Tour 2	20	20	21	20	20	22	23	23	23	20	19	18		20.75
	1500-1505	Tour 3	20	18	19	19	20	21	21	20	22	22	23	20		20.42
5th FLOOR SETBACK	0910-0915	Tour 1	26	25	25	25	24	26	24	23	23	20	21	20	23.50	
	1210-1215	Tour 2	26	26	27	26	25	24	24	23	20	20	20	21		23.50
	1510-1515	Tour 3	20	26	26	23	23	23	22	20	20	24	23	21		22.58
ROOF PERIMETER	0925-0930	Tour 1	28	28	29	30	30	29	30	30	31	31	30	29	29.58	
	1225-1230	Tour 2	30	30	31	32	29	28	28	30	29	28	27	28		29.17
	1525-1530	Tour 3	29	30	30	30	31	34	35	30	28	29	28	27		30.08

**DATE: 06/17/2007**

AREA:	TIME:	Tour #:													TOUR AVERAGE:	
PERIMETER OF BUILDING	0900-0905	Tour 1	20	19	19	21	21	20	24	23	20	19	18	20	20.33	
	1200-1205	Tour 2	21	21	23	23	21	26	25	24	24	20	21	19		22.33
	1500-1505	Tour 3	20	20	26	25	21	21	19	19	20	20	21	24		21.33
5th FLOOR SETBACK	0910-0915	Tour 1	25	25	26	24	24	23	21	20	20	19	25	24	23.00	
	1210-1215	Tour 2	26	26	25	24	23	20	20	20	19	19	21	20		21.92
	1510-1515	Tour 3	26	26	25	26	26	25	23	20	20	24	22	21		23.67
ROOF PERIMETER	0925-0930	Tour 1	30	31	30	30	29	29	28	26	31	36	31	31	30.17	
	1225-1230	Tour 2	31	31	30	29	28	28	27	28	30	31	30	30		29.42
	1525-1530	Tour 3	30	30	29	30	34	33	30	31	29	28	28	27		29.92

Submittal Summary - Scaffold Phase Week Seven (06/11/07 to 06/17/07)

Lab Name	Field Sample ID	Sample Location	Date Collected	Project Phase	Sample Volume (m3)	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Antimony Concentration (ng/m <sup>3</sup> )	Barium Concentration (ng/m <sup>3</sup> )	Beryllium Concentration (ng/m <sup>3</sup> )	Cadmium Concentration (ng/m <sup>3</sup> )	Chromium (Total) Concentration (ng/m <sup>3</sup> )	Copper Concentration (ng/m <sup>3</sup> )	Lead Concentration (ng/m <sup>3</sup> )	Manganese Concentration (ng/m <sup>3</sup> )	Nickel Concentration (ng/m <sup>3</sup> )	Zinc Concentration (ng/m <sup>3</sup> )	Unit	Flag	Qualifier	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels										5,000	5,000	20	500	10,000	1,000	500	200	10,000	1,000	200	10,000					
EPA Site Specific Trigger Levels										14,000	9,000	290	10	100,000	3,000	500	200	100,000	10,000	200	100,000					
STL-SAC	PH-061107-20	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/11/2007	Scaffold	5.76	GTF130181001	6/13/2007	6/16/2007	6020	-34.7	<17.0	<17.4	<17.4	184	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/18/2007	No	No	
STL-SAC	PH-061107-21	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/11/2007	Scaffold	5.76	GTF130181002	6/13/2007	6/16/2007	6020	-34.7	<17.0	<17.4	<17.4	198	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/18/2007	No	No	
STL-SAC	PH-061107-22	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/11/2007	Scaffold	5.76	GTF130181003	6/13/2007	6/16/2007	6020	-34.7	<17.0	<17.4	<17.4	178	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/18/2007	No	No	
STL-SAC	PH-061107-23	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/11/2007	Scaffold	5.76	GTF130181004	6/13/2007	6/16/2007	6020	-34.7	<17.0	<17.4	<17.4	185	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/18/2007	No	No	
STL-SAC	PH-061107-24	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/11/2007	Scaffold	5.76	GTF130181005	6/13/2007	6/16/2007	6020	-34.7	<17.0	<17.4	<17.4	194	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/18/2007	No	No	
STL-SAC	PH-061107-25	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/11/2007	Scaffold	5.76	GTF130181006	6/13/2007	6/16/2007	6020	-34.7	<17.0	<17.4	<17.4	174	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/18/2007	No	No	
STL-SAC	PH-061207-20	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/12/2007	Scaffold	5.76	GTF140236001	6/14/2007	6/16/2007	6020	-34.7	<17.0	<17.4	<17.4	177	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/19/2007	No	No	
STL-SAC	PH-061207-21	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/12/2007	Scaffold	5.76	GTF140236002	6/14/2007	6/16/2007	6020	-34.7	<17.0	<17.4	<17.4	174	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/19/2007	No	No	
STL-SAC	PH-061207-22	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/12/2007	Scaffold	5.76	GTF140236003	6/14/2007	6/16/2007	6020	-34.7	<17.0	<17.4	<17.4	174	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/19/2007	No	No	
STL-SAC	PH-061207-23	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/12/2007	Scaffold	5.76	GTF140236004	6/14/2007	6/16/2007	6020	-34.7	<17.0	<17.4	<17.4	178	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/19/2007	No	No	
STL-SAC	PH-061207-24	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/12/2007	Scaffold	5.76	GTF140236005	6/14/2007	6/16/2007	6020	-34.7	<17.0	<17.4	<17.4	207	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/19/2007	No	No	
STL-SAC	PH-061207-25	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/12/2007	Scaffold	5.76	GTF140236006	6/14/2007	6/16/2007	6020	-34.7	<17.0	<17.4	<17.4	186	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/19/2007	No	No	
STL-SAC	PH-061207-47	DUPLICATE (STATION 1)	6/12/2007	Scaffold	5.76	GTF140236008	6/14/2007	6/16/2007	6020	-34.7	<17.0	<17.4	<17.4	174	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/19/2007	No	No	
STL-SAC	PH-061307-20	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/13/2007	Scaffold	5.76	GTF150293001	6/15/2007	6/16/2007	6020	-34.7	<17.0	<17.4	<17.4	187	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/20/2007	No	No	
STL-SAC	PH-061307-21	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/13/2007	Scaffold	5.76	GTF150293002	6/15/2007	6/16/2007	6020	-34.7	<17.0	<17.4	<17.4	176	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/20/2007	No	No	
STL-SAC	PH-061307-22	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/13/2007	Scaffold	5.76	GTF150293003	6/15/2007	6/16/2007	6020	-34.7	<17.0	<17.4	<17.4	210	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/20/2007	No	No	
STL-SAC	PH-061307-23	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/13/2007	Scaffold	5.76	GTF150293004	6/15/2007	6/16/2007	6020	-34.7	<17.0	<17.4	<17.4	174	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/20/2007	No	No	
STL-SAC	PH-061307-24	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/13/2007	Scaffold	5.76	GTF150293005	6/15/2007	6/16/2007	6020	-34.7	<17.0	<17.4	<17.4	174	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/20/2007	No	No	
STL-SAC	PH-061307-25	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/13/2007	Scaffold	5.76	GTF150293006	6/15/2007	6/16/2007	6020	-34.7	<17.0	<17.4	<17.4	174	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/20/2007	No	No	
STL-SAC	PH-061407-20	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/14/2007	Scaffold	5.76	GTF160167001	6/16/2007	6/20/2007	6020	-34.7	<17.0	<17.4	<17.4	178	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/21/2007	No	No	
STL-SAC	PH-061407-21	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/14/2007	Scaffold	5.76	GTF160167002	6/16/2007	6/20/2007	6020	-34.7	<17.0	<17.4	<17.4	174	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/21/2007	No	No	
STL-SAC	PH-061407-22	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/14/2007	Scaffold	5.76	GTF160167003	6/16/2007	6/20/2007	6020	-34.7	<17.0	<17.4	<17.4	180	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/21/2007	No	No	
STL-SAC	PH-061407-23	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/14/2007	Scaffold	5.76	GTF160167004	6/16/2007	6/20/2007	6020	-34.7	<17.0	<17.4	<17.4	174	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/21/2007	No	No	
STL-SAC	PH-061407-24	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/14/2007	Scaffold	5.76	GTF160167005	6/16/2007	6/20/2007	6020	-34.7	<17.0	<17.4	<17.4	194	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/21/2007	No	No	
STL-SAC	PH-061407-25	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/14/2007	Scaffold	5.76	GTF160167006	6/16/2007	6/20/2007	6020	-34.7	<17.0	<17.4	<17.4	214	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/21/2007	No	No	
STL-SAC	PH-061507-20	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/15/2007	Scaffold	5.76	GTF190205001	6/19/2007	6/21/2007	6020	-34.7	<17.0	<17.4	<17.4	174	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/22/2007	No	No	
STL-SAC	PH-061507-21	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/15/2007	Scaffold	5.76	GTF190205002	6/19/2007	6/21/2007	6020	-34.7	<17.0	<17.4	<17.4	174	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/22/2007	No	No	
STL-SAC	PH-061507-22	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/15/2007	Scaffold	5.76	GTF190205003	6/19/2007	6/21/2007	6020	-34.7	<17.0	<17.4	<17.4	174	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/22/2007	No	No	
STL-SAC	PH-061507-23	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/15/2007	Scaffold	5.76	GTF190205004	6/19/2007	6/21/2007	6020	-34.7	<17.0	<17.4	<17.4	177	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/22/2007	No	No	
STL-SAC	PH-061507-24	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/15/2007	Scaffold	5.76	GTF190205005	6/19/2007	6/21/2007	6020	-34.7	<17.0	<17.4	<17.4	174	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/22/2007	No	No	
STL-SAC	PH-061507-25	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/15/2007	Scaffold	5.76	GTF190205006	6/19/2007	6/21/2007	6020	-34.7	<17.0	<17.4	<17.4	174	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/22/2007	No	No	
STL-SAC	PH-061607-20	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/16/2007	Scaffold	5.76	GTF190209001	6/19/2007	6/21/2007	6020	-34.7	<17.0	<17.4	<17.4	174	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/22/2007	No	No	
STL-SAC	PH-061607-21	#2 - SIDEWALK BRIDGE LEVEL SW CORNER	6/16/2007	Scaffold	5.76	GTF190209002	6/19/2007	6/21/2007	6020	-34.7	<17.0	<17.4	<17.4	174	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/22/2007	No	No	
STL-SAC	PH-061607-22	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	6/16/2007	Scaffold	5.76	GTF190209003	6/19/2007	6/21/2007	6020	-34.7	<17.0	<17.4	<17.4	174	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/22/2007	No	No	
STL-SAC	PH-061607-23	#4 - SIDEWALK BRIDGE LEVEL NE CORNER	6/16/2007	Scaffold	5.76	GTF190209004	6/19/2007	6/21/2007	6020	-34.7	<17.0	<17.4	<17.4	174	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/22/2007	No	No	
STL-SAC	PH-061607-24	#5 - 5TH FLOOR SETBACK ROOF N SIDE	6/16/2007	Scaffold	5.76	GTF190209005	6/19/2007	6/21/2007	6020	-34.7	<17.0	<17.4	<17.4	174	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/22/2007	No	No	
STL-SAC	PH-061607-25	#6 - 5TH FLOOR SETBACK ROOF SW SIDE	6/16/2007	Scaffold	5.76	GTF190209006	6/19/2007	6/21/2007	6020	-34.7	<17.0	<17.4	<17.4	174	<86.8	<17.4	<86.8	<86.8	<347	ng/m <sup>3</sup>			6/22/2007	No	No	
STL-SAC	PH-061707-20	#1 - SIDEWALK BRIDGE LEVEL NW CORNER	6/17/2007	Scaffold	5.76	GTF190212001	6/19/2007	6/21/2																		



**Submittal Summary - Scaffold Phase Week Seven (06/11/07 to 06/17/07)**

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m <sup>3</sup> )	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	Dioxin/Furans Concentration (ng/m <sup>3</sup> )	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
<b>Target Air Quality Levels</b>											0.00025				
<b>EPA Site Specific Trigger Levels</b>											0.025				
STL-SAC	FH-061107-40	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	06/11/07	Scaffold	360	G7F130195003	06/13/2007	06/26/2007	TO-9	Toxicity Equivalent Quotient (TEQ)	0.000046	06/27/2007	No	No	

**Submittal Summary - Scaffold Phase Week Seven (06/11/07 to 06/17/07)**

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m <sup>3</sup> )	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	PAHs Concentration (ug/m3)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											0.034				
EPA Site Specific Trigger Levels											3.4				
STL-SAC	FH-061107-49	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	06/11/07	Scaffold	360	G7F130203003	06/13/2007	06/15/2007	8270C SIM	BAP-equivalent	<0.0035	06/26/2007	No	No	

**Submittal Summary - Scaffold Phase Week Seven (06/11/07 to 06/17/07)**

Lab Name	Airtek Field Sample No.	Sample Location	Collection Start Date	Project Phase	Sample Volume (m <sup>3</sup> )	Lab Sample ID	Date Received	Date Analyzed	Analytical Method	Parameter Name	PCBs Concentration (ug/m3)	Date Reported	Exceeds Target Air Quality Levels?	Exceeds EPA Site Specific Trigger Levels?	Comments
Target Air Quality Levels											0.12				
EPA Site Specific Trigger Levels											12				
STL-SAC	FH-061107-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	06/11/2007	Scaffold	360	G7F130206003	06/13/2007	06/19/2007	TO-4	Aroclor 1016	<0.0021	06/27/2007	No	No	
STL-SAC	FH-061107-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	06/11/2007	Scaffold	360	G7F130206003	06/13/2007	06/19/2007	TO-4	Aroclor 1221	<0.0021	06/27/2007	No	No	
STL-SAC	FH-061107-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	06/11/2007	Scaffold	360	G7F130206003	06/13/2007	06/19/2007	TO-4	Aroclor 1232	<0.0021	06/27/2007	No	No	
STL-SAC	FH-061107-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	06/11/2007	Scaffold	360	G7F130206003	06/13/2007	06/19/2007	TO-4	Aroclor 1242	<0.0021	06/27/2007	No	No	
STL-SAC	FH-061107-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	06/11/2007	Scaffold	360	G7F130206003	06/13/2007	06/19/2007	TO-4	Aroclor 1248	<0.0021	06/27/2007	No	No	
STL-SAC	FH-061107-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	06/11/2007	Scaffold	360	G7F130206003	06/13/2007	06/19/2007	TO-4	Aroclor 1254	<0.0021	06/27/2007	No	No	
STL-SAC	FH-061107-58	#3 - SIDEWALK BRIDGE LEVEL SE CORNER	06/11/2007	Scaffold	360	G7F130206003	06/13/2007	06/19/2007	TO-4	Aroclor 1260	<0.0021	06/27/2007	No	No	